Portland Public Schools
Lead and Copper Water Sampling Results
Initial and Follow Up Flush Sample Data
2nd Site Visit - Rose City Park Elementary

Sample Identification #	Location	Date Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
278-4990-A-001-A	Porcelain Drinking Fountain - Hallway Near North Gym	11/9/2018	11/12/2018	A8K0325-01	Copper	0.0160	0.00200	1.3	ppm
278-4990-A-001-A	Porcelain Drinking Fountain - Hallway Near North Gym	11/9/2018	11/12/2018	A8K0325-01	Lead	2.22	0.200	15	ppb
278-4990-A-001-B	Porcelain Drinking Fountain - Hallway Near North Gym	11/9/2018	11/12/2018	A8K0325-02	Copper	0.0737	0.00200	1.3	ppm
278-4990-A-001-B	Porcelain Drinking Fountain - Hallway Near North Gym	11/9/2018	11/12/2018	A8K0325-02	Lead	6.50	0.200	15	ppb
278-4990-B-001-A	Porcelain Drinking Fountain - Hallway Near North Gym	11/9/2018	11/12/2018	A8K0325-03	Copper	0.0488	0.00200	1.3	ppm
278-4990-B-001-A	Porcelain Drinking Fountain - Hallway Near North Gym	11/9/2018	11/12/2018	A8K0325-03	Lead	6.23	0.200	15	ppb
278-4990-B-001-B	Porcelain Drinking Fountain - Hallway Near North Gym	11/9/2018	11/12/2018	A8K0325-04	Copper	0.0991	0.00200	1.3	ppm
278-4990-B-001-B	Porcelain Drinking Fountain - Hallway Near North Gym	11/9/2018	11/12/2018	A8K0325-04	Lead	11.5	0.200	15	ppb
278-4989-NA-001-A	Sink Bubbler - Classroom 116	11/9/2018	11/13/2018	A8K0325-05	Copper	0.240	0.00200	1.3	ppm
278-4989-NA-001-A	Sink Bubbler - Classroom 116	11/9/2018	11/13/2018	A8K0325-05	Lead	39.9	0.200	15	ppb
278-4989-NA-001-B	Sink Bubbler - Classroom 116	11/9/2018	11/12/2018	A8K0325-06	Copper	0.424	0.00200	1.3	ppm
278-4989-NA-001-B	Sink Bubbler - Classroom 116	11/9/2018	11/12/2018	A8K0325-06	Lead	11.0	0.200	15	ppb
278-4992-NA-001-A	Sink Bubbler - Classroom 115	11/9/2018	11/13/2018	A8K0325-07	Copper	0.134	0.00200	1.3	ppm
278-4992-NA-001-A	Sink Bubbler - Classroom 115	11/9/2018	11/13/2018	A8K0325-07	Lead	27.7	0.200	15	ppb
278-4992-NA-001-B	Sink Bubbler - Classroom 115	11/9/2018	11/13/2018	A8K0325-08	Copper	0.368	0.00200	1.3	ppm
278-4992-NA-001-B	Sink Bubbler - Classroom 115	11/9/2018	11/13/2018	A8K0325-08	Lead	17.4	0.200	15	ppb
278-Unk#2-NA-001-A	Sink Bubbler - Classroom 16	11/9/2018	11/13/2018	A8K0325-09	Copper	0.480	0.00200	1.3	ppm
278-Unk#2-NA-001-A	Sink Bubbler - Classroom 16	11/9/2018	11/13/2018	A8K0325-09	Lead	25.6	0.200	15	ppb
278-Unk#2-NA-001-B	Sink Bubbler - Classroom 16	11/9/2018	11/13/2018	A8K0325-10	Copper	0.305	0.00200	1.3	ppm
278-Unk#2-NA-001-B	Sink Bubbler - Classroom 16	11/9/2018	11/13/2018	A8K0325-10	Lead	7.44	0.200	15	ppb

Results highlighted indicate a value at or above the PPS Action Level and that the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

Analyzed by: Apex Laboratories
Reviewed by: G2 Consultants, Inc.