

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Rose City Park - Test 5**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
278-CH-5704-A-005-A	Hallway (Gym)	9/10/2019	9/11/2019	A9I0288-06	Lead	3.69	0.20	15	ppb

Results highlighted indicate a value at or above PPS Action Level and the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.