

Portland Public Schools
Lead and Copper Water Sampling Results
Initial and Follow Up Flush Sample Data
Boise Elliot

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
141-CH2692-A-001-A	Hall Bubbler	3/2/2018 0:00	3/12/2018	A8C0112-07RE1	Copper	1.52	0.00500	1.3	ppm
141-CH2692-A-001-A	Hall Bubbler	3/2/2018 0:00	3/12/2018	A8C0112-07	Lead	9.11	0.200	15	ppb
141-CH2692-A-001-B	Hall Bubbler	3/2/2018 0:00	3/13/2018	A8C0112-08RE1	Copper	1.12	0.00500	1.3	ppm
141-CH2692-A-001-B	Hall Bubbler	3/2/2018 0:00	3/13/2018	A8C0112-08	Lead	0.998	0.200	15	ppb
141-CH2692-B-001-A	Hall Bubbler	3/2/2018 0:00	3/13/2018	A8C0112-09RE1	Copper	0.648	0.00500	1.3	ppm
141-CH2692-B-001-A	Hall Bubbler	3/2/2018 0:00	3/13/2018	A8C0112-09	Lead	1.16	0.200	15	ppb
141-CH2692-B-001-B	Hall Bubbler	3/2/2018 0:00	3/13/2018	A8C0112-10	Copper	0.231	0.00100	1.3	ppm
141-CH2692-B-001-B	Hall Bubbler	3/2/2018 0:00	3/13/2018	A8C0112-10	Lead	ND	0.200	15	ppb
141-CH3534-A-001-A	Kitchen Sprayer	3/2/2018 0:00	3/12/2018	A8C0112-01	Copper	0.141	0.00100	1.3	ppm
141-CH3534-A-001-A	Kitchen Sprayer	3/2/2018 0:00	3/13/2018	A8C0112-01	Lead	3.76	0.200	15	ppb
141-CH3534-A-001-B	Kitchen Sprayer	3/2/2018 0:00	3/13/2018	A8C0112-02	Copper	0.154	0.00100	1.3	ppm
141-CH3534-A-001-B	Kitchen Sprayer	3/2/2018 0:00	3/13/2018	A8C0112-02	Lead	0.749	0.200	15	ppb
141-CH3535-N/A-001-A	Hall Bubbler	3/2/2018 0:00	3/13/2018	A8C0112-03RE1	Copper	0.752	0.00500	1.3	ppm
141-CH3535-N/A-001-A	Hall Bubbler	3/2/2018 0:00	3/13/2018	A8C0112-03	Lead	0.592	0.200	15	ppb
141-CH3535-N/A-001-B	Hall Bubbler	3/2/2018 0:00	3/13/2018	A8C0112-04RE1	Copper	0.699	0.00500	1.3	ppm
141-CH3535-N/A-001-B	Hall Bubbler	3/2/2018 0:00	3/13/2018	A8C0112-04	Lead	ND	0.200	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

141-CH3538-N/A-001-A	Hall Bubbler	3/2/2018 0:00	3/13/2018	A8C0112-05RE1	Copper	0.592	0.00500	1.3	ppm
141-CH3538-N/A-001-A	Hall Bubbler	3/2/2018 0:00	3/13/2018	A8C0112-05	Lead	0.301	0.200	15	ppb
141-CH3538-N/A-001-B	Hall Bubbler	3/2/2018 0:00	3/12/2018	A8C0112-06	Copper	0.0898	0.00100	1.3	ppm
141-CH3538-N/A-001-B	Hall Bubbler	3/2/2018 0:00	3/12/2018	A8C0112-06	Lead	ND	0.200	15	ppb

Results highlighted yellow indicate a value at or above the PPS Action Level and that the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.