

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Boise-Elliott/Humboldt School - Test 4**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
141-CH3514-N/A-004-A	Classroom 103	4/12/2019	4/24/2019	A9D0545-01	Lead	3.14	0.20	15	ppb
141-CH3529-N/A-004-A	Hallway (101)	4/12/2019	4/22/2019	A9D0545-02	Lead	9.28	0.20	15	ppb
141-CH3532-N/A-004-A	Classroom 106	4/12/2019	4/22/2019	A9D0545-03	Lead	11.7	0.20	15	ppb
141-CH2675-N/A-004-A	Classroom 120	4/12/2019	4/22/2019	A9D0545-04	Lead	10.5	0.20	15	ppb
141-CH2678-N/A-004-A	Classroom 122	4/12/2019	4/22/2019	A9D0545-05	Lead	8.86	0.20	15	ppb
141-CH2687-N/A-004-A	Classroom 126	4/12/2019	4/22/2019	A9D0545-06	Lead	12.5	0.20	15	ppb
141-CH2693-N/A-004-A	Classroom 137	4/12/2019	4/22/2019	A9D0545-07	Lead	5.54	0.20	15	ppb
141-CH2685-N/A-004-A	Classroom 229	4/12/2019	4/22/2019	A9D0545-08	Lead	5.64	0.20	15	ppb
141-CH2697-N/A-004-A	Classroom 228	4/12/2019	4/22/2019	A9D0545-09	Lead	2.68	0.20	15	ppb
141-CH2700-N/A-004-A	Classroom 226	4/12/2019	4/22/2019	A9D0545-10	Lead	3.84	0.20	15	ppb
141-CH2683-N/A-004-A	Classroom 224	4/12/2019	4/22/2019	A9D0545-11	Lead	4.52	0.20	15	ppb
141-CH2698-N/A-004-A	Classroom 211	4/12/2019	4/22/2019	A9D0545-12	Lead	4.33	0.20	15	ppb
141-CH2735-A-004-A	Hallway (209)	4/12/2019	4/22/2019	A9D0545-13	Lead	14.3	0.20	15	ppb
141-CH2735-B-004-A	Hallway (209)	4/12/2019	4/22/2019	A9D0545-14	Lead	6.98	0.20	15	ppb
141-CH2744-N/A-004-A	Classroom 202	4/12/2019	4/22/2019	A9D0545-15	Lead	4.54	0.20	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb