

**Portland Public Schools**  
**Lead and Copper Water Sampling Results**  
**A (Initial) and B (Follow-Up) Sample Data**  
**Bridger Elementary School**

| Sample Identification # and Location      | Date/Time Collected | Date/Time Analyzed | Container ID | Analyte | Results | PPS Action Level* | Units |
|-------------------------------------------|---------------------|--------------------|--------------|---------|---------|-------------------|-------|
| 238-4972-A-001A Hallway near Boys RR 3    | 08/01/18 7:15 AM    | 08/02/18 7:05 PM   | 18017010     | Copper  | 0.3     | 1.3               | ppm   |
| 238-4972-A-001A Hallway near Boys RR 3    | 08/01/18 7:15 AM    | 08/02/18 7:05 PM   | 18017010     | Lead    | 7       | 15                | ppb   |
| 238-4972-A-001B Hallway near Boys RR 3    | 08/01/18 7:15 AM    | 08/02/18 7:07 PM   | 18017011     | Copper  | 0.3     | 1.3               | ppm   |
| 238-4972-A-001B Hallway near Boys RR 3    | 08/01/18 7:15 AM    | 08/02/18 7:07 PM   | 18017011     | Lead    | 1       | 15                | ppb   |
| 238-4972-B-001A Hallway near Boys RR 3    | 08/01/18 7:20 AM    | 08/02/18 7:10 PM   | 18017001     | Copper  | 0.2     | 1.3               | ppm   |
| 238-4972-B-001A Hallway near Boys RR 3    | 08/01/18 7:20 AM    | 08/02/18 7:10 PM   | 18017001     | Lead    | 1       | 15                | ppb   |
| 238-4972-B-001B Hallway near Boys RR 3    | 08/01/18 7:20 AM    | 08/02/18 7:12 PM   | 18017008     | Copper  | 0.1     | 1.3               | ppm   |
| 238-4972-B-001B Hallway near Boys RR 3    | 08/01/18 7:20 AM    | 08/02/18 7:12 PM   | 18017008     | Lead    | <1      | 15                | ppb   |
| 238-4626-A-001A Hallway near Boys RR 20   | 08/01/18 7:25 AM    | 08/02/18 7:55 PM   | 18017002     | Copper  | 0.5     | 1.3               | ppm   |
| 238-4626-A-001A Hallway near Boys RR 20   | 08/01/18 7:25 AM    | 08/02/18 7:55 PM   | 18017002     | Lead    | 4       | 15                | ppb   |
| 238-4626-A-001B Hallway near Boys RR 20   | 08/01/18 7:25 AM    | 08/02/18 7:57 PM   | 18017006     | Copper  | 0.1     | 1.3               | ppm   |
| 238-4626-A-001B Hallway near Boys RR 20   | 08/01/18 7:25 AM    | 08/02/18 7:57 PM   | 18017006     | Lead    | <1      | 15                | ppb   |
| 238-4642-A-001A Hallway near Girls RR 25  | 08/01/18 7:30 AM    | 08/02/18 7:59 PM   | 18017013     | Copper  | 0.2     | 1.3               | ppm   |
| 238-4642-A-001A Hallway near Girls RR 25  | 08/01/18 7:30 AM    | 08/02/18 7:59 PM   | 18017013     | Lead    | 21      | 15                | ppb   |
| 238-4642-A-001B Hallway near Girls RR 25  | 08/01/18 7:30 AM    | 08/02/18 8:01 PM   | 18017007     | Copper  | 0.3     | 1.3               | ppm   |
| 238-4642-A-001B Hallway near Girls RR 25  | 08/01/18 7:30 AM    | 08/02/18 8:01 PM   | 18017007     | Lead    | 1       | 15                | ppb   |
| 238-4642-B-001A Hallway near Girls RR 25  | 08/01/18 7:30 AM    | 08/02/18 7:14 PM   | 18017012     | Copper  | 0.2     | 1.3               | ppm   |
| 238-4642-B-001A Hallway near Girls RR 25  | 08/01/18 7:30 AM    | 08/02/18 7:14 PM   | 18017012     | Lead    | 5       | 15                | ppb   |
| 238-4642-B-001B Hallway near Girls RR 25  | 08/01/18 7:30 AM    | 08/02/18 7:17 PM   | 18017003     | Copper  | 0.2     | 1.3               | ppm   |
| 238-4642-B-001B Hallway near Girls RR 25  | 08/01/18 7:30 AM    | 08/02/18 7:17 PM   | 18017003     | Lead    | 1       | 15                | ppb   |
| 238-4645-A-001A Cafeteria East Wall       | 08/01/18 7:35 AM    | 08/02/18 7:19 PM   | 18017004     | Copper  | 0.2     | 1.3               | ppm   |
| 238-4645-A-001A Cafeteria East Wall       | 08/01/18 7:35 AM    | 08/02/18 7:19 PM   | 18017004     | Lead    | 16      | 15                | ppb   |
| 238-4645-A-001B Cafeteria East Wall       | 08/01/18 7:35 AM    | 08/02/18 7:21 PM   | 18017009     | Copper  | 0.2     | 1.3               | ppm   |
| 238-4645-A-001B Cafeteria East Wall       | 08/01/18 7:35 AM    | 08/02/18 7:21 PM   | 18017009     | Lead    | 2       | 15                | ppb   |
| 238-4978-A-001A Gymnasium South Wall      | 08/01/18 7:40 AM    | 08/02/18 6:29 PM   | 18017000     | Copper  | 0.5     | 1.3               | ppm   |
| 238-4978-A-001A Gymnasium South Wall      | 08/01/18 7:40 AM    | 08/02/18 6:29 PM   | 18017000     | Lead    | 8       | 15                | ppb   |
| 238-4978-A-001B Gymnasium South Wall      | 08/01/18 7:40 AM    | 08/02/18 6:31 PM   | 18017005     | Copper  | 0.8     | 1.3               | ppm   |
| 238-4978-A-001B Gymnasium South Wall      | 08/01/18 7:40 AM    | 08/02/18 6:31 PM   | 18017005     | Lead    | 1       | 15                | ppb   |
| 238-4977-A-001A Gymnasium Storage Closet  | 08/01/18 7:45 AM    | 08/02/18 7:23 PM   | 18017017     | Copper  | 0.4     | 1.3               | ppm   |
| 238-4977-A-001A Gymnasium Storage Closet  | 08/01/18 7:45 AM    | 08/02/18 7:23 PM   | 18017017     | Lead    | 9       | 15                | ppb   |
| 238-4977-A-001B Gymnasium Storage Closet  | 08/01/18 7:45 AM    | 08/02/18 7:26 PM   | 18017021     | Copper  | 0.6     | 1.3               | ppm   |
| 238-4977-A-001B Gymnasium Storage Closet  | 08/01/18 7:45 AM    | 08/02/18 7:26 PM   | 18017021     | Lead    | 1       | 15                | ppb   |
| 238-4975-A-001A Hallway near Classroom 33 | 08/01/18 7:50 AM    | 08/02/18 6:33 PM   | 18017020     | Copper  | 0.4     | 1.3               | ppm   |
| 238-4975-A-001A Hallway near Classroom 33 | 08/01/18 7:50 AM    | 08/02/18 6:33 PM   | 18017020     | Lead    | 7       | 15                | ppb   |
| 238-4975-A-001B Hallway near Classroom 33 | 08/01/18 7:50 AM    | 08/02/18 6:35 PM   | 18017018     | Copper  | 0.4     | 1.3               | ppm   |
| 238-4975-A-001B Hallway near Classroom 33 | 08/01/18 7:50 AM    | 08/02/18 6:35 PM   | 18017018     | Lead    | <1      | 15                | ppb   |
| 238-4975-B-001A Hallway near Classroom 33 | 08/01/18 7:50 AM    | 08/02/18 6:38 PM   | 18017019     | Copper  | 0.4     | 1.3               | ppm   |
| 238-4975-B-001A Hallway near Classroom 33 | 08/01/18 7:50 AM    | 08/02/18 6:38 PM   | 18017019     | Lead    | 1       | 15                | ppb   |
| 238-4975-B-001B Hallway near Classroom 33 | 08/01/18 7:50 AM    | 08/02/18 6:40 PM   | 18017022     | Copper  | 0.4     | 1.3               | ppm   |
| 238-4975-B-001B Hallway near Classroom 33 | 08/01/18 7:50 AM    | 08/02/18 6:40 PM   | 18017022     | Lead    | <1      | 15                | ppb   |

Analyzed by: Pixis Labs

\*EPA action level for lead is 20 ppb and 1.3 for copper

Reviewed by: TRC Environmental Corporation