

Portland Public Schools
Lead and Copper Water Sampling Results
A (Initial) and B (Follow-Up) Sample Data
Bridger Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	PPS Action Level*
238-9010-A-004A Portable M104 (Drinking Fountain)	12/11/18 6:23 AM	12/13/18 8:06 PM	18033391	Copper	< 0.1	1.3
238-9010-A-004A Portable M104 (Drinking Fountain)	12/11/18 6:23 AM	12/13/18 8:06 PM	18033391	Lead	< 1	15
238-9010-A-004B Portable M104 (Drinking Fountain)	12/11/18 6:23 AM	12/13/18 8:10 PM	18033404	Copper	< 0.1	1.3
238-9010-A-004B Portable M104 (Drinking Fountain)	12/11/18 6:23 AM	12/13/18 8:10 PM	18033404	Lead	< 1	15
238-9010-B-004A Portable M104 (Bottle Filler)	12/11/18 6:24 AM	12/13/18 8:13 PM	18033405	Copper	< 0.1	1.3
238-9010-B-004A Portable M104 (Bottle Filler)	12/11/18 6:24 AM	12/13/18 8:13 PM	18033405	Lead	< 1	15
238-9010-B-004B Portable M104 (Bottle Filler)	12/11/18 6:24 AM	12/13/18 8:17 PM	18033406	Copper	< 0.1	1.3
238-9010-B-004B Portable M104 (Bottle Filler)	12/11/18 6:24 AM	12/13/18 8:17 PM	18033406	Lead	< 1	15
238-9011-A-004A Portable M107 (Drinking Fountain)	12/11/18 6:18 AM	12/13/18 8:21 PM	18033407	Copper	< 0.1	1.3
238-9011-A-004A Portable M107 (Drinking Fountain)	12/11/18 6:18 AM	12/13/18 8:21 PM	18033407	Lead	< 1	15
238-9011-A-004B Portable M107 (Drinking Fountain)	12/11/18 6:18 AM	12/17/18 4:37 PM	18033408	Copper	< 0.1	1.3
238-9011-A-004B Portable M107 (Drinking Fountain)	12/11/18 6:18 AM	12/17/18 4:37 PM	18033408	Lead	< 1	15
238-9011-B-004A Portable M107 (Bottle Filler)	12/11/18 6:19 AM	12/13/18 8:24 PM	18033409	Copper	< 0.1	1.3
238-9011-B-004A Portable M107 (Bottle Filler)	12/11/18 6:19 AM	12/13/18 8:24 PM	18033409	Lead	< 1	15
238-9011-B-004B Portable M107 (Bottle Filler)	12/11/18 6:19 AM	12/13/18 8:28 PM	18033410	Copper	< 0.1	1.3
238-9011-B-004B Portable M107 (Bottle Filler)	12/11/18 6:19 AM	12/13/18 8:28 PM	18033410	Lead	< 1	15

Analyzed by: Pixis Labs

*EPA action level for lead is 20 ppb and 1.3 for copper

Reviewed by: TRC Environmental Corporation