

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Bridger K-8 School - Test 5**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
238-CH4629-N/A-005-A	Classroom 21	4/25/2019	5/8/2019	A9D0959-01	Lead	9.33	0.20	15	ppb
238-CH4630-N/A-005-A	Classroom 22	4/25/2019	5/8/2019	A9D0959-02	Lead	3	0.20	15	ppb
238-CH4645-N/A-005-A	Cafeteria	4/25/2019	5/8/2019	A9D0959-03	Lead	10.7	0.20	15	ppb
238-CH4642-A-005-A	Hallway 37	4/25/2019	5/8/2019	A9D0959-04	Lead	2.92	0.20	15	ppb
238-CH4642-B-005-A	Hallway 37	4/25/2019	5/8/2019	A9D0959-05	Lead	2.51	0.20	15	ppb