

Portland Public Schools
Lead and Copper Water Sampling Results
A (Initial) and B (Follow-Up) Sample Data
Bridlemile Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	PPS Action Level*	Units
142-2048-A-001A Kitchen	08/02/18 10:00 AM	08/06/18 9:11 PM	18017305	Copper	0.1	1.3	ppm
142-2048-A-001A Kitchen	08/02/18 10:00 AM	08/06/18 9:11 PM	18017305	Lead	5	15	ppb
142-2048-A-001B Kitchen	08/02/18 10:00 AM	08/06/18 9:13 PM	18017312	Copper	<0.1	1.3	ppm
142-2048-A-001B Kitchen	08/02/18 10:00 AM	08/06/18 9:13 PM	18017312	Lead	<1	15	ppb
142-2049-A-001A Kitchen	08/02/18 10:00 AM	08/06/18 9:15 PM	18017308	Copper	0.1	1.3	ppm
142-2049-A-001A Kitchen	08/02/18 10:00 AM	08/06/18 9:15 PM	18017308	Lead	7	15	ppb
142-2049-A-001B Kitchen	08/02/18 10:00 AM	08/06/18 9:16 PM	18017314	Copper	<0.1	1.3	ppm
142-2049-A-001B Kitchen	08/02/18 10:00 AM	08/06/18 9:16 PM	18017314	Lead	<1	15	ppb
142-2045-A-001A Kitchen	08/02/18 10:35 AM	08/06/18 8:42 PM	18017307	Copper	0.2	1.3	ppm
142-2045-A-001A Kitchen	08/02/18 10:35 AM	08/06/18 8:42 PM	18017307	Lead	20	15	ppb
142-2045-A-001B Kitchen	08/02/18 10:35 AM	08/08/18 1:34 PM	18017316	Copper	0.1	1.3	ppm
142-2045-A-001B Kitchen	08/02/18 10:35 AM	08/08/18 1:34 PM	18017316	Lead	3	15	ppb

Results highlighted indicate a value at or above the PPS Action Level and that the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.

Analyzed by: Pixis Labs

*EPA action level for lead is 20 ppb and 1.3 for copper

Reviewed by: TRC Environmental Corporation

Page 1 of 1