

Portland Public Schools
Lead and Copper Water Sampling Results
A (Initial) and B (Follow-Up) Sample Data
Bridlemile Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	PPS Action Level*	Units
142-2045-A-002A Cafeteria	09/27/18 6:24 AM	10/02/18 7:20 PM	18024389	Copper	< 0.1	1.3	ppm
142-2045-A-002A Cafeteria	09/27/18 6:24 AM	10/02/18 7:20 PM	18024389	Lead	3	15	ppb
142-2045-A-002B Cafeteria	09/27/18 6:24 AM	10/02/18 7:25 PM	18024384	Copper	< 0.1	1.3	ppm
142-2045-A-002B Cafeteria	09/27/18 6:24 AM	10/02/18 7:25 PM	18024384	Lead	4	15	ppb
142-2055-A-002A Hallway (46)	09/27/18 6:30 AM	10/02/18 7:29 PM	18024386	Copper	< 0.1	1.3	ppm
142-2055-A-002A Hallway (46)	09/27/18 6:30 AM	10/02/18 7:29 PM	18024386	Lead	5	15	ppb
142-2055-A-002B Hallway (46)	09/27/18 6:30 AM	10/02/18 7:34 PM	18024391	Copper	< 0.1	1.3	ppm
142-2055-A-002B Hallway (46)	09/27/18 6:30 AM	10/02/18 7:34 PM	18024391	Lead	1	15	ppb
142-2056-A-002A Room 43	09/27/18 6:34 AM	10/02/18 7:39 PM	18024385	Copper	< 0.1	1.3	ppm
142-2056-A-002A Room 43	09/27/18 6:34 AM	10/02/18 7:39 PM	18024385	Lead	5	15	ppb
142-2056-A-002B Room 43	09/27/18 6:34 AM	10/02/18 7:44 PM	18024393	Copper	< 0.1	1.3	ppm
142-2056-A-002B Room 43	09/27/18 6:34 AM	10/02/18 7:44 PM	18024393	Lead	2	15	ppb
142-2057-A-002A Room 42	09/27/18 6:40 AM	10/02/18 7:48 PM	18024382	Copper	< 0.1	1.3	ppm
142-2057-A-002A Room 42	09/27/18 6:40 AM	10/02/18 7:48 PM	18024382	Lead	6	15	ppb
142-2057-A-002B Room 42	09/27/18 6:40 AM	10/02/18 7:53 PM	18024392	Copper	< 0.1	1.3	ppm
142-2057-A-002B Room 42	09/27/18 6:40 AM	10/02/18 7:53 PM	18024392	Lead	2	15	ppb
142-2058-A-002A Room 41	09/27/18 6:44 AM	10/02/18 7:58 PM	18024383	Copper	< 0.1	1.3	ppm
142-2058-A-002A Room 41	09/27/18 6:44 AM	10/02/18 7:58 PM	18024383	Lead	4	15	ppb
142-2058-A-002B Room 41	09/27/18 6:44 AM	10/02/18 8:31 PM	18024379	Copper	< 0.1	1.3	ppm
142-2058-A-002B Room 41	09/27/18 6:44 AM	10/02/18 8:31 PM	18024379	Lead	< 1	15	ppb
142-2054-A-002A Room 44	09/27/18 6:48 AM	10/02/18 8:36 PM	18024388	Copper	< 0.1	1.3	ppm
142-2054-A-002A Room 44	09/27/18 6:48 AM	10/02/18 8:36 PM	18024388	Lead	7	15	ppb
142-2054-A-002B Room 44	09/27/18 6:48 AM	10/02/18 8:40 PM	18024390	Copper	< 0.1	1.3	ppm
142-2054-A-002B Room 44	09/27/18 6:48 AM	10/02/18 8:40 PM	18024390	Lead	2	15	ppb
142-2059-A-002A Room 40	09/27/18 6:52 AM	10/02/18 8:45 PM	18024381	Copper	< 0.1	1.3	ppm
142-2059-A-002A Room 40	09/27/18 6:52 AM	10/02/18 8:45 PM	18024381	Lead	5	15	ppb
142-2059-A-002B Room 40	09/27/18 6:52 AM	10/02/18 8:50 PM	18024387	Copper	< 0.1	1.3	ppm
142-2059-A-002B Room 40	09/27/18 6:52 AM	10/02/18 8:50 PM	18024387	Lead	< 1	15	ppb
142-2053-A-002A Room 45	09/27/18 6:59 AM	10/02/18 8:55 PM	18024380	Copper	< 0.1	1.3	ppm
142-2053-A-002A Room 45	09/27/18 6:59 AM	10/02/18 8:55 PM	18024380	Lead	13	15	ppb
142-2053-A-002B Room 45	09/27/18 6:59 AM	10/02/18 8:59 PM	18024394	Copper	< 0.1	1.3	ppm
142-2053-A-002B Room 45	09/27/18 6:59 AM	10/02/18 8:59 PM	18024394	Lead	3	15	ppb
142-2052-A-002A Room 46	09/27/18 7:03 AM	10/02/18 9:04 PM	18024398	Copper	< 0.1	1.3	ppm
142-2052-A-002A Room 46	09/27/18 7:03 AM	10/02/18 9:04 PM	18024398	Lead	5	15	ppb
142-2052-A-002B Room 46	09/27/18 7:03 AM	10/02/18 9:09 PM	18024399	Copper	< 0.1	1.3	ppm
142-2052-A-002B Room 46	09/27/18 7:03 AM	10/02/18 9:09 PM	18024399	Lead	1	15	ppb
142-2060-A-002A Room 36	09/27/18 7:08 AM	10/02/18 9:14 PM	18024400	Copper	< 0.1	1.3	ppm
142-2060-A-002A Room 36	09/27/18 7:08 AM	10/02/18 9:14 PM	18024400	Lead	9	15	ppb
142-2060-A-002B Room 36	09/27/18 7:08 AM	10/02/18 9:47 PM	18024401	Copper	< 0.1	1.3	ppm
142-2060-A-002B Room 36	09/27/18 7:08 AM	10/02/18 9:47 PM	18024401	Lead	3	15	ppb
142-2061-A-002A Room 35	09/27/18 7:12 AM	10/02/18 9:52 PM	18024402	Copper	< 0.1	1.3	ppm
142-2061-A-002A Room 35	09/27/18 7:12 AM	10/02/18 9:52 PM	18024402	Lead	10	15	ppb
142-2061-A-002B Room 35	09/27/18 7:12 AM	10/02/18 9:56 PM	18024403	Copper	< 0.1	1.3	ppm
142-2061-A-002B Room 35	09/27/18 7:12 AM	10/02/18 9:56 PM	18024403	Lead	3	15	ppb
142-2062-A-002A Room 34	09/27/18 7:18 AM	10/02/18 10:01 PM	18024404	Copper	< 0.1	1.3	ppm
142-2062-A-002A Room 34	09/27/18 7:18 AM	10/02/18 10:01 PM	18024404	Lead	8	15	ppb
142-2062-A-002B Room 34	09/27/18 7:18 AM	10/02/18 10:06 PM	18024405	Copper	< 0.1	1.3	ppm
142-2062-A-002B Room 34	09/27/18 7:18 AM	10/02/18 10:06 PM	18024405	Lead	1	15	ppb
142-2063-A-002A Room 33	09/27/18 7:22 AM	10/02/18 10:11 PM	18024406	Copper	< 0.1	1.3	ppm
142-2063-A-002A Room 33	09/27/18 7:22 AM	10/02/18 10:11 PM	18024406	Lead	2	15	ppb
142-2063-A-002B Room 33	09/27/18 7:22 AM	10/02/18 10:15 PM	18024407	Copper	< 0.1	1.3	ppm

Analyzed by: Pixis Labs

*EPA action level for lead is 20 ppb and 1.3 for copper

Reviewed by: TRC Environmental Corporation

Portland Public Schools
Lead and Copper Water Sampling Results
A (Initial) and B (Follow-Up) Sample Data
Bridlemile Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	PPS Action Level*	Units
142-2063-A-002B Room 33	09/27/18 7:22 AM	10/02/18 10:15 PM	18024407	Lead	< 1	15	ppb
142-2064-A-002A Room 32	09/27/18 7:26 AM	10/02/18 10:20 PM	18024408	Copper	< 0.1	1.3	ppm
142-2064-A-002A Room 32	09/27/18 7:26 AM	10/02/18 10:20 PM	18024408	Lead	7	15	ppb
142-2064-A-002B Room 32	09/27/18 7:26 AM	10/02/18 10:25 PM	18024409	Copper	< 0.1	1.3	ppm
142-2064-A-002B Room 32	09/27/18 7:26 AM	10/02/18 10:25 PM	18024409	Lead	1	15	ppb
142-2070-A-002A Room 26	09/27/18 7:29 AM	10/02/18 10:30 PM	18024410	Copper	< 0.1	1.3	ppm
142-2070-A-002A Room 26	09/27/18 7:29 AM	10/02/18 10:30 PM	18024410	Lead	4	15	ppb
142-2070-A-002B Room 26	09/27/18 7:29 AM	10/02/18 11:03 PM	18024411	Copper	< 0.1	1.3	ppm
142-2070-A-002B Room 26	09/27/18 7:29 AM	10/02/18 11:03 PM	18024411	Lead	1	15	ppb
142-2065-A-002A Room 31	09/27/18 7:34 AM	10/02/18 11:08 PM	18024412	Copper	< 0.1	1.3	ppm
142-2065-A-002A Room 31	09/27/18 7:34 AM	10/02/18 11:08 PM	18024412	Lead	6	15	ppb
142-2065-A-002B Room 31	09/27/18 7:34 AM	10/02/18 11:12 PM	18024413	Copper	< 0.1	1.3	ppm
142-2065-A-002B Room 31	09/27/18 7:34 AM	10/02/18 11:12 PM	18024413	Lead	1	15	ppb
142-2066-A-002A Room 30	09/27/18 7:38 AM	10/03/18 4:34 PM	18024414	Copper	< 0.1	1.3	ppm
142-2066-A-002A Room 30	09/27/18 7:38 AM	10/03/18 4:34 PM	18024414	Lead	31	15	ppb
142-2066-A-002B Room 30	09/27/18 7:38 AM	10/03/18 4:38 PM	18024415	Copper	< 0.10	1.3	ppm
142-2066-A-002B Room 30	09/27/18 7:38 AM	10/03/18 4:38 PM	18024415	Lead	75	15	ppb
142-2069-A-002A Room 27	09/27/18 7:42 AM	10/03/18 4:42 PM	18024416	Copper	< 0.1	1.3	ppm
142-2069-A-002A Room 27	09/27/18 7:42 AM	10/03/18 4:42 PM	18024416	Lead	12	15	ppb
142-2069-A-002B Room 27	09/27/18 7:42 AM	10/02/18 11:17 PM	18024417	Copper	< 0.1	1.3	ppm
142-2069-A-002B Room 27	09/27/18 7:42 AM	10/02/18 11:17 PM	18024417	Lead	8	15	ppb
142-2068-A-002A Room 28	09/27/18 7:45 AM	10/02/18 11:22 PM	18024418	Copper	< 0.1	1.3	ppm
142-2068-A-002A Room 28	09/27/18 7:45 AM	10/02/18 11:22 PM	18024418	Lead	19	15	ppb
142-2068-A-002B Room 28	09/27/18 7:45 AM	10/02/18 11:27 PM	18024419	Copper	< 0.1	1.3	ppm
142-2068-A-002B Room 28	09/27/18 7:45 AM	10/02/18 11:27 PM	18024419	Lead	11	15	ppb
142-2067-A-002A Room 29	09/27/18 7:49 AM	10/02/18 11:31 PM	18024420	Copper	< 0.1	1.3	ppm
142-2067-A-002A Room 29	09/27/18 7:49 AM	10/02/18 11:31 PM	18024420	Lead	36	15	ppb
142-2067-A-002B Room 29	09/27/18 7:49 AM	10/03/18 4:46 PM	18024421	Copper	< 0.1	1.3	ppm
142-2067-A-002B Room 29	09/27/18 7:49 AM	10/03/18 4:46 PM	18024421	Lead	50	15	ppb
142-2071-A-002A Library / Media Cntr	09/27/18 7:54 AM	10/02/18 11:36 PM	18024422	Copper	< 0.1	1.3	ppm
142-2071-A-002A Library / Media Cntr	09/27/18 7:54 AM	10/02/18 11:36 PM	18024422	Lead	7	15	ppb
142-2071-A-002B Library / Media Cntr	09/27/18 7:54 AM	10/02/18 11:41 PM	18024423	Copper	< 0.1	1.3	ppm
142-2071-A-002B Library / Media Cntr	09/27/18 7:54 AM	10/02/18 11:41 PM	18024423	Lead	2	15	ppb
142-2081-A-002A Staff Office (Bubbler)	09/27/18 7:59 AM	10/02/18 11:46 PM	18024424	Copper	< 0.1	1.3	ppm
142-2081-A-002A Staff Office (Bubbler)	09/27/18 7:59 AM	10/02/18 11:46 PM	18024424	Lead	5	15	ppb
142-2081-A-002B Staff Office (Bubbler)	09/27/18 7:59 AM	10/03/18 12:20 AM	18024425	Copper	< 0.1	1.3	ppm
142-2081-A-002B Staff Office (Bubbler)	09/27/18 7:59 AM	10/03/18 12:20 AM	18024425	Lead	3	15	ppb

Results highlighted indicate a value at or above the PPS Action Level and that the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.