Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Bridlemile - Test 3

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
142-CH2072-A-003-A	Hallway (17)	3/28/2019	4/9/2019	A9C1070-01	Lead	4.46	0.20	15	ppb
142-CH2072-B-003-A	Hallway (17)	3/28/2019	4/9/2019	A9C1070-03	Lead	2.5	0.20	15	ppb
142-CH2050-N/A-003-A	Classroom 51	3/28/2019	4/9/2019	A9C1070-05	Lead	2.06	0.20	15	ppb
142-CH2073-N/A-003-A	Classroom 15	3/28/2019	4/9/2019	A9C1070-07	Lead	1.1	0.20	15	ppb
142-CH2080-N/A-003-A	Classroom 5	3/28/2019	4/9/2019	A9C1070-09	Lead	7.03	0.20	15	ppb
142-CH2078-N/A-003-A	Classroom 6	3/28/2019	4/9/2019	A9C1070-11	Lead	4.38	0.20	15	ppb
142-CH2079-N/A-003-A	Hallway (14A)	3/28/2019	4/9/2019	A9C1070-13	Lead	4.17	0.20	15	ppb
142-CH2076-N/A-003-A	Classroom 8	3/28/2019	4/9/2019	A9C1070-15	Lead	1.08	0.20	15	ppb
142-CH2074-N/A-003-A	Gym	3/28/2019	4/9/2019	A9C1070-17	Lead	2.94	0.20	15	ppb
142-CH2075-N/A-003-A	Girls Locker Room	3/28/2019	4/9/2019	A9C1070-19	Lead	14	0.20	15	ppb

*OHA Action Level = 15 ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek