Portland Public Schools
Lead and Copper Water Sampling Results
Initial and Follow Up Flush Sample Data
Buckman

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
143-CH4538-A-002-A	North Gym Bubbler	10/30/2018	11/6/2018	A8K0069-35	Copper	0.0553	0.00200	1.3	ppm
143-CH4538-A-002-A	North Gym Bubbler	10/30/2018	11/6/2018	A8K0069-35	Lead	2.60	0.200	15	ppb
143-CH4538-A-002-B	North Gym Bubbler	10/30/2018	11/6/2018	A8K0069-36	Copper	0.00965	0.00200	1.3	ppm
143-CH4538-A-002-B	North Gym Bubbler	10/30/2018	11/6/2018	A8K0069-36	Lead	1.41	0.200	15	ppb
143-CH4538-B-002-A	North Gym Bubbler	10/30/2018	11/6/2018	A8K0069-33	Copper	0.0192	0.00200	1.3	ppm
143-CH4538-B-002-A	North Gym Bubbler	10/30/2018	11/6/2018	A8K0069-33	Lead	1.47	0.200	15	ppb
143-CH4538-B-002-B	North Gym Bubbler	10/30/2018	11/6/2018	A8K0069-34	Copper	0.00632	0.00200	1.3	ppm
143-CH4538-B-002-B	North Gym Bubbler	10/30/2018	11/6/2018	A8K0069-34	Lead	0.603	0.200	15	ppb
143-CH4538-C-002-A	North Gym Bubbler	10/30/2018	11/6/2018	A8K0069-31	Copper	0.00979	0.00200	1.3	ppm
143-CH4538-C-002-A	North Gym Bubbler	10/30/2018	11/6/2018	A8K0069-31	Lead	2.66	0.200	15	ppb
143-CH4538-C-002-B	North Gym Bubbler	10/30/2018	11/6/2018	A8K0069-32	Copper	0.00698	0.00200	1.3	ppm
143-CH4538-C-002-B	North Gym Bubbler	10/30/2018	11/6/2018	A8K0069-32	Lead	0.847	0.200	15	ppb
143-CH4538-D-002-A	North Gym Bubbler	10/30/2018	11/6/2018	A8K0069-29	Copper	0.0458	0.00200	1.3	ppm
143-CH4538-D-002-A	North Gym Bubbler	10/30/2018	11/6/2018	A8K0069-29	Lead	14.6	0.200	15	ppb
143-CH4538-D-002-B	North Gym Bubbler	10/30/2018	11/6/2018	A8K0069-30	Copper	0.0134	0.00200	1.3	ppm
143-CH4538-D-002-B	North Gym Bubbler	10/30/2018	11/6/2018	A8K0069-30	Lead	1.61	0.200	15	ppb

Analyzed by:
Reviewed by: PBS Engineering and Environmental

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

143-CH4556-NA-002-A	Cafeteria Bubbler	10/30/2018	11/6/2018	A8K0069-49	Copper	0.0153	0.00200	1.3	ppm
143-CH4556-NA-002-A	Cafeteria Bubbler	10/30/2018	11/6/2018	A8K0069-49	Lead	2.59	0.200	15	ppb
143-CH4556-NA-002-B	Cafeteria Bubbler	10/30/2018	11/6/2018	A8K0069-50	Copper	0.00717	0.00200	1.3	ppm
143-CH4556-NA-002-B	Cafeteria Bubbler	10/30/2018	11/6/2018	A8K0069-50	Lead	0.454	0.200	15	ppb
143-CH4559-NA-002-A	Cafeteria Bubbler	10/30/2018	11/6/2018	A8K0069-51	Copper	0.0213	0.00200	1.3	ppm
143-CH4559-NA-002-A	Cafeteria Bubbler	10/30/2018	11/6/2018	A8K0069-51	Lead	1.64	0.200	15	ppb
143-CH4559-NA-002-B	Cafeteria Bubbler	10/30/2018	11/6/2018	A8K0069-52	Copper	0.0123	0.00200	1.3	ppm
143-CH4559-NA-002-B	Cafeteria Bubbler	10/30/2018	11/6/2018	A8K0069-52	Lead	0.754	0.200	15	ppb
143-CH4562-A-002-A	South Gym Bubbler	10/30/2018	11/6/2018	A8K0069-45RE2	Copper	0.0525	0.00200	1.3	ppm
143-CH4562-A-002-A	South Gym Bubbler	10/30/2018	11/6/2018	A8K0069-45RE2	Lead	14.4	0.200	15	ppb
143-CH4562-A-002-B	South Gym Bubbler	10/30/2018	11/6/2018	A8K0069-46	Copper	0.0102	0.00200	1.3	ppm
143-CH4562-A-002-B	South Gym Bubbler	10/30/2018	11/6/2018	A8K0069-46	Lead	2.23	0.200	15	ppb
143-CH4562-B-002-A	South Gym Bubbler	10/30/2018	11/6/2018	A8K0069-47	Copper	0.0201	0.00200	1.3	ppm
143-CH4562-B-002-A	South Gym Bubbler	10/30/2018	11/6/2018	A8K0069-47	Lead	3.51	0.200	15	ppb
143-CH4562-B-002-B	South Gym Bubbler	10/30/2018	11/6/2018	A8K0069-48	Copper	0.00829	0.00200	1.3	ppm
143-CH4562-B-002-B	South Gym Bubbler	10/30/2018	11/6/2018	A8K0069-48	Lead	1.16	0.200	15	ppb
143-CH4565-A-002-A	South Gym Bubbler	10/30/2018	11/6/2018	A8K0069-37	Copper	0.0163	0.00200	1.3	ppm
143-CH4565-A-002-A	South Gym Bubbler	10/30/2018	11/6/2018	A8K0069-37	Lead	3.51	0.200	15	ppb
143-CH4565-A-002-B	South Gym Bubbler	10/30/2018	11/6/2018	A8K0069-38	Copper	0.00587	0.00200	1.3	ppm
143-CH4565-A-002-B	South Gym Bubbler	10/30/2018	11/6/2018	A8K0069-38	Lead	0.702	0.200	15	ppb

Analyzed by:

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

Reviewed by: PBS Engineering and Environmental

143-CH4565-B-002-A	South Gym Bubbler	10/30/2018	11/6/2018	A8K0069-39	Copper	0.0315	0.00200	1.3	ppm
143-CH4565-B-002-A	South Gym Bubbler	10/30/2018	11/6/2018	A8K0069-39	Lead	2.42	0.200	15	ppb
143-CH4565-B-002-B	South Gym Bubbler	10/30/2018	11/6/2018	A8K0069-40	Copper	0.0163	0.00200	1.3	ppm
143-CH4565-B-002-B	South Gym Bubbler	10/30/2018	11/6/2018	A8K0069-40	Lead	0.813	0.200	15	ppb
143-CH4565-C-002-A	South Gym Bubbler	10/30/2018	11/6/2018	A8K0069-41	Copper	0.0559	0.00200	1.3	ppm
143-CH4565-C-002-A	South Gym Bubbler	10/30/2018	11/6/2018	A8K0069-41	Lead	1.80	0.200	15	ppb
143-CH4565-C-002-B	South Gym Bubbler	10/30/2018	11/6/2018	A8K0069-42	Copper	0.0137	0.00200	1.3	ppm
143-CH4565-C-002-B	South Gym Bubbler	10/30/2018	11/6/2018	A8K0069-42	Lead	0.596	0.200	15	ppb
143-CH4565-D-002-A	South Gym Bubbler	10/30/2018	11/6/2018	A8K0069-43	Copper	0.0807	0.00200	1.3	ppm
143-CH4565-D-002-A	South Gym Bubbler	10/30/2018	11/6/2018	A8K0069-43	Lead	0.964	0.200	15	ppb
143-CH4565-D-002-B	South Gym Bubbler	10/30/2018	11/6/2018	A8K0069-44	Copper	0.00479	0.00200	1.3	ppm
143-CH4565-D-002-B	South Gym Bubbler	10/30/2018	11/6/2018	A8K0069-44	Lead	0.543	0.200	15	ppb
143-CH4566-NA-002-A	Hallway Bubbler	10/30/2018	11/6/2018	A8K0069-57	Copper	0.549	0.00200	1.3	ppm
143-CH4566-NA-002-A	Hallway Bubbler	10/30/2018	11/6/2018	A8K0069-57	Lead	10.0	0.200	15	ppb
143-CH4566-NA-002-B	Hallway Bubbler	10/30/2018	11/6/2018	A8K0069-58	Copper	0.294	0.00200	1.3	ppm
143-CH4566-NA-002-B	Hallway Bubbler	10/30/2018	11/6/2018	A8K0069-58	Lead	4.84	0.200	15	ppb
143-CH4567-NA-002-A	Hallway Bubbler	10/30/2018	11/6/2018	A8K0069-63	Copper	0.122	0.00200	1.3	ppm
143-CH4567-NA-002-A	Hallway Bubbler	10/30/2018	11/6/2018	A8K0069-63	Lead	6.41	0.200	15	ppb
143-CH4567-NA-002-B	Hallway Bubbler	10/30/2018	11/6/2018	A8K0069-64	Copper	0.109	0.00200	1.3	ppm
143-CH4567-NA-002-B	Hallway Bubbler	10/30/2018	11/6/2018	A8K0069-64	Lead	1.75	0.200	15	ppb

Analyzed by:

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

Reviewed by: PBS Engineering and Environmental

143-CH4568-A-002-A	Hallway Bubbler	10/30/2018	11/6/2018	A8K0069-03	Copper	0.0495	0.00200	1.3	ppm
143-CH4568-A-002-A	Hallway Bubbler	10/30/2018	11/6/2018	A8K0069-03	Lead	23.8	0.200	15	ppb
143-CH4568-A-002-B	Hallway Bubbler	10/30/2018	11/6/2018	A8K0069-04	Copper	0.00374	0.00200	1.3	ppm
143-CH4568-A-002-B	Hallway Bubbler	10/30/2018	11/6/2018	A8K0069-04	Lead	1.13	0.200	15	ppb
143-CH4568-B-002-A	Hallway Bubbler	10/30/2018	11/6/2018	A8K0069-05	Copper	0.0130	0.00200	1.3	ppm
143-CH4568-B-002-A	Hallway Bubbler	10/30/2018	11/6/2018	A8K0069-05	Lead	4.76	0.200	15	ppb
143-CH4568-B-002-B	Hallway Bubbler	10/30/2018	11/6/2018	A8K0069-06	Copper	0.00363	0.00200	1.3	ppm
143-CH4568-B-002-B	Hallway Bubbler	10/30/2018	11/6/2018	A8K0069-06	Lead	1.16	0.200	15	ppb
143-CH4569-NA-002-A	Hallway Bubbler	10/30/2018	11/6/2018	A8K0069-55	Copper	0.543	0.00200	1.3	ppm
143-CH4569-NA-002-A	Hallway Bubbler	10/30/2018	11/6/2018	A8K0069-55	Lead	18.5	0.200	15	ppb
143-CH4569-NA-002-B	Hallway Bubbler	10/30/2018	11/6/2018	A8K0069-56	Copper	0.901	0.00200	1.3	ppm
143-CH4569-NA-002-B	Hallway Bubbler	10/30/2018	11/6/2018	A8K0069-56	Lead	16.3	0.200	15	ppb
143-CH4570-NA-002-A	Room 206	10/30/2018	11/6/2018	A8K0069-67RE1	Copper	1.40	0.0100	1.3	ppm
143-CH4570-NA-002-A	Room 206	10/30/2018	11/6/2018	A8K0069-67	Lead	19.6	0.200	15	ppb
143-CH4570-NA-002-B	Room 206	10/30/2018	11/6/2018	A8K0069-68RE1	Copper	1.45	0.0100	1.3	ppm
143-CH4570-NA-002-B	Room 206	10/30/2018	11/6/2018	A8K0069-68	Lead	10.4	0.200	15	ppb
143-CH4572-NA-002-A	Room 210	10/30/2018	11/6/2018	A8K0069-79	Copper	0.319	0.00200	1.3	ppm
143-CH4572-NA-002-A	Room 210	10/30/2018	11/6/2018	A8K0069-79	Lead	4.27	0.200	15	ppb
143-CH4572-NA-002-B	Room 210	10/30/2018	11/6/2018	A8K0069-80	Copper	0.663	0.00200	1.3	ppm
143-CH4572-NA-002-B	Room 210	10/30/2018	11/6/2018	A8K0069-80RE1	Lead	1.84	0.200	15	ppb

Analyzed by:

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

Reviewed by: PBS Engineering and Environmental

143-CH4573-NA-002-A	Room 205	10/30/2018	11/6/2018	A8K0069-69	Copper	0.640	0.00200	1.3	ppm
143-CH4573-NA-002-A	Room 205	10/30/2018	11/6/2018	A8K0069-69	Lead	11.4	0.200	15	ppb
143-CH4573-NA-002-B	Room 205	10/30/2018	11/6/2018	A8K0069-70	Copper	0.636	0.00200	1.3	ppm
143-CH4573-NA-002-B	Room 205	10/30/2018	11/6/2018	A8K0069-70	Lead	1.97	0.200	15	ppb
143-CH4574-NA-002-A	Room 113	10/30/2018	11/6/2018	A8K0069-01	Copper	0.945	0.00200	1.3	ppm
143-CH4574-NA-002-A	Room 113	10/30/2018	11/6/2018	A8K0069-01	Lead	21.5	0.200	15	ppb
143-CH4574-NA-002-B	Room 113	10/30/2018	11/6/2018	A8K0069-02RE1	Copper	1.33	0.0100	1.3	ppm
143-CH4574-NA-002-B	Room 113	10/30/2018	11/6/2018	A8K0069-02	Lead	5.35	0.200	15	ppb
143-CH4575-A-002-A	Room 208	10/30/2018	11/6/2018	A8K0069-59	Copper	0.375	0.00200	1.3	ppm
143-CH4575-A-002-A	Room 208	10/30/2018	11/6/2018	A8K0069-59	Lead	7.30	0.200	15	ppb
143-CH4575-A-002-B	Room 208	10/30/2018	11/6/2018	A8K0069-60	Copper	0.104	0.00200	1.3	ppm
143-CH4575-A-002-B	Room 208	10/30/2018	11/6/2018	A8K0069-60	Lead	2.60	0.200	15	ppb
143-CH4575-B-002-A	Room 208	10/30/2018	11/6/2018	A8K0069-61	Copper	0.114	0.00200	1.3	ppm
143-CH4575-B-002-A	Room 208	10/30/2018	11/6/2018	A8K0069-61	Lead	2.89	0.200	15	ppb
143-CH4575-B-002-B	Room 208	10/30/2018	11/6/2018	A8K0069-62	Copper	0.171	0.00200	1.3	ppm
143-CH4575-B-002-B	Room 208	10/30/2018	11/6/2018	A8K0069-62	Lead	1.08	0.200	15	ppb
143-CH4576-NA-002-A	Room 204	10/30/2018	11/6/2018	A8K0069-71	Copper	0.612	0.00200	1.3	ppm
143-CH4576-NA-002-A	Room 204	10/30/2018	11/6/2018	A8K0069-71	Lead	17.8	0.200	15	ppb
143-CH4576-NA-002-B	Room 204	10/30/2018	11/6/2018	A8K0069-72	Copper	0.299	0.00200	1.3	ppm
143-CH4576-NA-002-B	Room 204	10/30/2018	11/6/2018	A8K0069-72	Lead	2.21	0.200	15	ppb

Analyzed by:

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

Reviewed by: PBS Engineering and Environmental

143-CH4577-NA-002-A	Room 114	10/30/2018	11/6/2018	A8K0069-07RE1	Copper	1.10	0.0100	1.3	ppm
143-CH4577-NA-002-A	Room 114	10/30/2018	11/6/2018	A8K0069-07	Lead	27.7	0.200	15	ppb
143-CH4577-NA-002-B	Room 114	10/30/2018	11/6/2018	A8K0069-08	Copper	0.392	0.00200	1.3	ppm
143-CH4577-NA-002-B	Room 114	10/30/2018	11/6/2018	A8K0069-08	Lead	3.79	0.200	15	ppb
143-CH4578-NA-002-A	Room 207	10/30/2018	11/6/2018	A8K0069-65	Copper	0.324	0.00200	1.3	ppm
143-CH4578-NA-002-A	Room 207	10/30/2018	11/6/2018	A8K0069-65	Lead	4.32	0.200	15	ppb
143-CH4578-NA-002-B	Room 207	10/30/2018	11/6/2018	A8K0069-66	Copper	0.480	0.00200	1.3	ppm
143-CH4578-NA-002-B	Room 207	10/30/2018	11/6/2018	A8K0069-66	Lead	0.986	0.200	15	ppb
143-CH4579-NA-002-A	Room 203	10/30/2018	11/6/2018	A8K0069-73	Copper	0.426	0.00200	1.3	ppm
143-CH4579-NA-002-A	Room 203	10/30/2018	11/6/2018	A8K0069-73	Lead	9.01	0.200	15	ppb
143-CH4579-NA-002-B	Room 203	10/30/2018	11/6/2018	A8K0069-74	Copper	0.518	0.00200	1.3	ppm
143-CH4579-NA-002-B	Room 203	10/30/2018	11/6/2018	A8K0069-74RE2	Lead	1.69	0.200	15	ppb
143-CH4580-NA-002-A	Hallway Bubbler	10/30/2018	11/6/2018	A8K0069-09RE1	Copper	1.26	0.0100	1.3	ppm
143-CH4580-NA-002-A	Hallway Bubbler	10/30/2018	11/6/2018	A8K0069-09	Lead	3.07	0.200	15	ppb
143-CH4580-NA-002-B	Hallway Bubbler	10/30/2018	11/6/2018	A8K0069-10	Copper	0.497	0.00200	1.3	ppm
143-CH4580-NA-002-B	Hallway Bubbler	10/30/2018	11/6/2018	A8K0069-10	Lead	2.21	0.200	15	ppb
143-CH4581-NA-002-A	Room 216	10/30/2018	11/6/2018	A8K0069-53RE1	Copper	1.69	0.0100	1.3	ppm
143-CH4581-NA-002-A	Room 216	10/30/2018	11/6/2018	A8K0069-53	Lead	24.4	0.200	15	ppb
143-CH4581-NA-002-B	Room 216	10/30/2018	11/6/2018	A8K0069-54	Copper	0.984	0.00200	1.3	ppm
143-CH4581-NA-002-B	Room 216	10/30/2018	11/6/2018	A8K0069-54	Lead	6.77	0.200	15	ppb

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

Analyzed by:
Reviewed by: PBS Engineering and Environmental

143-CH4582-NA-002-A	Room 202	10/30/2018	11/6/2018	A8K0069-75	Copper	0.519	0.00200	1.3	ppm
143-CH4582-NA-002-A	Room 202	10/30/2018	11/6/2018	A8K0069-75	Lead	9.47	0.200	15	ppb
143-CH4582-NA-002-B	Room 202	10/30/2018	11/6/2018	A8K0069-76	Copper	0.758	0.00200	1.3	ppm
143-CH4582-NA-002-B	Room 202	10/30/2018	11/6/2018	A8K0069-76	Lead	2.15	0.200	15	ppb
143-CH4583-NA-002-A	Room 109	10/30/2018	11/6/2018	A8K0069-11	Copper	0.553	0.00200	1.3	ppm
143-CH4583-NA-002-A	Room 109	10/30/2018	11/6/2018	A8K0069-11	Lead	14.1	0.200	15	ppb
143-CH4583-NA-002-B	Room 109	10/30/2018	11/6/2018	A8K0069-12	Copper	0.598	0.00200	1.3	ppm
143-CH4583-NA-002-B	Room 109	10/30/2018	11/6/2018	A8K0069-12	Lead	4.16	0.200	15	ppb
143-CH4585-NA-002-A	Room 201	10/30/2018	11/6/2018	A8K0069-77	Copper	0.182	0.00200	1.3	ppm
143-CH4585-NA-002-A	Room 201	10/30/2018	11/6/2018	A8K0069-77	Lead	22.8	0.200	15	ppb
143-CH4585-NA-002-B	Room 201	10/30/2018	11/6/2018	A8K0069-78	Copper	0.251	0.00200	1.3	ppm
143-CH4585-NA-002-B	Room 201	10/30/2018	11/6/2018	A8K0069-78	Lead	11.0	0.200	15	ppb
143-CH4586-NA-002-A	Room 108	10/30/2018	11/6/2018	A8K0069-13RE1	Copper	0.795	0.00200	1.3	ppm
143-CH4586-NA-002-A	Room 108	10/30/2018	11/6/2018	A8K0069-13RE1	Lead	12.2	0.200	15	ppb
143-CH4586-NA-002-B	Room 108	10/30/2018	11/6/2018	A8K0069-14	Copper	0.850	0.00200	1.3	ppm
143-CH4586-NA-002-B	Room 108	10/30/2018	11/6/2018	A8K0069-14	Lead	3.52	0.200	15	ppb
143-CH4589-NA-002-A	Room 107	10/30/2018	11/6/2018	A8K0069-15	Copper	0.947	0.00200	1.3	ppm
143-CH4589-NA-002-A	Room 107	10/30/2018	11/6/2018	A8K0069-15	Lead	10.3	0.200	15	ppb
143-CH4589-NA-002-B	Room 107	10/30/2018	11/6/2018	A8K0069-16	Copper	0.993	0.00200	1.3	ppm
143-CH4589-NA-002-B	Room 107	10/30/2018	11/6/2018	A8K0069-16	Lead	5.36	0.200	15	ppb

143-CH4591-NA-002-A	Room 101	10/30/2018	11/6/2018	A8K0069-27	Copper	0.0932	0.00200	1.3	ppm
143-CH4591-NA-002-A	Room 101	10/30/2018	11/6/2018	A8K0069-27	Lead	1.49	0.200	15	ppb
143-CH4591-NA-002-B	Room 101	10/30/2018	11/6/2018	A8K0069-28	Copper	0.0637	0.00200	1.3	ppm
143-CH4591-NA-002-B	Room 101	10/30/2018	11/6/2018	A8K0069-28	Lead	1.76	0.200	15	ppb
143-CH4598-NA-002-A	Hallway Bubbler	10/30/2018	11/6/2018	A8K0069-21	Copper	0.513	0.00200	1.3	ppm
143-CH4598-NA-002-A	Hallway Bubbler	10/30/2018	11/6/2018	A8K0069-21	Lead	5.33	0.200	15	ppb
143-CH4598-NA-002-B	Hallway Bubbler	10/30/2018	11/6/2018	A8K0069-22	Copper	0.112	0.00200	1.3	ppm
143-CH4598-NA-002-B	Hallway Bubbler	10/30/2018	11/6/2018	A8K0069-22	Lead	0.754	0.200	15	ppb
143-CH4601-NA-002-A	Hallway Bubbler	10/30/2018	11/6/2018	A8K0069-23	Copper	0.228	0.00200	1.3	ppm
143-CH4601-NA-002-A	Hallway Bubbler	10/30/2018	11/6/2018	A8K0069-23	Lead	1.76	0.200	15	ppb
143-CH4601-NA-002-B	Hallway Bubbler	10/30/2018	11/6/2018	A8K0069-24	Copper	0.184	0.00200	1.3	ppm
143-CH4601-NA-002-B	Hallway Bubbler	10/30/2018	11/6/2018	A8K0069-24	Lead	1.51	0.200	15	ppb
143-CH4604-NA-002-A	Room 103	10/30/2018	11/6/2018	A8K0069-25	Copper	0.226	0.00200	1.3	ppm
143-CH4604-NA-002-A	Room 103	10/30/2018	11/6/2018	A8K0069-25	Lead	14.4	0.200	15	ppb
143-CH4604-NA-002-B	Room 103	10/30/2018	11/6/2018	A8K0069-26	Copper	0.422	0.00200	1.3	ppm
143-CH4604-NA-002-B	Room 103	10/30/2018	11/6/2018	A8K0069-26	Lead	1.73	0.200	15	ppb
143-CH4607-NA-002-A	Room 104	10/30/2018	11/6/2018	A8K0069-19	Copper	0.462	0.00200	1.3	ppm
143-CH4607-NA-002-A	Room 104	10/30/2018	11/6/2018	A8K0069-19	Lead	9.15	0.200	15	ppb
143-CH4607-NA-002-B	Room 104	10/30/2018	11/6/2018	A8K0069-20	Copper	0.531	0.00200	1.3	ppm
143-CH4607-NA-002-B	Room 104	10/30/2018	11/6/2018	A8K0069-20	Lead	2.64	0.200	15	ppb
143-CH4610-NA-002-A	Room 105	10/30/2018	11/6/2018	A8K0069-17	Copper	0.498	0.00200	1.3	ppm
143-CH4610-NA-002-A	Room 105	10/30/2018	11/6/2018	A8K0069-17	Lead	5.91	0.200	15	ppb

Analyzed by:

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

Reviewed by: PBS Engineering and Environmental

143-CH4610-NA-002-B	Room 105	10/30/2018	11/6/2018	A8K0069-18	Copper	0.833	0.00200	1.3	ppm
143-CH4610-NA-002-B	Room 105	10/30/2018	11/6/2018	A8K0069-18	Lead	1.29	0.200	15	ppb

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

Analyzed by:
Reviewed by: PBS Engineering and Environmental