Portland Public Schools
Lead and Copper Water Sampling Results
Initial and Follow Up Flush Sample Data
Capitol Hill

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
144-CH3949-N/A-001-A	Main Kitchen Prep	8/8/2018	8/14/2018	1808427-01A	Copper	0.0648	0.0000259	1.3	ppm
144-CH3949-N/A-001-A	Main Kitchen Prep	8/8/2018	8/14/2018	1808427-01A	Lead	1.69	0.00523	15	ppb
144-CH3949-N/A-001-B	Main Kitchen Prep	8/8/2018	8/14/2018	1808427-02A	Copper	0.00656	0.0000259	1.3	ppm
144-CH3949-N/A-001-B	Main Kitchen Prep	8/8/2018	8/14/2018	1808427-02A	Lead	0.259	0.00523	15	ppb
144-CH3957-N/A-001-A	Gym	8/8/2018	8/14/2018	1808427-03A	Copper	0.0702	0.0000259	1.3	ppm
144-CH3957-N/A-001-A	Gym	8/8/2018	8/14/2018	1808427-03A	Lead	5.84	0.00523	15	ppb
144-CH3957-N/A-001-B	Gym	8/8/2018	8/14/2018	1808427-04A	Copper	0.0262	0.0000259	1.3	ppm
144-CH3957-N/A-001-B	Gym	8/8/2018	8/14/2018	1808427-04A	Lead	1.9	0.00523	15	ppb
144-CH3953-A-001-A	Hallway by 108	8/8/2018	8/14/2018	1808427-05A	Copper	2.34	0.000259	1.3	ppm
144-CH3953-A-001-A	Hallway by 108	8/8/2018	8/14/2018	1808427-05A	Lead	11.9	0.00523	15	ppb
144-CH3953-A-001-B	Hallway by 108	8/8/2018	8/14/2018	1808427-06A	Copper	1.75	0.000259	1.3	ppm
144-CH3953-A-001-B	Hallway by 108	8/8/2018	8/14/2018	1808427-06A	Lead	1.35	0.00523	15	ppb
144-CH3953-B-001-A	Hallway by 108	8/8/2018	8/14/2018	1808427-07A	Copper	1.77	0.000259	1.3	ppm
144-CH3953-B-001-A	Hallway by 108	8/8/2018	8/14/2018	1808427-07A	Lead	3.1	0.00523	15	ppb
144-CH3953-B-001-B	Hallway by 108	8/8/2018	8/14/2018	1808427-08A	Copper	0.322	0.0000259	1.3	ppm
144-CH3953-B-001-B	Hallway by 108	8/8/2018	8/14/2018	1808427-08A	Lead	0.976	0.00523	15	ppb

Analyzed by: Neilson Research Corporation
Reviewed by: PBS Engineering and Environmental

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

144-CH3965-A-001-A	Hallway by Custodial Ro	8/8/2018	8/14/2018	1808427-09A	Copper	0.109	0.0000259	1.3	ppm
144-CH3965-A-001-A	Hallway by Custodial Ro	8/8/2018	8/14/2018	1808427-09A	Lead	205	0.00523	15	ppb
144-CH3965-A-001-B	Hallway by Custodial Ro	8/8/2018	8/14/2018	1808427-10A	Copper	0.0578	0.0000259	1.3	ppm
144-CH3965-A-001-B	Hallway by Custodial Ro	8/8/2018	8/14/2018	1808427-10A	Lead	12.3	0.00523	15	ppb
144-CH3965-B-001-A	Hallway by Custodial Ro	8/8/2018	8/14/2018	1808427-11A	Copper	0.0641	0.0000259	1.3	ppm
144-CH3965-B-001-A	Hallway by Custodial Ro	8/8/2018	8/14/2018	1808427-11A	Lead	39.6	0.00523	15	ppb
144-CH3965-B-001-B	Hallway by Custodial Ro	8/8/2018	8/14/2018	1808427-12A	Copper	0.0470	0.0000259	1.3	ppm
144-CH3965-B-001-B	Hallway by Custodial Ro	8/8/2018	8/14/2018	1808427-12A	Lead	2.47	0.00523	15	ppb
144-CH3945-N/A-001-A	Hallway by Room 102	8/8/2018	8/14/2018	1808427-13A	Copper	0.0392	0.0000259	1.3	ppm
144-CH3945-N/A-001-A	Hallway by Room 102	8/8/2018	8/14/2018	1808427-13A	Lead	6.09	0.00523	15	ppb
144-CH3945-N/A-001-B	Hallway by Room 102	8/8/2018	8/14/2018	1808427-14A	Copper	0.0252	0.0000259	1.3	ppm
144-CH3945-N/A-001-B	Hallway by Room 102	8/8/2018	8/14/2018	1808427-14A	Lead	3.31	0.00523	15	ppb
144-CH3962-N/A-001-A	108	8/8/2018	8/14/2018	1808427-15A	Copper	0.712	0.0000259	1.3	ppm
144-CH3962-N/A-001-A	108	8/8/2018	8/14/2018	1808427-15A	Lead	40.1	0.00523	15	ppb
144-CH3962-N/A-001-B	108	8/8/2018	8/14/2018	1808427-16A	Copper	0.906	0.000259	1.3	ppm
144-CH3962-N/A-001-B	108	8/8/2018	8/14/2018	1808427-16A	Lead	15.5	0.00523	15	ppb
144-CH3956-N/A-001-A	By Room 111	8/8/2018	8/14/2018	1808427-17A	Copper	0.0359	0.0000259	1.3	ppm
144-CH3956-N/A-001-A	By Room 111	8/8/2018	8/14/2018	1808427-17A	Lead	85.6	0.00523	15	ppb
144-CH3956-N/A-001-B	By Room 111	8/8/2018	8/14/2018	1808427-18A	Copper	0.0203	0.0000259	1.3	ppm
144-CH3956-N/A-001-B	By Room 111	8/8/2018	8/14/2018	1808427-18A	Lead	11.6	0.00523	15	ppb

Analyzed by: Neilson Research Corporation
Reviewed by: PBS Engineering and Environmental

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

144-CH3951-N/A-001-A	Break Room	8/8/2018	8/14/2018	1808427-19A	Copper	0.131	0.0000259	1.3	ppm
144-CH3951-N/A-001-A	Break Room	8/8/2018	8/14/2018	1808427-19A	Lead	3.73	0.00523	15	ppb
144-CH3951-N/A-001-B	Break Room	8/8/2018	8/14/2018	1808427-20A	Copper	0.0143	0.0000259	1.3	ppm
144-CH3951-N/A-001-B	Break Room	8/8/2018	8/14/2018	1808427-20A	Lead	7.01	0.00523	15	ppb
144-CH3960-N/A-001-A	Cafeteria	8/8/2018	8/14/2018	1808427-21A	Copper	0.0174	0.0000259	1.3	ppm
144-CH3960-N/A-001-A	Cafeteria	8/8/2018	8/14/2018	1808427-21A	Lead	19.2	0.00523	15	ppb
144-CH3960-N/A-001-B	Cafeteria	8/8/2018	8/14/2018	1808427-22A	Copper	0.00361	0.0000259	1.3	ppm
144-CH3960-N/A-001-B	Cafeteria	8/8/2018	8/14/2018	1808427-22A	Lead	2.04	0.00523	15	ppb
144-CH3952-N/A-001-A	By Store Room	8/8/2018	8/14/2018	1808427-23A	Copper	0.0206	0.0000259	1.3	ppm
144-CH3952-N/A-001-A	By Store Room	8/8/2018	8/14/2018	1808427-23A	Lead	2.74	0.00523	15	ppb
144-CH3952-N/A-001-B	By Store Room	8/8/2018	8/14/2018	1808427-24A	Copper	0.0120	0.0000259	1.3	ppm
144-CH3952-N/A-001-B	By Store Room	8/8/2018	8/14/2018	1808427-24A	Lead	1.4	0.00523	15	ppb
144-CH3967-N/A-001-A	By 209	8/8/2018	8/14/2018	1808427-25A	Copper	0.0162	0.0000259	1.3	ppm
144-CH3967-N/A-001-A	By 209	8/8/2018	8/14/2018	1808427-25A	Lead	10.6	0.00523	15	ppb
144-CH3967-N/A-001-B	By 209	8/8/2018	8/14/2018	1808427-26A	Copper	0.00392	0.0000259	1.3	ppm
144-CH3967-N/A-001-B	By 209	8/8/2018	8/14/2018	1808427-26A	Lead	6.61	0.00523	15	ppb
144-CH3959-N/A-001-A	112	8/8/2018	8/14/2018	1808427-27A	Copper	0.0130	0.0000259	1.3	ppm
144-CH3959-N/A-001-A	112	8/8/2018	8/14/2018	1808427-27A	Lead	6.14	0.00523	15	ppb
144-CH3959-N/A-001-B	112	8/8/2018	8/14/2018	1808427-28A	Copper	0.00885	0.0000259	1.3	ppm
144-CH3959-N/A-001-B	112	8/8/2018	8/14/2018	1808427-28A	Lead	3.76	0.00523	15	ppb

Results highlighted indicate a value at or above the PPS Action Level and that the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.

Analyzed by: Neilson Research Corporation

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

Reviewed by: PBS Engineering and Environmental