

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Buckman Elementary School - Test 3**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
143-CH4568-A-003-A	Hallway (112)	3/20/2019	3/29/2019	A9C0794-01	Lead	20.40	0.20	15	ppb
143-CH4568-A-003-B	Hallway (112)	3/20/2019	4/10/2019	A9C0794-02	Lead	6.83	0.20	15	ppb
143-CH4568-B-003-A	Hallway (112)	3/20/2019	3/29/2019	A9C0794-03	Lead	9.34	0.20	15	ppb
143-CH4571-N/A-003-A	Classroom 112	3/20/2019	3/29/2019	A9C0794-05	Lead	4.83	0.20	15	ppb
143-CH4592-N/A-003-A	Classroom 102	3/20/2019	3/29/2019	A9C0794-07	Lead	7.32	0.20	15	ppb
143-CH4590-N/A-003-A	Classroom 211	3/20/2019	3/29/2019	A9C0794-09	Lead	ND	0.20	15	ppb
143-CH4569-N/A-003-A	Hallway (210)	3/20/2019	3/29/2019	A9C0794-11	Lead	2.95	0.20	15	ppb
143-CH4584-N/A-003-A	Classroom 213	3/20/2019	3/29/2019	A9C0794-13	Lead	6.23	0.20	15	ppb

Results highlighted indicate a value at or above PPS Action Level and the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.