

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data - No Follow Up Required
Capitol Hill Elementary School - Test 3**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
144-CH3954-A-003-A	Hallway (Nurse's Office)	3/28/2019	4/9/2019	A9C1076-01	Lead	4.47	0.20	15	ppb
144-CH3954-B-003-A	Hallway (Nurse's Office)	3/28/2019	4/9/2019	A9C1076-03	Lead	1.7	0.20	15	ppb
144-CH3960-N/A-003-A	Cafeteria	3/28/2019	4/9/2019	A9C1076-05	Lead	7.18	0.20	15	ppb
144-CH3962-N/A-003-A	Classroom 108	3/28/2019	4/9/2019	A9C1076-07	Lead	43.70	0.20	15	ppb
144-CH3948-N/A-003-A	Classroom 100	3/28/2019	4/9/2019	A9C1076-09	Lead	4.69	0.20	15	ppb
144-CH3970-N/A-003-A	Classroom 200	3/28/2019	4/9/2019	A9C1076-11	Lead	21.90	0.20	15	ppb
144-CH3971-N/A-003-A	Classroom 201	3/28/2019	4/9/2019	A9C1076-13	Lead	7.51	0.20	15	ppb
144-CH3977-N/A-003-A	Classroom 203	3/28/2019	4/9/2019	A9C1076-15	Lead	34.50	0.20	15	ppb

Results highlighted indicate a value at or above the PPS Action Level and that the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.