

Portland Public Schools
Lead and Copper Water Sampling Results
A (Initial) and B (Follow-Up) Sample Data
Cesar Chavez School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	PPS Action Level*	Units
182-2925-A-002A Hallway Near 148	11/16/18 6:00 AM	11/19/18 11:31 AM	18030714	Copper	0.5	1.3	ppm
182-2925-A-002A Hallway Near 148	11/16/18 6:00 AM	11/19/18 11:31 AM	18030714	Lead	4	15	ppb
182-2925-A-002B Hallway Near 148	11/16/18 6:01 AM	11/19/18 11:32 AM	18030725	Copper	0.5	1.3	ppm
182-2925-A-002B Hallway Near 148	11/16/18 6:01 AM	11/19/18 11:32 AM	18030725	Lead	< 1	15	ppb
182-2918-A-002A Kitchen	11/16/18 6:04 AM	11/19/18 11:33 AM	18030694	Copper	0.4	1.3	ppm
182-2918-A-002A Kitchen	11/16/18 6:04 AM	11/19/18 11:33 AM	18030694	Lead	3	15	ppb
182-2918-A-002B Kitchen	11/16/18 6:05 AM	11/19/18 11:34 AM	18030701	Copper	0.4	1.3	ppm
182-2918-A-002B Kitchen	11/16/18 6:05 AM	11/19/18 11:34 AM	18030701	Lead	< 1	15	ppb
182-2918-B-002A Kitchen	11/16/18 6:06 AM	11/19/18 11:35 AM	18030693	Copper	0.4	1.3	ppm
182-2918-B-002A Kitchen	11/16/18 6:06 AM	11/19/18 11:35 AM	18030693	Lead	5	15	ppb
182-2918-B-002B Kitchen	11/16/18 6:07 AM	11/19/18 11:36 AM	18030699	Copper	0.5	1.3	ppm
182-2918-B-002B Kitchen	11/16/18 6:07 AM	11/19/18 11:36 AM	18030699	Lead	< 1	15	ppb
182-2936-A-002A Hallway Near 139	11/16/18 6:14 AM	11/19/18 11:38 AM	18030723	Copper	0.8	1.3	ppm
182-2936-A-002A Hallway Near 139	11/16/18 6:14 AM	11/19/18 11:38 AM	18030723	Lead	3	15	ppb
182-2936-A-002B Hallway Near 139	11/16/18 6:15 AM	11/19/18 11:39 AM	18030711	Copper	1.1	1.3	ppm
182-2936-A-002B Hallway Near 139	11/16/18 6:15 AM	11/19/18 11:39 AM	18030711	Lead	< 1	15	ppb
182-2942-A-002A Locker Room Boys	11/16/18 6:19 AM	11/19/18 11:40 AM	18030691	Copper	0.9	1.3	ppm
182-2942-A-002A Locker Room Boys	11/16/18 6:19 AM	11/19/18 11:40 AM	18030691	Lead	10	15	ppb
182-2942-A-002B Locker Room Boys	11/16/18 6:20 AM	11/19/18 11:41 AM	18030696	Copper	0.7	1.3	ppm
182-2942-A-002B Locker Room Boys	11/16/18 6:20 AM	11/19/18 11:41 AM	18030696	Lead	4	15	ppb
182-2933-A-002A Locker Room Girls	11/16/18 6:24 AM	11/19/18 11:49 AM	18030703	Copper	0.7	1.3	ppm
182-2933-A-002A Locker Room Girls	11/16/18 6:24 AM	11/19/18 11:49 AM	18030703	Lead	10	15	ppb
182-2933-A-002B Locker Room Girls	11/16/18 6:25 AM	11/19/18 11:50 AM	18030722	Copper	1.0	1.3	ppm
182-2933-A-002B Locker Room Girls	11/16/18 6:25 AM	11/19/18 11:50 AM	18030722	Lead	4	15	ppb
182-2931-A-002A Staff Room (Opp 121)	11/16/18 6:30 AM	11/19/18 11:52 AM	18030697	Copper	0.3	1.3	ppm
182-2931-A-002A Staff Room (Opp 121)	11/16/18 6:30 AM	11/19/18 11:52 AM	18030697	Lead	9	15	ppb
182-2931-A-002B Staff Room (Opp 121)	11/16/18 6:31 AM	11/19/18 11:53 AM	18030709	Copper	0.4	1.3	ppm
182-2931-A-002B Staff Room (Opp 121)	11/16/18 6:31 AM	11/19/18 11:53 AM	18030709	Lead	< 1	15	ppb
182-2929-A-002A Conference 136	11/16/18 6:36 AM	11/19/18 11:54 AM	18030692	Copper	1.2	1.3	ppm
182-2929-A-002A Conference 136	11/16/18 6:36 AM	11/19/18 11:54 AM	18030692	Lead	76	15	ppb
182-2929-A-002B Conference 136	11/16/18 6:37 AM	11/19/18 11:55 AM	18030717	Copper	1.1	1.3	ppm
182-2929-A-002B Conference 136	11/16/18 6:37 AM	11/19/18 11:55 AM	18030717	Lead	9	15	ppb
182-2922-A-002A Clinic Near 135	11/16/18 6:45 AM	11/19/18 11:56 AM	18030705	Copper	0.2	1.3	ppm
182-2922-A-002A Clinic Near 135	11/16/18 6:45 AM	11/19/18 11:56 AM	18030705	Lead	8	15	ppb
182-2922-A-002B Clinic Near 135	11/16/18 6:46 AM	11/19/18 11:58 AM	18030724	Copper	0.1	1.3	ppm
182-2922-A-002B Clinic Near 135	11/16/18 6:46 AM	11/19/18 11:58 AM	18030724	Lead	2	15	ppb
182-2943-A-002A Commons Near 204	11/16/18 6:53 AM	11/19/18 11:59 AM	18030716	Copper	1.0	1.3	ppm
182-2943-A-002A Commons Near 204	11/16/18 6:53 AM	11/19/18 11:59 AM	18030716	Lead	15	15	ppb
182-2943-A-002B Commons Near 204	11/16/18 6:54 AM	11/19/18 12:00 PM	18030710	Copper	0.7	1.3	ppm
182-2943-A-002B Commons Near 204	11/16/18 6:54 AM	11/19/18 12:00 PM	18030710	Lead	2	15	ppb
182-2927-A-002A Classroom 171	11/16/18 6:58 AM	11/19/18 12:08 PM	18030704	Copper	0.6	1.3	ppm
182-2927-A-002A Classroom 171	11/16/18 6:58 AM	11/19/18 12:08 PM	18030704	Lead	19	15	ppb
182-2927-A-002B Classroom 171	11/16/18 6:59 AM	11/19/18 12:09 PM	18030700	Copper	0.4	1.3	ppm
182-2927-A-002B Classroom 171	11/16/18 6:59 AM	11/19/18 12:09 PM	18030700	Lead	2	15	ppb

Results highlighted indicate a value at or above the PPS Action Level and that the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.

Analyzed by: Pixis Labs

*EPA action level for lead is 20 ppb and 1.3 for copper

Reviewed by: TRC Environmental Corporation

Page 1 of 1