

Portland Public Schools
Lead and Copper Water Sampling Results
A (Initial) and B (Follow-Up) Sample Data
Cesar Chavez School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	PPS Action Level*	Units
182-9013-A-003A Portable M101	12/11/18 6:12 AM	12/13/18 8:31 PM	18033423	Copper	< 0.1	1.3	ppm
182-9013-A-003A Portable M101	12/11/18 6:12 AM	12/13/18 8:31 PM	18033423	Lead	< 1	15	ppb
182-9013-A-003B Portable M101	12/11/18 6:13 AM	12/17/18 4:40 PM	18033424	Copper	< 0.1	1.3	ppm
182-9013-A-003B Portable M101	12/11/18 6:13 AM	12/17/18 4:40 PM	18033424	Lead	< 1	15	ppb
182-9013-B-003A Portable M101	12/11/18 6:14 AM	12/17/18 5:03 PM	18033425	Copper	< 0.1	1.3	ppm
182-9013-B-003A Portable M101	12/11/18 6:14 AM	12/17/18 5:03 PM	18033425	Lead	< 1	15	ppb
182-9013-B-003B Portable M101	12/11/18 6:15 AM	12/17/18 5:07 PM	18033426	Copper	< 0.1	1.3	ppm
182-9013-B-003B Portable M101	12/11/18 6:15 AM	12/17/18 5:07 PM	18033426	Lead	< 1	15	ppb
182-9012-A-003A Portable M100	12/11/18 6:20 AM	12/13/18 8:35 PM	18033427	Copper	< 0.1	1.3	ppm
182-9012-A-003A Portable M100	12/11/18 6:20 AM	12/13/18 8:35 PM	18033427	Lead	< 1	15	ppb
182-9012-A-003B Portable M100	12/11/18 6:21 AM	12/17/18 5:10 PM	18033428	Copper	< 0.1	1.3	ppm
182-9012-A-003B Portable M100	12/11/18 6:21 AM	12/17/18 5:10 PM	18033428	Lead	< 1	15	ppb
182-9012-B-003A Portable M100	12/11/18 6:22 AM	12/17/18 5:14 PM	18033429	Copper	< 0.1	1.3	ppm
182-9012-B-003A Portable M100	12/11/18 6:22 AM	12/17/18 5:14 PM	18033429	Lead	< 1	15	ppb
182-9012-B-003B Portable M100	12/11/18 6:23 AM	12/17/18 5:17 PM	18033430	Copper	< 0.1	1.3	ppm
182-9012-B-003B Portable M100	12/11/18 6:23 AM	12/17/18 5:17 PM	18033430	Lead	< 1	15	ppb

Analyzed by: Pixis Labs

Reviewed by: TRC Environmental Corporation

*EPA action level for lead is 20 ppb and 1.3 for copper