

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Cesar Chavez - Test 4**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
182-CH2934-N/A-004-A	Classroom 101	3/26/2019	4/9/2019	A9C1081-01	Lead	20.40	0.20	15	ppb
182-CH2937-N/A-004-A	Classroom 102 (Right)	3/27/2019	4/10/2019	A9C1081-03	Lead	16.70	0.20	15	ppb
182-CH2940-N/A-004-A	Classroom 102 (Left)	3/28/2019	4/10/2019	A9C1081-05	Lead	13.5	0.20	15	ppb
182-CH2935-N/A-004-A	Commons Near 250	3/29/2019	4/10/2019	A9C1081-07	Lead	17.90	0.20	15	ppb

Results highlighted indicate a value at or above the PPS Action Level and that the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.