

**Portland Public Schools
Lead and Copper Water Sampling Results
Initial and Follow Up Flush Sample Data
Chapman Elementary**

Sample Identification #	Location	Date Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
146-3579-N/A-001-A	Drinking Fountain - Gym/Cafeteria	8/28/2018	8/29/2018	A8H0776-01	Copper	0.449	0.00200	1.3	ppm
146-3579-N/A-001-A	Drinking Fountain - Gym/Cafeteria	8/28/2018	8/29/2018	A8H0776-01	Lead	35.9	0.200	15	ppb
146-3579-N/A-001-B	Drinking Fountain - Gym/Cafeteria	8/28/2018	8/29/2018	A8H0776-02	Copper	0.160	0.00200	1.3	ppm
146-3579-N/A-001-B	Drinking Fountain - Gym/Cafeteria	8/28/2018	8/29/2018	A8H0776-02	Lead	11.0	0.200	15	ppb
146-3588-N/A-001-A	Classroom Sink Bubbler - Classroom 10	8/28/2018	8/29/2018	A8H0776-03	Copper	0.0244	0.00200	1.3	ppm
146-3588-N/A-001-A	Classroom Sink Bubbler - Classroom 10	8/28/2018	8/29/2018	A8H0776-03	Lead	5.65	0.200	15	ppb
146-3588-N/A-001-B	Classroom Sink Bubbler - Classroom 10	8/28/2018	8/29/2018	A8H0776-04	Copper	0.00469	0.00200	1.3	ppm
146-3588-N/A-001-B	Classroom Sink Bubbler - Classroom 10	8/28/2018	8/29/2018	A8H0776-04	Lead	0.609	0.200	15	ppb
146-3571-N/A-001-A	Classroom Sink Bubbler - Classroom 6	8/28/2018	8/29/2018	A8H0776-05	Copper	0.0115	0.00200	1.3	ppm
146-3571-N/A-001-A	Classroom Sink Bubbler - Classroom 6	8/28/2018	8/29/2018	A8H0776-05	Lead	2.27	0.200	15	ppb
146-3571-N/A-001-B	Classroom Sink Bubbler - Classroom 6	8/28/2018	8/29/2018	A8H0776-06	Copper	0.00320	0.00200	1.3	ppm
146-3571-N/A-001-B	Classroom Sink Bubbler - Classroom 6	8/28/2018	8/29/2018	A8H0776-06	Lead	0.373	0.200	15	ppb
146-3577-N/A-001-A	Classroom Sink Bubbler - Classroom 5	8/28/2018	8/29/2018	A8H0776-07	Copper	0.00930	0.00200	1.3	ppm
146-3577-N/A-001-A	Classroom Sink Bubbler - Classroom 5	8/28/2018	8/29/2018	A8H0776-07	Lead	4.60	0.200	15	ppb
146-3577-N/A-001-B	Classroom Sink Bubbler - Classroom 5	8/28/2018	8/29/2018	A8H0776-08	Copper	ND	0.00200	1.3	ppm
146-3577-N/A-001-B	Classroom Sink Bubbler - Classroom 5	8/28/2018	8/29/2018	A8H0776-08	Lead	0.501	0.200	15	ppb
146-3574-N/A-001-A	Classroom Sink Bubbler - Staff Workroom 7B	8/28/2018	8/29/2018	A8H0776-09	Copper	0.0681	0.00200	1.3	ppm
146-3574-N/A-001-A	Classroom Sink Bubbler - Staff Workroom 7B	8/28/2018	8/29/2018	A8H0776-09	Lead	1.54	0.200	15	ppb
146-3574-N/A-001-B	Classroom Sink Bubbler - Staff Workroom 7B	8/28/2018	8/29/2018	A8H0776-10	Copper	0.00762	0.00200	1.3	ppm
146-3574-N/A-001-B	Classroom Sink Bubbler - Staff Workroom 7B	8/28/2018	8/29/2018	A8H0776-10	Lead	0.222	0.200	15	ppb
146-3580-N/A-001-A	Classroom Sink Bubbler - Classroom 3	8/28/2018	8/29/2018	A8H0776-11	Copper	0.254	0.00200	1.3	ppm
146-3580-N/A-001-A	Classroom Sink Bubbler - Classroom 3	8/28/2018	8/29/2018	A8H0776-11	Lead	9.46	0.200	15	ppb
146-3580-N/A-001-B	Classroom Sink Bubbler - Classroom 3	8/28/2018	8/29/2018	A8H0776-12	Copper	0.0241	0.00200	1.3	ppm
146-3580-N/A-001-B	Classroom Sink Bubbler - Classroom 3	8/28/2018	8/29/2018	A8H0776-12	Lead	0.506	0.200	15	ppb
146-3583-N/A-001-A	Classroom Sink Bubbler - Classroom 2	8/28/2018	8/29/2018	A8H0776-13	Copper	0.399	0.00200	1.3	ppm

146-3583-N/A-001-A	Classroom Sink Bubbler - Classroom 2	8/28/2018	8/29/2018	A8H0776-13	Lead	4.69	0.200	15	ppb
146-3583-N/A-001-B	Classroom Sink Bubbler - Classroom 2	8/28/2018	8/29/2018	A8H0776-14	Copper	0.0523	0.00200	1.3	ppm
146-3583-N/A-001-B	Classroom Sink Bubbler - Classroom 2	8/28/2018	8/29/2018	A8H0776-14	Lead	0.783	0.200	15	ppb
146-3592-N/A-001-A	Drinking Fountain -Hallway near lunchroom	8/28/2018	8/29/2018	A8H0776-15RE1	Copper	1.98	0.0200	1.3	ppm
146-3592-N/A-001-A	Drinking Fountain -Hallway near lunchroom	8/28/2018	8/29/2018	A8H0776-15	Lead	33.2	0.200	15	ppb
146-3592-N/A-001-B	Drinking Fountain -Hallway near lunchroom	8/28/2018	8/29/2018	A8H0776-16	Copper	0.270	0.00200	1.3	ppm
146-3592-N/A-001-B	Drinking Fountain -Hallway near lunchroom	8/28/2018	8/29/2018	A8H0776-16	Lead	14.0	0.200	15	ppb
146-3594-N/A-001-A	Classroom Sink Bubbler - Play Room	8/28/2018	8/29/2018	A8H0776-17	Copper	0.332	0.00200	1.3	ppm
146-3594-N/A-001-A	Classroom Sink Bubbler - Play Room	8/28/2018	8/29/2018	A8H0776-17	Lead	6.80	0.200	15	ppb
146-3594-N/A-001-B	Classroom Sink Bubbler - Play Room	8/28/2018	8/29/2018	A8H0776-18	Copper	0.238	0.00200	1.3	ppm
146-3594-N/A-001-B	Classroom Sink Bubbler - Play Room	8/28/2018	8/29/2018	A8H0776-18	Lead	1.55	0.200	15	ppb
146-3617-N/A-001-A	Classroom Sink Bubbler - Music Room B1	8/28/2018	8/29/2018	A8H0776-19	Copper	0.0436	0.00200	1.3	ppm
146-3617-N/A-001-A	Classroom Sink Bubbler - Music Room B1	8/28/2018	8/29/2018	A8H0776-19	Lead	12.3	0.200	15	ppb
146-3617-N/A-001-B	Classroom Sink Bubbler - Music Room B1	8/28/2018	8/29/2018	A8H0776-20	Copper	0.00628	0.00200	1.3	ppm
146-3617-N/A-001-B	Classroom Sink Bubbler - Music Room B1	8/28/2018	8/29/2018	A8H0776-20	Lead	1.84	0.200	15	ppb
146-3602-N/A-001-A	Classroom Sink Bubbler - Classroom 15	8/28/2018	8/29/2018	A8H0776-21	Copper	0.327	0.00200	1.3	ppm
146-3602-N/A-001-A	Classroom Sink Bubbler - Classroom 15	8/28/2018	8/29/2018	A8H0776-21	Lead	10.5	0.200	15	ppb
146-3602-N/A-001-B	Classroom Sink Bubbler - Classroom 15	8/28/2018	8/29/2018	A8H0776-22	Copper	0.203	0.00200	1.3	ppm
146-3602-N/A-001-B	Classroom Sink Bubbler - Classroom 15	8/28/2018	8/29/2018	A8H0776-22	Lead	2.71	0.200	15	ppb
146-3605-N/A-001-A	Classroom Sink Bubbler - Classroom 14	8/28/2018	8/29/2018	A8H0776-23	Copper	0.0318	0.00200	1.3	ppm
146-3605-N/A-001-A	Classroom Sink Bubbler - Classroom 14	8/28/2018	8/29/2018	A8H0776-23	Lead	9.16	0.200	15	ppb
146-3605-N/A-001-B	Classroom Sink Bubbler - Classroom 14	8/28/2018	8/29/2018	A8H0776-24	Copper	0.0101	0.00200	1.3	ppm
146-3605-N/A-001-B	Classroom Sink Bubbler - Classroom 14	8/28/2018	8/29/2018	A8H0776-24	Lead	6.13	0.200	15	ppb
146-3603-N/A-001-A	Classroom Sink Bubbler - Classroom 27	8/28/2018	8/29/2018	A8H0776-25	Copper	0.0322	0.00200	1.3	ppm
146-3603-N/A-001-A	Classroom Sink Bubbler - Classroom 27	8/28/2018	8/29/2018	A8H0776-25	Lead	11.2	0.200	15	ppb
146-3603-N/A-001-B	Classroom Sink Bubbler - Classroom 27	8/28/2018	8/29/2018	A8H0776-26	Copper	0.0121	0.00200	1.3	ppm
146-3603-N/A-001-B	Classroom Sink Bubbler - Classroom 27	8/28/2018	8/29/2018	A8H0776-26	Lead	2.51	0.200	15	ppb
146-3600-N/A-001-A	Classroom Sink Bubbler - Classroom 26	8/28/2018	8/29/2018	A8H0776-27	Copper	0.0182	0.00200	1.3	ppm
146-3600-N/A-001-A	Classroom Sink Bubbler - Classroom 26	8/28/2018	8/29/2018	A8H0776-27	Lead	6.13	0.200	15	ppb

146-3600-N/A-001-B	Classroom Sink Bubbler - Classroom 26	8/28/2018	8/29/2018	A8H0776-28	Copper	0.0102	0.00200	1.3	ppm
146-3600-N/A-001-B	Classroom Sink Bubbler - Classroom 26	8/28/2018	8/29/2018	A8H0776-28	Lead	3.18	0.200	15	ppb

Results highlighted indicate a value at or above the PPS Action Level and that the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.