

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Chapman Elementary School - Test 4**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
146-CH3597-N/A-004-A	Classroom 25	4/17/2019	4/25/2019	A9D0759-01	Lead	3.61	0.20	15	ppb
146-CH3579-N/A-004-A	Gym (1st Floor)	4/17/2019	4/25/2019	A9D0759-02	Lead	12.5	0.20	15	ppb
146-CH3570-N/A-004-A	Kitchen	4/17/2019	4/25/2019	A9D0759-03	Lead	0.659	0.20	15	ppb
146-CH3592-N/A-004-A	Hallway (Classroom 2)	4/17/2019	4/25/2019	A9D0759-04	Lead	10.7	0.20	15	ppb
146-CH3614-N/A-004-A	Classroom 23	4/17/2019	4/25/2019	A9D0759-05	Lead	7.18	0.20	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb