

Portland Public Schools
Lead and Copper Water Sampling Results
Initial and Follow Up Flush Sample Data
Chief Joseph Elementary

Sample Identification #	Location	Date Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
148-2976-NA-001-A	Drinking Fountain (Porcelain) - Classroom 1	8/17/2018	8/28/2018	A8H0518-01	Copper	0.0481	0.00200	1.3	ppm
148-2976-NA-001-A	Drinking Fountain (Porcelain) - Classroom 1	8/17/2018	8/28/2018	A8H0518-01	Lead	7.85	0.200	15	ppb
148-2976-NA-001-B	Drinking Fountain (Porcelain) - Classroom 1	8/17/2018	8/28/2018	A8H0518-02	Copper	0.0403	0.00200	1.3	ppm
148-2976-NA-001-B	Drinking Fountain (Porcelain) - Classroom 1	8/17/2018	8/28/2018	A8H0518-02	Lead	10.3	0.200	15	ppb
148-2979-NA-001-A	Drinking Fountain (Porcelain) - Classroom 2	8/17/2018	8/28/2018	A8H0518-03	Copper	0.0421	0.00200	1.3	ppm
148-2979-NA-001-A	Drinking Fountain (Porcelain) - Classroom 2	8/17/2018	8/28/2018	A8H0518-03	Lead	8.19	0.200	15	ppb
148-2979-NA-001-B	Drinking Fountain (Porcelain) - Classroom 2	8/17/2018	8/28/2018	A8H0518-04	Copper	0.0426	0.00200	1.3	ppm
148-2979-NA-001-B	Drinking Fountain (Porcelain) - Classroom 2	8/17/2018	8/28/2018	A8H0518-04	Lead	7.62	0.200	15	ppb
148-2982-NA-001-A	Drinking Fountain (Porcelain) - Classroom 4	8/17/2018	8/28/2018	A8H0518-05	Copper	0.0765	0.00200	1.3	ppm
148-2982-NA-001-A	Drinking Fountain (Porcelain) - Classroom 4	8/17/2018	8/28/2018	A8H0518-05	Lead	14.3	0.200	15	ppb
148-2982-NA-001-B	Drinking Fountain (Porcelain) - Classroom 4	8/17/2018	8/28/2018	A8H0518-06	Copper	0.0727	0.00200	1.3	ppm
148-2982-NA-001-B	Drinking Fountain (Porcelain) - Classroom 4	8/17/2018	8/28/2018	A8H0518-06	Lead	13.8	0.200	15	ppb
148-2985-NA-001-A	Drinking Fountain (Porcelain) - Classroom 3	8/17/2018	8/28/2018	A8H0518-07	Copper	0.100	0.00200	1.3	ppm
148-2985-NA-001-A	Drinking Fountain (Porcelain) - Classroom 3	8/17/2018	8/28/2018	A8H0518-07	Lead	36.3	0.200	15	ppb
148-2985-NA-001-B	Drinking Fountain (Porcelain) - Classroom 3	8/17/2018	8/28/2018	A8H0518-08	Copper	0.0765	0.00200	1.3	ppm
148-2985-NA-001-B	Drinking Fountain (Porcelain) - Classroom 3	8/17/2018	8/28/2018	A8H0518-08	Lead	19.1	0.200	15	ppb
148-2988-NA-001-A	Sink (Food Prep) - Staff Room	8/17/2018	8/28/2018	A8H0518-09	Copper	0.115	0.00200	1.3	ppm
148-2988-NA-001-A	Sink (Food Prep) - Staff Room	8/17/2018	8/28/2018	A8H0518-09	Lead	48.3	0.200	15	ppb
148-2988-NA-001-B	Sink (Food Prep) - Staff Room	8/17/2018	8/28/2018	A8H0518-10	Copper	0.0195	0.00200	1.3	ppm
148-2988-NA-001-B	Sink (Food Prep) - Staff Room	8/17/2018	8/28/2018	A8H0518-10	Lead	2.67	0.200	15	ppb
148-2994-NA-001-A	Drinking Fountain (Porcelain) - Classroom 6	8/17/2018	8/29/2018	A8H0518-11RE1	Copper	1.08	0.0100	1.3	ppm
148-2994-NA-001-A	Drinking Fountain (Porcelain) - Classroom 6	8/17/2018	8/28/2018	A8H0518-11	Lead	114	0.200	15	ppb
148-2994-NA-001-B	Drinking Fountain (Porcelain) - Classroom 6	8/17/2018	8/28/2018	A8H0518-12	Copper	0.0309	0.00200	1.3	ppm
148-2994-NA-001-B	Drinking Fountain (Porcelain) - Classroom 6	8/17/2018	8/28/2018	A8H0518-12	Lead	12.8	0.200	15	ppb
148-2997-NA-001-A	Drinking Fountain (Porcelain) - Classroom 5	8/17/2018	8/28/2018	A8H0518-13	Copper	0.169	0.00200	1.3	ppm

148-2997-NA-001-A	Drinking Fountain (Porcelain) - Classroom 5	8/17/2018	8/28/2018	A8H0518-13	Lead	8.83	0.200	15	ppb
148-2997-NA-001-B	Drinking Fountain (Porcelain) - Classroom 5	8/17/2018	8/28/2018	A8H0518-14	Copper	0.158	0.00200	1.3	ppm
148-2997-NA-001-B	Drinking Fountain (Porcelain) - Classroom 5	8/17/2018	8/28/2018	A8H0518-14	Lead	11.9	0.200	15	ppb
148-3035-NA-001-A	Drinking Fountain (Porcelain) - Classroom 8	8/17/2018	8/29/2018	A8H0518-15RE1	Copper	1.30	0.0100	1.3	ppm
148-3035-NA-001-A	Drinking Fountain (Porcelain) - Classroom 8	8/17/2018	8/28/2018	A8H0518-15	Lead	23.9	0.200	15	ppb
148-3035-NA-001-B	Drinking Fountain (Porcelain) - Classroom 8	8/17/2018	8/28/2018	A8H0518-16	Copper	0.0737	0.00200	1.3	ppm
148-3035-NA-001-B	Drinking Fountain (Porcelain) - Classroom 8	8/17/2018	8/28/2018	A8H0518-16	Lead	7.90	0.200	15	ppb
148-2995-NA-001-A	Drinking Fountain (Porcelain) - Classroom 7	8/17/2018	8/28/2018	A8H0518-17	Copper	0.0223	0.00200	1.3	ppm
148-2995-NA-001-A	Drinking Fountain (Porcelain) - Classroom 7	8/17/2018	8/28/2018	A8H0518-17	Lead	10.7	0.200	15	ppb
148-2995-NA-001-B	Drinking Fountain (Porcelain) - Classroom 7	8/17/2018	8/28/2018	A8H0518-18	Copper	0.0131	0.00200	1.3	ppm
148-2995-NA-001-B	Drinking Fountain (Porcelain) - Classroom 7	8/17/2018	8/28/2018	A8H0518-18	Lead	2.83	0.200	15	ppb
148-2974-NA-001-A	Classroom Sink Bubblers - Classroom 9	8/17/2018	8/28/2018	A8H0518-19	Copper	0.0387	0.00200	1.3	ppm
148-2974-NA-001-A	Classroom Sink Bubblers - Classroom 9	8/17/2018	8/28/2018	A8H0518-19	Lead	13.1	0.200	15	ppb
148-2974-NA-001-B	Classroom Sink Bubblers - Classroom 9	8/17/2018	8/28/2018	A8H0518-20	Copper	0.0131	0.00200	1.3	ppm
148-2974-NA-001-B	Classroom Sink Bubblers - Classroom 9	8/17/2018	8/28/2018	A8H0518-20	Lead	9.83	0.200	15	ppb
148-2977-NA-001-A	Classroom Sink Bubblers - Classroom 10	8/17/2018	8/28/2018	A8H0518-21	Copper	0.0142	0.00200	1.3	ppm
148-2977-NA-001-A	Classroom Sink Bubblers - Classroom 10	8/17/2018	8/28/2018	A8H0518-21	Lead	6.79	0.200	15	ppb
148-2977-NA-001-B	Classroom Sink Bubblers - Classroom 10	8/17/2018	8/28/2018	A8H0518-22	Copper	0.00612	0.00200	1.3	ppm
148-2977-NA-001-B	Classroom Sink Bubblers - Classroom 10	8/17/2018	8/28/2018	A8H0518-22	Lead	7.75	0.200	15	ppb
148-3044-NA-001-A	Classroom Sink Bubblers - Classroom 28	8/17/2018	8/28/2018	A8H0518-23	Copper	0.0199	0.00200	1.3	ppm
148-3044-NA-001-A	Classroom Sink Bubblers - Classroom 28	8/17/2018	8/28/2018	A8H0518-23	Lead	7.25	0.200	15	ppb
148-3044-NA-001-B	Classroom Sink Bubblers - Classroom 28	8/17/2018	8/28/2018	A8H0518-24	Copper	0.0166	0.00200	1.3	ppm
148-3044-NA-001-B	Classroom Sink Bubblers - Classroom 28	8/17/2018	8/28/2018	A8H0518-24	Lead	0.341	0.200	15	ppb
148-3038-NA-001-A	Drinking Fountain (Porcelain) - Classroom 26	8/17/2018	8/28/2018	A8H0518-25	Copper	0.0404	0.00200	1.3	ppm
148-3038-NA-001-A	Drinking Fountain (Porcelain) - Classroom 26	8/17/2018	8/28/2018	A8H0518-25	Lead	24.1	0.200	15	ppb
148-3038-NA-001-B	Drinking Fountain (Porcelain) - Classroom 26	8/17/2018	8/28/2018	A8H0518-26	Copper	0.0259	0.00200	1.3	ppm
148-3038-NA-001-B	Drinking Fountain (Porcelain) - Classroom 26	8/17/2018	8/28/2018	A8H0518-26	Lead	4.52	0.200	15	ppb
148-3041-NA-001-A	Classroom Sink Bubblers - Classroom 27	8/17/2018	8/28/2018	A8H0518-27	Copper	0.00896	0.00200	1.3	ppm
148-3041-NA-001-A	Classroom Sink Bubblers - Classroom 27	8/17/2018	8/28/2018	A8H0518-27	Lead	4.30	0.200	15	ppb

148-3041-NA-001-B	Classroom Sink Bubbler - Classroom 27	8/17/2018	8/28/2018	A8H0518-28	Copper	0.00577	0.00200	1.3	ppm
148-3041-NA-001-B	Classroom Sink Bubbler - Classroom 27	8/17/2018	8/28/2018	A8H0518-28	Lead	0.810	0.200	15	ppb
148-2989-NA-001-A	Drinking Fountain (Porcelain) - Cafeteria	8/17/2018	8/28/2018	A8H0518-29	Copper	0.0364	0.00200	1.3	ppm
148-2989-NA-001-A	Drinking Fountain (Porcelain) - Cafeteria	8/17/2018	8/28/2018	A8H0518-29	Lead	20.6	0.200	15	ppb
148-2989-NA-001-B	Drinking Fountain (Porcelain) - Cafeteria	8/17/2018	8/28/2018	A8H0518-30	Copper	0.0293	0.00200	1.3	ppm
148-2989-NA-001-B	Drinking Fountain (Porcelain) - Cafeteria	8/17/2018	8/28/2018	A8H0518-30	Lead	15.8	0.200	15	ppb
148-3032-NA-001-A	Drinking Fountain (Plastic) - Gym	8/17/2018	8/28/2018	A8H0518-31	Copper	0.112	0.00200	1.3	ppm
148-3032-NA-001-A	Drinking Fountain (Plastic) - Gym	8/17/2018	8/28/2018	A8H0518-31	Lead	37.7	0.200	15	ppb
148-3032-NA-001-B	Drinking Fountain (Plastic) - Gym	8/17/2018	8/28/2018	A8H0518-32	Copper	0.247	0.00200	1.3	ppm
148-3032-NA-001-B	Drinking Fountain (Plastic) - Gym	8/17/2018	8/28/2018	A8H0518-32	Lead	30.7	0.200	15	ppb

Results highlighted indicate a value at or above the PPS Action Level and that the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.