

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Chief Joseph Elementary School - Test 4**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
148-CH2989-N/A-004-A	Cafeteria	5/21/2019	5/28/2019	A9E0811-04	Lead	9.71	0.20	15	ppb