

Portland Public Schools
Lead and Copper Water Sampling Results
Initial and Follow Up Flush Sample Data
Clarendon

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
150-CH2951-N/A-001-A	Gym Bubblers	3/2/2018	3/8/2018	A8C0111-03	Copper	0.00832	0.00100	1.3	ppm
150-CH2951-N/A-001-A	Gym Bubblers	3/2/2018	3/8/2018	A8C0111-03	Lead	11.9	0.200	15	ppb
150-CH2951-N/A-001-B	Gym Bubblers	3/2/2018	3/8/2018	A8C0111-04	Copper	0.0110	0.00100	1.3	ppm
150-CH2951-N/A-001-B	Gym Bubblers Hall Water	3/2/2018	3/8/2018	A8C0111-04	Lead	10.6	0.200	15	ppb
150-CH2961-N/A-001-A	Bottle Filler Hall Water	3/2/2018	3/8/2018	A8C0111-01	Copper	0.0738	0.00100	1.3	ppm
150-CH2961-N/A-001-A	Bottle Filler Hall Water	3/2/2018	3/8/2018	A8C0111-01	Lead	0.823	0.200	15	ppb
150-CH2961-N/A-001-B	Bottle Filler Hall Water	3/2/2018	3/12/2018	A8C0111-02	Copper	0.0133	0.00100	1.3	ppm
150-CH2961-N/A-001-B	Bottle Filler	3/2/2018	3/12/2018	A8C0111-02	Lead	0.361	0.200	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

*EPA action level for lead is 20 ppb and 1.3 ppm for copper