

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Clarendon Early Learning Academy - Test 4**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
150-CH2966-N/A-004-A	Classroom 003	4/2/2019	4/16/2019	A9D0366-01	Lead	1.87	0.20	15	ppb
150-CH2957-N/A-004-A	Classroom 007	4/2/2019	4/16/2019	A9D0366-03	Lead	6.44	0.20	15	ppb
150-CH2958-N/A-004-A	Classroom 015	4/2/2019	4/16/2019	A9D0366-05	Lead	0.795	0.20	15	ppb
150-CH2952-N/A-004-A	Classroom 017	4/2/2019	4/16/2019	A9D0366-07	Lead	2.38	0.20	15	ppb