

Portland Public Schools
Lead and Copper Water Sampling Results
Initial and Follow Up Flush Sample Data
2nd Site Visit - Cleveland High School

Sample Identification #	Location	Date Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
213-1101-A-001-A	Food Prep Sprayer - Kitchen	8/31/2018	9/7/2018	A8H0900-01	Copper	0.0882	0.00400	1.3	ppm
213-1101-A-001-A	Food Prep Sprayer - Kitchen	8/31/2018	9/10/2018	A8H0900-01RE1	Lead	2.45	0.200	15	ppb
213-1101-A-001-B	Food Prep Sprayer - Kitchen	8/31/2018	9/7/2018	A8H0900-02	Copper	0.0202	0.00400	1.3	ppm
213-1101-A-001-B	Food Prep Sprayer - Kitchen	8/31/2018	9/10/2018	A8H0900-02RE1	Lead	0.578	0.200	15	ppb
213-1101-B-001-A	Food Prep Faucet - Kitchen	8/31/2018	9/7/2018	A8H0900-03	Copper	0.289	0.00400	1.3	ppm
213-1101-B-001-A	Food Prep Faucet - Kitchen	8/31/2018	9/10/2018	A8H0900-03RE1	Lead	3.62	0.200	15	ppb
213-1101-B-001-B	Food Prep Faucet - Kitchen	8/31/2018	9/7/2018	A8H0900-04	Copper	0.0208	0.00400	1.3	ppm
213-1101-B-001-B	Food Prep Faucet - Kitchen	8/31/2018	9/10/2018	A8H0900-04RE1	Lead	0.657	0.200	15	ppb
213-1128-N/A-001-A	CTE Room Sink - Classroom 263	8/31/2018	9/7/2018	A8H0900-05	Copper	0.139	0.00400	1.3	ppm
213-1128-N/A-001-A	CTE Room Sink - Classroom 263	8/31/2018	9/10/2018	A8H0900-05RE1	Lead	12.1	0.200	15	ppb
213-1128-N/A-001-B	CTE Room Sink - Classroom 263	8/31/2018	9/7/2018	A8H0900-06	Copper	0.0100	0.00400	1.3	ppm
213-1128-N/A-001-B	CTE Room Sink - Classroom 263	8/31/2018	9/10/2018	A8H0900-06RE1	Lead	27.0	0.200	15	ppb
213-1125-N/A-001-A	CTE Room Sink - Classroom 263	8/31/2018	9/7/2018	A8H0900-07	Copper	0.0185	0.00400	1.3	ppm
213-1125-N/A-001-A	CTE Room Sink - Classroom 263	8/31/2018	9/10/2018	A8H0900-07RE1	Lead	9.33	0.200	15	ppb
213-1125-N/A-001-B	CTE Room Sink - Classroom 263	8/31/2018	9/7/2018	A8H0900-08	Copper	0.00893	0.00400	1.3	ppm
213-1125-N/A-001-B	CTE Room Sink - Classroom 263	8/31/2018	9/10/2018	A8H0900-08RE1	Lead	3.24	0.200	15	ppb
213-1117-N/A-001-A	CTE Room Sink - Classroom 287	8/31/2018	9/7/2018	A8H0900-09	Copper	0.0440	0.00400	1.3	ppm
213-1117-N/A-001-A	CTE Room Sink - Classroom 287	8/31/2018	9/10/2018	A8H0900-09RE1	Lead	4.14	0.200	15	ppb
213-1117-N/A-001-B	CTE Room Sink - Classroom 287	8/31/2018	9/7/2018	A8H0900-10	Copper	0.00626	0.00400	1.3	ppm
213-1117-N/A-001-B	CTE Room Sink - Classroom 287	8/31/2018	9/10/2018	A8H0900-10RE1	Lead	3.21	0.200	15	ppb
213-1120-N/A-001-A	CTE Room Sink - Classroom 287	8/31/2018	9/7/2018	A8H0900-11	Copper	0.0189	0.00400	1.3	ppm
213-1120-N/A-001-A	CTE Room Sink - Classroom 287	8/31/2018	9/10/2018	A8H0900-11RE1	Lead	14.0	0.200	15	ppb
213-1120-N/A-001-B	CTE Room Sink - Classroom 287	8/31/2018	9/10/2018	A8H0900-12RE1	Copper	ND	0.00200	1.3	ppm

213-1120-N/A-001-B	CTE Room Sink - Classroom 287	8/31/2018	9/10/2018	A8H0900-12RE1	Lead	4.74	0.200	15	ppb
213-1114-N/A-001-A	Drinking Fountain - Hallway 282	8/31/2018	9/6/2018	A8H0900-13	Copper	0.0121	0.00200	1.3	ppm
213-1114-N/A-001-A	Drinking Fountain - Hallway 282	8/31/2018	9/6/2018	A8H0900-13	Lead	1.32	0.200	15	ppb
213-1114-N/A-001-B	Drinking Fountain - Hallway 282	8/31/2018	9/6/2018	A8H0900-14	Copper	0.00499	0.00200	1.3	ppm
213-1114-N/A-001-B	Drinking Fountain - Hallway 282	8/31/2018	9/6/2018	A8H0900-14	Lead	0.683	0.200	15	ppb
213-1123-N/A-001-A	Drinking Fountain - Hallway 240/236	8/31/2018	9/6/2018	A8H0900-15	Copper	0.0329	0.00200	1.3	ppm
213-1123-N/A-001-A	Drinking Fountain - Hallway 240/236	8/31/2018	9/6/2018	A8H0900-15	Lead	3.39	0.200	15	ppb
213-1123-N/A-001-B	Drinking Fountain - Hallway 240/236	8/31/2018	9/7/2018	A8H0900-16	Copper	0.0296	0.00400	1.3	ppm
213-1123-N/A-001-B	Drinking Fountain - Hallway 240/236	8/31/2018	9/10/2018	A8H0900-16RE1	Lead	0.640	0.200	15	ppb
213-1119-N/A-001-A	Bubbler - Gym near G7	8/31/2018	9/6/2018	A8H0900-17	Copper	0.312	0.00200	1.3	ppm
213-1119-N/A-001-A	Bubbler - Gym near G7	8/31/2018	9/6/2018	A8H0900-17	Lead	18.4	0.200	15	ppb
213-1119-N/A-001-B	Bubbler - Gym near G7	8/31/2018	9/6/2018	A8H0900-18	Copper	0.170	0.00200	1.3	ppm
213-1119-N/A-001-B	Bubbler - Gym near G7	8/31/2018	9/6/2018	A8H0900-18	Lead	14.5	0.200	15	ppb
213-1122-N/A-001-A	Bubbler - Gym near G34	8/31/2018	9/7/2018	A8H0900-19	Copper	0.0108	0.00400	1.3	ppm
213-1122-N/A-001-A	Bubbler - Gym near G34	8/31/2018	9/10/2018	A8H0900-19RE1	Lead	11.5	0.200	15	ppb
213-1122-N/A-001-B	Bubbler - Gym near G34	8/31/2018	9/7/2018	A8H0900-20	Copper	0.00564	0.00400	1.3	ppm
213-1122-N/A-001-B	Bubbler - Gym near G34	8/31/2018	9/10/2018	A8H0900-20RE1	Lead	1.73	0.200	15	ppb

Results highlighted indicate a value at or above the PPS Action Level and that the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.