

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Cleveland High School - Test 3**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
213-CH1121-N/A-003-A	Hallway 117	4/11/2019	4/22/2019	A9D0538-01	Lead	7.27	0.20	15	ppb
213-CH1118-N/A-003-A	Hallway 116	4/11/2019	4/22/2019	A9D0538-03	Lead	30.90	0.20	15	ppb
213-CH1107-A-003-A	Cafeteria	4/11/2019	4/22/2019	A9D0538-05	Lead	10.1	0.20	15	ppb
213-CH1107-B-003-A	Cafeteria	4/11/2019	4/22/2019	A9D0538-07	Lead	4.06	0.20	15	ppb
213-CH1124-N/A-003-A	Gym G20 (Girls Locker Room)	4/11/2019	4/22/2019	A9D0538-09	Lead	14.1	0.20	15	ppb
213-CH1110-N/A-003-A	Gym G7 (Boys Locker Room)	4/11/2019	4/22/2019	A9D0538-11	Lead	1.89	0.20	15	ppb
213-CH1119-N/A-003-A	Gym G5	4/11/2019	4/22/2019	A9D0538-13	Lead	37.40	0.20	15	ppb
213-CH1135-N/A-003-A	Hallway 225	4/11/2019	4/22/2019	A9D0538-15	Lead	19.10	0.20	15	ppb
213-CHUNK-A-003-A	Hallway 218	4/11/2019	4/22/2019	A9D0538-17	Lead	0.759	0.20	15	ppb
213-CHUNK-B-003-A	Hallway 218	4/11/2019	4/22/2019	A9D0538-19	Lead	1.11	0.20	15	ppb
213-CH1132-N/A-003-A	Hallway 317	4/11/2019	4/22/2019	A9D0538-21	Lead	14.7	0.20	15	ppb
213-CH1193-N/A-003-A	Hallway 380	4/11/2019	4/22/2019	A9D0538-23	Lead	34.30	0.20	15	ppb

Results highlighted indicate a value at or above PPS Action Level and the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.