

Portland Public Schools
Lead and Copper Water Sampling Results
A (Initial) and B (Follow-Up) Sample Data
Columbia School of English

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	PPS Action Level*	Units
353-3061-A-001A Between Rms 9 & 11	08/06/18 10:59 AM	08/08/18 1:38 PM	18017743	Copper	< 0.1	1.3	ppm
353-3061-A-001A Between Rms 9 & 11	08/06/18 10:59 AM	08/08/18 1:38 PM	18017743	Lead	9	15	ppb
353-3061-A-001B Between Rms 9 & 11	08/06/18 10:59 AM	08/08/18 1:40 PM	18017740	Copper	< 0.1	1.3	ppm
353-3061-A-001B Between Rms 9 & 11	08/06/18 10:59 AM	08/08/18 1:40 PM	18017740	Lead	2	15	ppb
353-3055-A-001A Gym	08/06/18 11:04 AM	08/08/18 1:41 PM	18017741	Copper	< 0.1	1.3	ppm
353-3055-A-001A Gym	08/06/18 11:04 AM	08/08/18 1:41 PM	18017741	Lead	13	15	ppb
353-3055-A-001B Gym	08/06/18 11:04 AM	08/08/18 1:47 PM	18017739	Copper	< 0.1	1.3	ppm
353-3055-A-001B Gym	08/06/18 11:04 AM	08/08/18 1:47 PM	18017739	Lead	7	15	ppb

Analyzed by: Pixis Labs

Reviewed by: TRC Environmental Corporation

*EPA action level for lead is 20 ppb and 1.3 for copper