

Portland Public Schools
Lead and Copper Water Sampling Results
A (Initial) and B (Follow-Up) Sample Data
Columbia School of English

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	PPS Action Level*	Units
353-3064-N/A-002-A Classroom 9	12/12/18 6:37 AM	12/13/18 6:43 PM	18033556	Copper	0.2	1.3	ppm
353-3064-N/A-002-A Classroom 9	12/12/18 6:37 AM	12/13/18 6:43 PM	18033556	Lead	11	15	ppb
353-3064-N/A-002-B Classroom 9	12/12/18 6:38 AM	12/13/18 7:09 PM	18033557	Copper	< 0.1	1.3	ppm
353-3064-N/A-002-B Classroom 9	12/12/18 6:38 AM	12/13/18 7:09 PM	18033557	Lead	2	15	ppb
353-3058-N/A-002-A Gym	12/12/18 6:42 AM	12/13/18 7:12 PM	18033558	Copper	< 0.1	1.3	ppm
353-3058-N/A-002-A Gym	12/12/18 6:42 AM	12/13/18 7:12 PM	18033558	Lead	8	15	ppb
353-3058-N/A-002-B Gym	12/12/18 6:43 AM	12/13/18 7:16 PM	18033559	Copper	< 0.1	1.3	ppm
353-3058-N/A-002-B Gym	12/12/18 6:43 AM	12/13/18 7:16 PM	18033559	Lead	6	15	ppb
353-3079-N/A-002-A Hallway 36	12/12/18 6:50 AM	12/17/18 6:44 PM	18033560	Copper	1.2	1.3	ppm
353-3079-N/A-002-A Hallway 36	12/12/18 6:50 AM	12/17/18 6:44 PM	18033560	Lead	120	15	ppb
353-3079-N/A-002-B Hallway 36	12/12/18 6:51 AM	12/17/18 6:47 PM	18033561	Copper	0.4	1.3	ppm
353-3079-N/A-002-B Hallway 36	12/12/18 6:51 AM	12/17/18 6:47 PM	18033561	Lead	33	15	ppb
353-3075-N/A-002-A Classroom 16	12/12/18 6:55 AM	12/13/18 7:19 PM	18033562	Copper	0.2	1.3	ppm
353-3075-N/A-002-A Classroom 16	12/12/18 6:55 AM	12/13/18 7:19 PM	18033562	Lead	2	15	ppb
353-3075-N/A-002-B Classroom 16	12/12/18 6:56 AM	12/13/18 7:23 PM	18033563	Copper	0.2	1.3	ppm
353-3075-N/A-002-B Classroom 16	12/12/18 6:56 AM	12/13/18 7:23 PM	18033563	Lead	11	15	ppb
353-3078-A-002-A Hallway 16 (Bottle Fill)	12/12/18 7:01 AM	12/13/18 7:27 PM	18033564	Copper	< 0.1	1.3	ppm
353-3078-A-002-A Hallway 16 (Bottle Fill)	12/12/18 7:01 AM	12/13/18 7:27 PM	18033564	Lead	17	15	ppb
353-3078-A-002-B Hallway 16 (Bottle Fill)	12/12/18 7:02 AM	12/13/18 7:30 PM	18033565	Copper	< 0.1	1.3	ppm
353-3078-A-002-B Hallway 16 (Bottle Fill)	12/12/18 7:02 AM	12/13/18 7:30 PM	18033565	Lead	31	15	ppb
353-3078-B-002-A Hallway 16	12/12/18 7:03 AM	12/13/18 7:34 PM	18033566	Copper	< 0.1	1.3	ppm
353-3078-B-002-A Hallway 16	12/12/18 7:03 AM	12/13/18 7:34 PM	18033566	Lead	30	15	ppb
353-3078-B-002-B Hallway 16	12/12/18 7:04 AM	12/13/18 7:37 PM	18033567	Copper	< 0.1	1.3	ppm
353-3078-B-002-B Hallway 16	12/12/18 7:04 AM	12/13/18 7:37 PM	18033567	Lead	29	15	ppb
353-3107-N/A-002-A Cafeteria	12/12/18 7:10 AM	12/13/18 7:41 PM	18033568	Copper	< 0.1	1.3	ppm
353-3107-N/A-002-A Cafeteria	12/12/18 7:10 AM	12/13/18 7:41 PM	18033568	Lead	2	15	ppb
353-3107-N/A-002-B Cafeteria	12/12/18 7:11 AM	12/17/18 6:51 PM	18033569	Copper	< 0.1	1.3	ppm
353-3107-N/A-002-B Cafeteria	12/12/18 7:11 AM	12/17/18 6:51 PM	18033569	Lead	2	15	ppb
353-3067-N/A-002-A Kitchen (Sprayer)	12/12/18 7:18 AM	12/17/18 7:09 PM	18033570	Copper	0.3	1.3	ppm
353-3067-N/A-002-A Kitchen (Sprayer)	12/12/18 7:18 AM	12/17/18 7:09 PM	18033570	Lead	27	15	ppb
353-3067-N/A-002-B Kitchen (Sprayer)	12/12/18 7:19 AM	12/17/18 7:13 PM	18033571	Copper	< 0.1	1.3	ppm
353-3067-N/A-002-B Kitchen (Sprayer)	12/12/18 7:19 AM	12/17/18 7:13 PM	18033571	Lead	4	15	ppb
353-3070-N/A-002-A Kitchen (Faucet)	12/12/18 7:20 AM	12/17/18 7:16 PM	18033572	Copper	< 0.1	1.3	ppm
353-3070-N/A-002-A Kitchen (Faucet)	12/12/18 7:20 AM	12/17/18 7:16 PM	18033572	Lead	3	15	ppb
353-3070-N/A-002-B Kitchen (Faucet)	12/12/18 7:21 AM	12/17/18 7:20 PM	18033573	Copper	< 0.1	1.3	ppm
353-3070-N/A-002-B Kitchen (Faucet)	12/12/18 7:21 AM	12/17/18 7:20 PM	18033573	Lead	1	15	ppb

Results highlighted indicate a value at or above the PPS Action Level and that the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.