

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Columbia Transport Facility - Test 4**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
353-CHCOL1-N/A-004-A	Staff Kitchen (Basement)	5/21/2019	5/28/2019	A9E0811-01	Lead	5.38	0.20	15	ppb
353-CHCOL3-N/A-004-A	Staff Kitchen (Basement)	5/21/2019	5/28/2019	A9E0811-02	Lead	35.20	0.20	15	ppb

Results highlighted indicate a value at or above PPS Action Level and the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.