

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Green Thumb Program (305)- Test 3**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
305-CH-5751-N/A-003-A	Room 3	10/11/2019	10/16/2019	A9J0428-02	Lead	11.7	0.20	15	ppb
305-CH-5753-N/A-003-A	Room 4	10/11/2019	10/16/2019	A9J0428-03	Lead	19.00	0.20	15	ppb
305-CH-5754-N/A-003-A	Room 5	10/11/2019	10/16/2019	A9J0428-04	Lead	21.30	0.20	15	ppb

Results highlighted indicate a value at or above PPS Action Level and the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.