Portland Public Schools
Lead and Copper Water Sampling Results
A (Initial) and B (Follow-Up) Sample Data
Clark Creative Science School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	PPS Action Level*	Units
240-5429-A-001A Across from Gym	08/06/18 8:48 AM	08/08/18 1:58 PM	18017754	Copper	< 0.1	1.3	ppm
240-5429-A-001A Across from Gym	08/06/18 8:48 AM	08/08/18 1:58 PM	18017754	Lead	12	15	ppb
240-5429-A-001B Across from Gym	08/06/18 8:48 AM	08/08/18 2:11 PM	18017751	Copper	< 0.1	1.3	ppm
240-5429-A-001B Across from Gym	08/06/18 8:48 AM	08/08/18 2:11 PM	18017751	Lead	4	15	ppb
240-5432-A-001A Gym	08/06/18 8:54 AM	08/08/18 2:13 PM	18017750	Copper	< 0.1	1.3	ppm
240-5432-A-001A Gym	08/06/18 8:54 AM	08/08/18 2:13 PM	18017750	Lead	35	15	ppb
240-5432-A-001B Gym	08/06/18 8:54 AM	08/08/18 2:14 PM	18017755	Copper	< 0.1	1.3	ppm
240-5432-A-001B Gym	08/06/18 8:54 AM	08/08/18 2:14 PM	18017755	Lead	16	15	ppb
240-5479-A-001A Near Rm 25	08/06/18 8:59 AM	08/08/18 2:16 PM	18017752	Copper	< 0.1	1.3	ppm
240-5479-A-001A Near Rm 25	08/06/18 8:59 AM	08/08/18 2:16 PM	18017752	Lead	16	15	ppb
240-5479-A-001B Near Rm 25	08/06/18 8:59 AM	08/08/18 2:18 PM	18017753	Copper	< 0.1	1.3	ppm
240-5479-A-001B Near Rm 25	08/06/18 8:59 AM	08/08/18 2:18 PM	18017753	Lead	37	15	ppb
240-5438-A-001A Near Rm 20	08/06/18 9:04 AM	08/08/18 2:20 PM	18017756	Copper	< 0.1	1.3	ppm
240-5438-A-001A Near Rm 20	08/06/18 9:04 AM	08/08/18 2:20 PM	18017756	Lead	7	15	ppb
240-5438-A-001B Near Rm 20	08/06/18 9:04 AM	08/08/18 2:22 PM	18017757	Copper	< 0.1	1.3	ppm
240-5438-A-001B Near Rm 20	08/06/18 9:04 AM	08/08/18 2:22 PM	18017757	Lead	9	15	ppb
240-5458-A-001A Between RR across from Cafeteria	08/06/18 9:09 AM	08/08/18 2:23 PM	18017758	Copper	< 0.1	1.3	ppm
240-5458-A-001A Between RR across from Cafeteria	08/06/18 9:09 AM	08/08/18 2:23 PM	18017758	Lead	2	15	ppb
240-5458-A-001B Between RR across from Cafeteria	08/06/18 9:09 AM	08/08/18 2:25 PM	18017759	Copper	< 0.1	1.3	ppm
240-5458-A-001B Between RR across from Cafeteria	08/06/18 9:09 AM	08/08/18 2:25 PM	18017759	Lead	< 1	15	ppb
240-5457-A-001A Near Rm 4	08/06/18 9:13 AM	08/08/18 2:27 PM	18017760	Copper	< 0.1	1.3	ppm
240-5457-A-001A Near Rm 4	08/06/18 9:13 AM	08/08/18 2:27 PM	18017760	Lead	8	15	ppb
240-5457-A-001B Near Rm 4	08/06/18 9:13 AM	08/08/18 2:40 PM	18017761	Copper	< 0.1	1.3	ppm
240-5457-A-001B Near Rm 4	08/06/18 9:13 AM	08/08/18 2:40 PM	18017761	Lead	7	15	ppb
240-5470-A-001A Cafeteria	08/06/18 9:20 AM	08/08/18 2:41 PM	18017762	Copper	< 0.1	1.3	ppm
240-5470-A-001A Cafeteria	08/06/18 9:20 AM	08/08/18 2:41 PM	18017762	Lead	9	15	ppb
240-5470-A-001B Cafeteria	08/06/18 9:20 AM	08/08/18 2:43 PM	18017763	Copper	< 0.1	1.3	ppm
240-5470-A-001B Cafeteria	08/06/18 9:20 AM	08/08/18 2:43 PM	18017763	Lead	3	15	ppb
240-5467-A-001A Kitchen Food Prep Faucet	08/06/18 9:25 AM	08/08/18 2:45 PM	18017764	Copper	< 0.1	1.3	ppm
240-5467-A-001A Kitchen Food Prep Faucet	08/06/18 9:25 AM	08/08/18 2:45 PM	18017764	Lead	1	15	ppb
240-5467-A-001B Kitchen Food Prep Faucet	08/06/18 9:25 AM	08/08/18 2:47 PM	18017765	Copper	< 0.1	1.3	ppm
240-5467-A-001B Kitchen Food Prep Faucet	08/06/18 9:25 AM	08/08/18 2:47 PM	18017765	Lead	2	15	ppb

Results highlighted indicate a value at or above the PPS Action Level and that the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.

Analyzed by: Pixis Labs

Reviewed by: TRC Environmental Corporation

*EPA action level for lead is 20 ppb and 1.3 for copper