

Portland Public Schools
Lead and Copper Water Sampling Results
Initial and Follow Up Flush Sample Data
CSS

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
240-CH5430-N/A-002-A	Media Center	11/6/2018	11/9/2018	A8K0264-19	Copper	0.0402	0.00200	1.3	ppm
240-CH5430-N/A-002-A	Media Center	11/6/2018	11/9/2018	A8K0264-19	Lead	25.3	0.200	15	ppb
240-CH5430-N/A-002-B	Media Center	11/6/2018	11/9/2018	A8K0264-20	Copper	0.0182	0.00200	1.3	ppm
240-CH5430-N/A-002-B	Media Center	11/6/2018	11/9/2018	A8K0264-20	Lead	6.80	0.200	15	ppb
240-CH5432-N/A-002-A	Gym Bubbler	11/6/2018	11/9/2018	A8K0264-33RE1	Copper	0.00661	0.00200	1.3	ppm
240-CH5432-N/A-002-A	Gym Bubbler	11/6/2018	11/9/2018	A8K0264-33	Lead	18.1	0.200	15	ppb
240-CH5432-N/A-002-B	Gym Bubbler	11/6/2018	11/9/2018	A8K0264-34RE1	Copper	0.00466	0.00200	1.3	ppm
240-CH5432-N/A-002-B	Gym Bubbler	11/6/2018	11/9/2018	A8K0264-34	Lead	8.63	0.200	15	ppb
240-CH5441-N/A-002-A	Room 19	11/6/2018	11/9/2018	A8K0264-23	Copper	ND	0.00200	1.3	ppm
240-CH5441-N/A-002-A	Room 19	11/6/2018	11/9/2018	A8K0264-23	Lead	1.57	0.200	15	ppb
240-CH5441-N/A-002-B	Room 19	11/6/2018	11/9/2018	A8K0264-24	Copper	ND	0.00200	1.3	ppm
240-CH5441-N/A-002-B	Room 19	11/6/2018	11/9/2018	A8K0264-24	Lead	1.60	0.200	15	ppb
240-CH5444-N/A-002-A	Room 18	11/6/2018	11/9/2018	A8K0264-25	Copper	0.0226	0.00200	1.3	ppm
240-CH5444-N/A-002-A	Room 18	11/6/2018	11/9/2018	A8K0264-25	Lead	5.54	0.200	15	ppb
240-CH5444-N/A-002-B	Room 18	11/6/2018	11/9/2018	A8K0264-26RE1	Copper	0.00613	0.00200	1.3	ppm
240-CH5444-N/A-002-B	Room 18	11/6/2018	11/9/2018	A8K0264-26	Lead	3.43	0.200	15	ppb

Analyzed by:

Reviewed by: PBS Engineering and Environmental

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

240-CH5447-N/A-002-A	Room 17	11/6/2018	11/9/2018	A8K0264-29RE1	Copper	0.0186	0.00200	1.3	ppm
240-CH5447-N/A-002-A	Room 17	11/6/2018	11/9/2018	A8K0264-29	Lead	16.5	0.200	15	ppb
240-CH5447-N/A-002-B	Room 17	11/6/2018	11/9/2018	A8K0264-30RE1	Copper	0.00583	0.00200	1.3	ppm
240-CH5447-N/A-002-B	Room 17	11/6/2018	11/9/2018	A8K0264-30	Lead	19.3	0.200	15	ppb
240-CH5450-N/A-002-A	Room 16	11/6/2018	11/9/2018	A8K0264-27RE1	Copper	0.0286	0.00200	1.3	ppm
240-CH5450-N/A-002-A	Room 16	11/6/2018	11/9/2018	A8K0264-27	Lead	9.15	0.200	15	ppb
240-CH5450-N/A-002-B	Room 16	11/6/2018	11/9/2018	A8K0264-28RE1	Copper	0.00466	0.00200	1.3	ppm
240-CH5450-N/A-002-B	Room 16	11/6/2018	11/9/2018	A8K0264-28	Lead	4.07	0.200	15	ppb
240-CH5453-N/A-002-A	Room 14	11/6/2018	11/9/2018	A8K0264-21	Copper	0.00573	0.00200	1.3	ppm
240-CH5453-N/A-002-A	Room 14	11/6/2018	11/9/2018	A8K0264-21	Lead	2.09	0.200	15	ppb
240-CH5453-N/A-002-B	Room 14	11/6/2018	11/9/2018	A8K0264-22	Copper	ND	0.00200	1.3	ppm
240-CH5453-N/A-002-B	Room 14	11/6/2018	11/9/2018	A8K0264-22	Lead	1.01	0.200	15	ppb
240-CH5460-N/A-002-A	Room 4	11/6/2018	11/9/2018	A8K0264-07	Copper	0.202	0.00200	1.3	ppm
240-CH5460-N/A-002-A	Room 4	11/6/2018	11/9/2018	A8K0264-07	Lead	13.4	0.200	15	ppb
240-CH5460-N/A-002-B	Room 4	11/6/2018	11/9/2018	A8K0264-08	Copper	0.0211	0.00200	1.3	ppm
240-CH5460-N/A-002-B	Room 4	11/6/2018	11/9/2018	A8K0264-08	Lead	2.18	0.200	15	ppb
240-CH5463-N/A-002-A	Room 5	11/6/2018	11/9/2018	A8K0264-11	Copper	0.00896	0.00200	1.3	ppm
240-CH5463-N/A-002-A	Room 5	11/6/2018	11/9/2018	A8K0264-11	Lead	6.58	0.200	15	ppb
240-CH5463-N/A-002-B	Room 5	11/6/2018	11/9/2018	A8K0264-12	Copper	0.00233	0.00200	1.3	ppm
240-CH5463-N/A-002-B	Room 5	11/6/2018	11/9/2018	A8K0264-12	Lead	3.56	0.200	15	ppb

Analyzed by:

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

Reviewed by: PBS Engineering and Environmental

Page 2 of 4

240-CH5466-N/A-002-A	Room 6	11/6/2018	11/9/2018	A8K0264-15	Copper	ND	0.00200	1.3	ppm
240-CH5466-N/A-002-A	Room 6	11/6/2018	11/9/2018	A8K0264-15	Lead	6.52	0.200	15	ppb
240-CH5466-N/A-002-B	Room 6	11/6/2018	11/9/2018	A8K0264-16	Copper	ND	0.00200	1.3	ppm
240-CH5466-N/A-002-B	Room 6	11/6/2018	11/9/2018	A8K0264-16	Lead	1.10	0.200	15	ppb
240-CH5469-N/A-002-A	Room 7	11/6/2018	11/9/2018	A8K0264-17	Copper	0.0569	0.00200	1.3	ppm
240-CH5469-N/A-002-A	Room 7	11/6/2018	11/9/2018	A8K0264-17	Lead	14.2	0.200	15	ppb
240-CH5469-N/A-002-B	Room 7	11/6/2018	11/9/2018	A8K0264-18	Copper	0.0328	0.00200	1.3	ppm
240-CH5469-N/A-002-B	Room 7	11/6/2018	11/9/2018	A8K0264-18	Lead	32.2	0.200	15	ppb
240-CH5472-N/A-002-A	Room 8	11/6/2018	11/9/2018	A8K0264-13	Copper	0.00584	0.00200	1.3	ppm
240-CH5472-N/A-002-A	Room 8	11/6/2018	11/9/2018	A8K0264-13	Lead	4.28	0.200	15	ppb
240-CH5472-N/A-002-B	Room 8	11/6/2018	11/9/2018	A8K0264-14	Copper	0.00366	0.00200	1.3	ppm
240-CH5472-N/A-002-B	Room 8	11/6/2018	11/9/2018	A8K0264-14	Lead	1.43	0.200	15	ppb
240-CH5475-N/A-002-A	Room 9	11/6/2018	11/9/2018	A8K0264-09	Copper	0.0526	0.00200	1.3	ppm
240-CH5475-N/A-002-A	Room 9	11/6/2018	11/9/2018	A8K0264-09	Lead	4.47	0.200	15	ppb
240-CH5475-N/A-002-B	Room 9	11/6/2018	11/9/2018	A8K0264-10	Copper	0.00920	0.00200	1.3	ppm
240-CH5475-N/A-002-B	Room 9	11/6/2018	11/9/2018	A8K0264-10	Lead	0.710	0.200	15	ppb
240-CH5477-N/A-002-A	Room 2	11/6/2018	11/9/2018	A8K0264-01	Copper	0.0295	0.00200	1.3	ppm
240-CH5477-N/A-002-A	Room 2	11/6/2018	11/9/2018	A8K0264-01	Lead	12.4	0.200	15	ppb
240-CH5477-N/A-002-B	Room 2	11/6/2018	11/9/2018	A8K0264-02	Copper	0.00649	0.00200	1.3	ppm
240-CH5477-N/A-002-B	Room 2	11/6/2018	11/9/2018	A8K0264-02	Lead	2.97	0.200	15	ppb

Analyzed by:

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

Reviewed by: PBS Engineering and Environmental

Page 3 of 4

240-CH5478-N/A-002-A	Room 10	11/6/2018	11/9/2018	A8K0264-03	Copper	0.255	0.00200	1.3	ppm
240-CH5478-N/A-002-A	Room 10	11/6/2018	11/9/2018	A8K0264-03	Lead	10.2	0.200	15	ppb
240-CH5478-N/A-002-B	Room 10	11/6/2018	11/9/2018	A8K0264-04	Copper	0.0330	0.00200	1.3	ppm
240-CH5478-N/A-002-B	Room 10	11/6/2018	11/9/2018	A8K0264-04	Lead	8.37	0.200	15	ppb
240-CH5479-N/A-002-A	Hallway Bubblers	11/6/2018	11/9/2018	A8K0264-31RE1	Copper	0.0124	0.00200	1.3	ppm
240-CH5479-N/A-002-A	Hallway Bubblers	11/6/2018	11/9/2018	A8K0264-31	Lead	32.0	0.200	15	ppb
240-CH5479-N/A-002-B	Hallway Bubblers	11/6/2018	11/9/2018	A8K0264-32RE1	Copper	0.00629	0.00200	1.3	ppm
240-CH5479-N/A-002-B	Hallway Bubblers	11/6/2018	11/9/2018	A8K0264-32	Lead	23.9	0.200	15	ppb
240-CH5480-N/A-002-A	Room 3	11/6/2018	11/9/2018	A8K0264-05	Copper	0.0629	0.00200	1.3	ppm
240-CH5480-N/A-002-A	Room 3	11/6/2018	11/9/2018	A8K0264-05	Lead	4.76	0.200	15	ppb
240-CH5480-N/A-002-B	Room 3	11/6/2018	11/9/2018	A8K0264-06	Copper	0.0138	0.00200	1.3	ppm
240-CH5480-N/A-002-B	Room 3	11/6/2018	11/9/2018	A8K0264-06	Lead	1.14	0.200	15	ppb

Results highlighted indicate a value at or above the PPS Action Level and that the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.

Analyzed by:

Reviewed by: PBS Engineering and Environmental

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

Page 4 of 4