

Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Creative Science School (Clark K-8) - Test 4

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
240-CH-5762-A-004-A	Staff Break Room (26C)	1/16/2020	1/22/2020	A0A0515-01	Lead	37.70	0.20	15	ppb
240-CH-5763-A-004-A	Staff Break Room (26C)	1/16/2020	1/22/2020	A0A0515-02	Lead	7.94	0.20	15	ppb
240-CH-5764-A-004-A	Staff Break Room (26C)	1/16/2020	1/22/2020	A0A0515-03	Lead	9.08	0.20	15	ppb
240-CH-5765-A-004-A	Work Room (117)	1/16/2020	1/22/2020	A0A0515-04	Lead	8.82	0.20	15	ppb

Results highlighted indicate a value at or above PPS Action Level and the fixture is under further review. During

Results highlighted indicate a value at or above PPS Action Level and the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.