

Portland Public Schools
Lead and Copper Water Sampling Results
Initial and Follow Up Flush Sample Data
Creston

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
243-CH5358-N/A-001-A	Hall Bubbler	4/25/2018	5/3/2018	A8D0790-13	Copper	0.123	0.001	1.3	ppm
243-CH5358-N/A-001-A	Hall Bubbler	4/25/2018	5/3/2018	A8D0790-13	Lead	0.204	0.2	15	ppb
243-CH5358-N/A-001-B	Hall Bubbler	4/25/2018	5/3/2018	A8D0790-14	Copper	0.118	0.001	1.3	ppm
243-CH5358-N/A-001-B	Hall Bubbler	4/25/2018	5/3/2018	A8D0790-14	Lead	ND	0.2	15	ppb
243-CH5361-N/A-001-A	Hall Bubbler	4/25/2018	5/3/2018	A8D0790-11	Copper	0.15	0.001	1.3	ppm
243-CH5361-N/A-001-A	Hall Bubbler	4/25/2018	5/3/2018	A8D0790-11	Lead	0.454	0.2	15	ppb
243-CH5361-N/A-001-B	Hall Bubbler	4/25/2018	5/3/2018	A8D0790-12	Copper	0.142	0.001	1.3	ppm
243-CH5361-N/A-001-B	Hall Bubbler	4/25/2018	5/3/2018	A8D0790-12	Lead	ND	0.2	15	ppb
243-CH5364-N/A-001-A	Hall Bubbler	4/25/2018	5/3/2018	A8D0790-09	Copper	0.0964	0.001	1.3	ppm
243-CH5364-N/A-001-A	Hall Bubbler	4/25/2018	5/3/2018	A8D0790-09	Lead	0.666	0.2	15	ppb
243-CH5364-N/A-001-B	Hall Bubbler	4/25/2018	5/3/2018	A8D0790-10	Copper	0.0687	0.001	1.3	ppm
243-CH5364-N/A-001-B	Hall Bubbler	4/25/2018	5/3/2018	A8D0790-10	Lead	0.398	0.2	15	ppb
243-CH5365-N/A-001-A	Hall Bubbler	4/25/2018	5/3/2018	A8D0790-03	Copper	0.0864	0.001	1.3	ppm
243-CH5365-N/A-001-A	Hall Bubbler	4/25/2018	5/3/2018	A8D0790-03	Lead	3.49	0.2	15	ppb
243-CH5365-N/A-001-B	Hall Bubbler	4/25/2018	5/3/2018	A8D0790-04	Copper	0.261	0.001	1.3	ppm
243-CH5365-N/A-001-B	Hall Bubbler	4/25/2018	5/3/2018	A8D0790-04	Lead	0.715	0.2	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

Page 1 of 2

243-CH5367-N/A-001-A	Hall Bubbler	4/25/2018	5/3/2018	A8D0790-07	Copper	0.106	0.001	1.3	ppm
243-CH5367-N/A-001-A	Hall Bubbler	4/25/2018	5/3/2018	A8D0790-07	Lead	1.15	0.2	15	ppb
243-CH5367-N/A-001-B	Hall Bubbler	4/25/2018	5/3/2018	A8D0790-08	Copper	0.131	0.001	1.3	ppm
243-CH5367-N/A-001-B	Hall Bubbler	4/25/2018	5/3/2018	A8D0790-08	Lead	0.232	0.2	15	ppb
243-CH5370-N/A-001-A	Hall Bubbler	4/25/2018	5/3/2018	A8D0790-05	Copper	0.0753	0.001	1.3	ppm
243-CH5370-N/A-001-A	Hall Bubbler	4/25/2018	5/3/2018	A8D0790-05	Lead	1.06	0.2	15	ppb
243-CH5370-N/A-001-B	Hall Bubbler	4/25/2018	5/3/2018	A8D0790-06	Copper	0.154	0.001	1.3	ppm
243-CH5370-N/A-001-B	Hall Bubbler	4/25/2018	5/3/2018	A8D0790-06	Lead	0.743	0.2	15	ppb
243-CH5373-N/A-001-A	Hall Bubbler	4/25/2018	5/3/2018	A8D0790-01	Copper	0.137	0.001	1.3	ppm
243-CH5373-N/A-001-A	Hall Bubbler	4/25/2018	5/3/2018	A8D0790-01	Lead	1.09	0.2	15	ppb
243-CH5373-N/A-001-B	Hall Bubbler	4/25/2018	5/3/2018	A8D0790-02	Copper	0.269	0.001	1.3	ppm
243-CH5373-N/A-001-B	Hall Bubbler	4/25/2018	5/3/2018	A8D0790-02	Lead	1.4	0.2	15	ppb

Analyzed by: Apex Laboratories

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

Reviewed by: PBS Engineering and Environmental

Page 2 of 2