

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Creston K-8 School - Test 3**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
243-CH5372-N/A-003-A	Hallway (Cafeteria)	3/29/2019	4/9/2019	A9C1066-01	Lead	16.90	0.20	15	ppb
243-CH5349-N/A-003-A	Staff Room	3/29/2019	4/9/2019	A9C1066-03	Lead	6.3	0.20	15	ppb
243-CH5356-N/A-003-A	Classroom 115	3/29/2019	4/9/2019	A9C1066-05	Lead	8.08	0.20	15	ppb
243-CH5368-N/A-003-A	Gym - Main	3/29/2019	4/9/2019	A9C1066-07	Lead	2.87	0.20	15	ppb
243-CH5371-A-003-A	Gym - Main	3/29/2019	4/9/2019	A9C1066-09	Lead	4.38	0.20	15	ppb
243-CH5240-N/A-003-A	Classroom 5	3/29/2019	4/9/2019	A9C1066-11	Lead	7.95	0.20	15	ppb
243-CH7777-N/A-003-A	Classroom 7	3/29/2019	4/9/2019	A9C1066-13	Lead	4.73	0.20	15	ppb

Results highlighted indicate a value at or above the PPS Action Level and that the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.