

Portland Public Schools
Lead and Copper Water Sampling Results
Initial and Follow Up Flush Sample Data
DaVinci/Monroe

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
365CH-4603-A-001-A	Near CR 204	8/16/2018	8/21/2018	1808845-01A	Copper	0.0405	0.0000259	1.3	ppm
365CH-4603-A-001-A	Near CR 204	8/16/2018	8/21/2018	1808845-01A	Lead	9.16	0.00523	15	ppb
365CH-4603-A-001-B	Near CR 204	8/16/2018	8/21/2018	1808845-02A	Copper	0.00580	0.0000259	1.3	ppm
365CH-4603-A-001-B	Near CR 204	8/16/2018	8/21/2018	1808845-02A	Lead	3.01	0.00523	15	ppb
365CH-4603-B-001-A	Near CR 204	8/16/2018	8/21/2018	1808845-03A	Copper	0.0199	0.0000259	1.3	ppm
365CH-4603-B-001-A	Near CR 204	8/16/2018	8/21/2018	1808845-03A	Lead	4.82	0.00523	15	ppb
365CH-4603-B-001-B	Near CR 204	8/16/2018	8/21/2018	1808845-04A	Copper	0.00474	0.0000259	1.3	ppm
365CH-4603-B-001-B	Near CR 204	8/16/2018	8/21/2018	1808845-04A	Lead	5.93	0.00523	15	ppb
365CH-4612-A-001-A	Near CR 211	8/16/2018	8/21/2018	1808845-05A	Copper	0.0143	0.0000259	1.3	ppm
365CH-4612-A-001-A	Near CR 211	8/16/2018	8/21/2018	1808845-05A	Lead	3.26	0.00523	15	ppb
365CH-4612-A-001-B	Near CR 211	8/16/2018	8/21/2018	1808845-06A	Copper	0.00620	0.0000259	1.3	ppm
365CH-4612-A-001-B	Near CR 211	8/16/2018	8/21/2018	1808845-06A	Lead	0.643	0.00523	15	ppb
365CH-4612-B-001-A	Near CR 211	8/16/2018	8/21/2018	1808845-07A	Copper	0.0356	0.0000259	1.3	ppm
365CH-4612-B-001-A	Near CR 211	8/16/2018	8/21/2018	1808845-07A	Lead	6.49	0.00523	15	ppb
365CH-4612-B-001-B	Near CR 211	8/16/2018	8/21/2018	1808845-08A	Copper	0.00674	0.0000259	1.3	ppm
365CH-4612-B-001-B	Near CR 211	8/16/2018	8/21/2018	1808845-08A	Lead	0.947	0.00523	15	ppb

Analyzed by: Neilson Research Corporation
Reviewed by: PBS Engineering and Environmental

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

365CH-4606-A-001-A	Near CR 201	8/16/2018	8/21/2018	1808845-09A	Copper	0.0369	0.0000259	1.3	ppm
365CH-4606-A-001-A	Near CR 201	8/16/2018	8/21/2018	1808845-09A	Lead	11.8	0.00523	15	ppb
365CH-4606-A-001-B	Near CR 201	8/16/2018	8/21/2018	1808845-10A	Copper	0.00441	0.0000259	1.3	ppm
365CH-4606-A-001-B	Near CR 201	8/16/2018	8/21/2018	1808845-10A	Lead	0.552	0.00523	15	ppb
365CH-4606-B-001-A	Near CR 201	8/16/2018	8/21/2018	1808845-11A	Copper	0.0416	0.0000259	1.3	ppm
365CH-4606-B-001-A	Near CR 201	8/16/2018	8/21/2018	1808845-11A	Lead	9.04	0.00523	15	ppb
365CH-4606-B-001-B	Near CR 201	8/16/2018	8/21/2018	1808845-12A	Copper	0.00461	0.0000259	1.3	ppm
365CH-4606-B-001-B	Near CR 201	8/16/2018	8/21/2018	1808845-12A	Lead	0.779	0.00523	15	ppb
365CH-4616-A-001-A	Near CR 109	8/16/2018	8/21/2018	1808845-13A	Copper	0.0449	0.0000259	1.3	ppm
365CH-4616-A-001-A	Near CR 109	8/16/2018	8/21/2018	1808845-13A	Lead	2.29	0.00523	15	ppb
365CH-4616-A-001-B	Near CR 109	8/16/2018	8/21/2018	1808845-14A	Copper	0.00492	0.0000259	1.3	ppm
365CH-4616-A-001-B	Near CR 109	8/16/2018	8/21/2018	1808845-14A	Lead	0.163	0.00523	15	ppb
365CH-4616-B-001-A	Near CR 109	8/16/2018	8/21/2018	1808845-15A	Copper	0.0171	0.0000259	1.3	ppm
365CH-4616-B-001-A	Near CR 109	8/16/2018	8/21/2018	1808845-15A	Lead	0.661	0.00523	15	ppb
365CH-4616-B-001-B	Near CR 109	8/16/2018	8/21/2018	1808845-16A	Copper	0.00501	0.0000259	1.3	ppm
365CH-4616-B-001-B	Near CR 109	8/16/2018	8/21/2018	1808845-16A	Lead	0.133	0.00523	15	ppb
365CH-4602-NA-001-A	Kitchen	8/16/2018	8/21/2018	1808845-17A	Copper	0.287	0.0000259	1.3	ppm
365CH-4602-NA-001-A	Kitchen	8/16/2018	8/21/2018	1808845-17A	Lead	11.5	0.00523	15	ppb
365CH-4602-NA-001-B	Kitchen	8/16/2018	8/21/2018	1808845-18A	Copper	0.00842	0.0000259	1.3	ppm
365CH-4602-NA-001-B	Kitchen	8/16/2018	8/21/2018	1808845-18A	Lead	0.27	0.00523	15	ppb

365CH-4599-A-001-A	CR 104	8/16/2018	8/21/2018	1808845-19A	Copper	0.0146	0.0000259	1.3	ppm
365CH-4599-A-001-A	CR 104	8/16/2018	8/21/2018	1808845-19A	Lead	5.82	0.00523	15	ppb
365CH-4599-A-001-B	CR 104	8/16/2018	8/21/2018	1808845-20A	Copper	0.00392	0.0000259	1.3	ppm
365CH-4599-A-001-B	CR 104	8/16/2018	8/21/2018	1808845-20A	Lead	1.29	0.00523	15	ppb
365CH-4599-B-001-A	CR 104	8/16/2018	8/21/2018	1808845-21A	Copper	0.0157	0.0000259	1.3	ppm
365CH-4599-B-001-A	CR 104	8/16/2018	8/21/2018	1808845-21A	Lead	3.22	0.00523	15	ppb
365CH-4599-B-001-B	CR 104	8/16/2018	8/21/2018	1808845-22A	Copper	0.00393	0.0000259	1.3	ppm
365CH-4599-B-001-B	CR 104	8/16/2018	8/21/2018	1808845-22A	Lead	0.49	0.00523	15	ppb
365CH-4614-A-001-A	Near Locker Room	8/16/2018	8/21/2018	1808845-23A	Copper	0.209	0.0000259	1.3	ppm
365CH-4614-A-001-A	Near Locker Room	8/16/2018	8/21/2018	1808845-23A	Lead	6.5	0.00523	15	ppb
365CH-4614-A-001-B	Near Locker Room	8/16/2018	8/21/2018	1808845-24A	Copper	0.0154	0.0000259	1.3	ppm
365CH-4614-A-001-B	Near Locker Room	8/16/2018	8/21/2018	1808845-24A	Lead	0.616	0.00523	15	ppb
365CH-4614-B-001-A	Near Locker Room	8/16/2018	8/21/2018	1808845-25A	Copper	0.0706	0.0000259	1.3	ppm
365CH-4614-B-001-A	Near Locker Room	8/16/2018	8/21/2018	1808845-25A	Lead	6.53	0.00523	15	ppb
365CH-4614-B-001-B	Near Locker Room	8/16/2018	8/21/2018	1808845-26A	Copper	0.00756	0.0000259	1.3	ppm
365CH-4614-B-001-B	Near Locker Room	8/16/2018	8/21/2018	1808845-26A	Lead	0.516	0.00523	15	ppb
365CH-4617-A-001-A	Near CR 102	8/16/2018	8/21/2018	1808845-27A	Copper	0.0207	0.0000259	1.3	ppm
365CH-4617-A-001-A	Near CR 102	8/16/2018	8/21/2018	1808845-27A	Lead	2.34	0.00523	15	ppb
365CH-4617-A-001-B	Near CR 102	8/16/2018	8/21/2018	1808845-28A	Copper	0.00432	0.0000259	1.3	ppm
365CH-4617-A-001-B	Near CR 102	8/16/2018	8/21/2018	1808845-28A	Lead	0.201	0.00523	15	ppb

365CH-4617-B-001-A	Near CR 102	8/16/2018	8/21/2018	1808845-29A	Copper	0.0255	0.0000259	1.3	ppm
365CH-4617-B-001-A	Near CR 102	8/16/2018	8/21/2018	1808845-29A	Lead	6.96	0.00523	15	ppb
365CH-4617-B-001-B	Near CR 102	8/16/2018	8/21/2018	1808845-30A	Copper	0.00530	0.0000259	1.3	ppm
365CH-4617-B-001-B	Near CR 102	8/16/2018	8/21/2018	1808845-30A	Lead	0.269	0.00523	15	ppb
365CH-4625-A-001-A	Near CR 301	8/16/2018	8/21/2018	1808845-31A	Copper	0.0239	0.0000259	1.3	ppm
365CH-4625-A-001-A	Near CR 301	8/16/2018	8/21/2018	1808845-31A	Lead	7.09	0.00523	15	ppb
365CH-4625-A-001-B	Near CR 301	8/16/2018	8/21/2018	1808845-32A	Copper	0.0165	0.0000259	1.3	ppm
365CH-4625-A-001-B	Near CR 301	8/16/2018	8/21/2018	1808845-32A	Lead	4.47	0.00523	15	ppb
365CH-4625-B-001-A	Near CR 301	8/16/2018	8/21/2018	1808845-33A	Copper	0.0119	0.0000259	1.3	ppm
365CH-4625-B-001-A	Near CR 301	8/16/2018	8/21/2018	1808845-33A	Lead	2.56	0.00523	15	ppb
365CH-4625-B-001-B	Near CR 301	8/16/2018	8/21/2018	1808845-34A	Copper	0.00435	0.0000259	1.3	ppm
365CH-4625-B-001-B	Near CR 301	8/16/2018	8/21/2018	1808845-34A	Lead	0.872	0.00523	15	ppb
365CH-4621-A-001-A	Near Library	8/16/2018	8/21/2018	1808845-35A	Copper	0.00499	0.0000259	1.3	ppm
365CH-4621-A-001-A	Near Library	8/16/2018	8/21/2018	1808845-35A	Lead	4.39	0.00523	15	ppb
365CH-4621-A-001-B	Near Library	8/16/2018	8/21/2018	1808845-36A	Copper	0.0568	0.0000259	1.3	ppm
365CH-4621-A-001-B	Near Library	8/16/2018	8/21/2018	1808845-36A	Lead	14.5	0.00523	15	ppb
365CH-4621-B-001-A	Near Library	8/16/2018	8/21/2018	1808845-37A	Copper	0.0444	0.0000259	1.3	ppm
365CH-4621-B-001-A	Near Library	8/16/2018	8/21/2018	1808845-37A	Lead	9.16	0.00523	15	ppb
365CH-4621-B-001-B	Near Library	8/16/2018	8/21/2018	1808845-38A	Copper	0.00506	0.0000259	1.3	ppm
365CH-4621-B-001-B	Near Library	8/16/2018	8/21/2018	1808845-38A	Lead	1.88	0.00523	15	ppb