

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Da Vinci Arts Middle School (Monroe) - Test 4**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
365-CH4593-N/A-004-A	Hallway (105)	5/22/2019	6/5/2019	A9E0811-16	Lead	44.40	0.20	15	ppb

Results highlighted indicate a value at or above PPS Action Level and the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.