

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Da Vinci Arts Middle School (Monroe) - Test 3**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
365-CH4597-N/A-003-A	Classroom 207	3/21/2019	3/29/2019	A9C0793-01	Lead	18.10	0.20	15	ppb
365-CH4597-N/A-003-B	Classroom 207	3/22/2019	4/10/2019	A9C0793-02	Lead	6.5	0.20	15	ppb
365-CH4593-N/A-003-A	Hallway (105)	3/23/2019	3/29/2019	A9C0793-03	Lead	45.30	0.20	15	ppb
365-CH4593-N/A-003-B	Hallway (105)	3/24/2019	4/10/2019	A9C0793-04	Lead	54.10	0.20	15	ppb

Results highlighted indicate a value at or above PPS Action Level and the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.