

Portland Public Schools
Lead and Copper Water Sampling Results
Initial and Follow Up Flush Sample Data
Duniway

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
244-CH1100-N/A-001-A	Kitchen Prep	8/13/2018	8/17/2018	1808608-01A	Copper	0.151	0.0000259	1.3	ppm
244-CH1100-N/A-001-A	Kitchen Prep	8/13/2018	8/17/2018	1808608-01A	Lead	11.1	0.00523	15	ppb
244-CH1100-N/A-001-B	Kitchen Prep	8/13/2018	8/17/2018	1808608-02A	Copper	0.0332	0.0000259	1.3	ppm
244-CH1100-N/A-001-B	Kitchen Prep	8/13/2018	8/17/2018	1808608-02A	Lead	3.52	0.00523	15	ppb
244-CH1096-N/A-001-A	Hallway By Rm 1	8/13/2018	8/17/2018	1808608-03A	Copper	0.0316	0.0000259	1.3	ppm
244-CH1096-N/A-001-A	Hallway By Rm 1	8/13/2018	8/17/2018	1808608-03A	Lead	9.94	0.00523	15	ppb
244-CH1096-N/A-001-B	Hallway By Rm 1	8/13/2018	8/17/2018	1808608-04A	Copper	0.00399	0.0000259	1.3	ppm
244-CH1096-N/A-001-B	Hallway By Rm 1	8/13/2018	8/17/2018	1808608-04A	Lead	5.74	0.00523	15	ppb
244-CH1106-N/A-001-A	Cafeteria	8/13/2018	8/17/2018	1808608-05A	Copper	0.0279	0.0000259	1.3	ppm
244-CH1106-N/A-001-A	Cafeteria	8/13/2018	8/17/2018	1808608-05A	Lead	2.48	0.00523	15	ppb
244-CH1106-N/A-001-B	Cafeteria	8/13/2018	8/17/2018	1808608-06A	Copper	0.00534	0.0000259	1.3	ppm
244-CH1106-N/A-001-B	Cafeteria	8/13/2018	8/17/2018	1808608-06A	Lead	0.515	0.00523	15	ppb
244-CH1085-A-001-A	Hallway By Gym	8/13/2018	8/17/2018	1808608-07A	Copper	0.0231	0.0000259	1.3	ppm
244-CH1085-A-001-A	Hallway By Gym	8/13/2018	8/17/2018	1808608-07A	Lead	122	0.00523	15	ppb
244-CH1085-A-001-B	Hallway By Gym	8/13/2018	8/17/2018	1808608-08A	Copper	0.00397	0.0000259	1.3	ppm
244-CH1085-A-001-B	Hallway By Gym	8/13/2018	8/17/2018	1808608-08A	Lead	53.5	0.00523	15	ppb

Analyzed by: Neilson Research Corporation
Reviewed by: PBS Engineering and Environmental

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

244-CH1085-B-001-A	Hallway By Gym	8/13/2018	8/17/2018	1808608-09A	Copper	0.0280	0.0000259	1.3	ppm
244-CH1085-B-001-A	Hallway By Gym	8/13/2018	8/17/2018	1808608-09A	Lead	52.9	0.00523	15	ppb
244-CH1085-B-001-B	Hallway By Gym	8/13/2018	8/17/2018	1808608-10A	Copper	0.00761	0.0000259	1.3	ppm
244-CH1085-B-001-B	Hallway By Gym	8/13/2018	8/17/2018	1808608-10A	Lead	39.8	0.00523	15	ppb
244-CH1068-A-001-A	By Room 16	8/13/2018	8/17/2018	1808608-11A	Copper	0.0491	0.0000259	1.3	ppm
244-CH1068-A-001-A	By Room 16	8/13/2018	8/17/2018	1808608-11A	Lead	141	0.00523	15	ppb
244-CH1068-A-001-B	By Room 16	8/13/2018	8/17/2018	1808608-12A	Copper	0.0102	0.0000259	1.3	ppm
244-CH1068-A-001-B	By Room 16	8/13/2018	8/17/2018	1808608-12A	Lead	94.7	0.00523	15	ppb
244-CH1068-B-001-A	By Room 16	8/13/2018	8/17/2018	1808608-13A	Copper	0.0151	0.0000259	1.3	ppm
244-CH1068-B-001-A	By Room 16	8/13/2018	8/17/2018	1808608-13A	Lead	88.6	0.00523	15	ppb
244-CH1068-B-001-B	By Room 16	8/13/2018	8/17/2018	1808608-14A	Copper	0.00398	0.0000259	1.3	ppm
244-CH1068-B-001-B	By Room 16	8/13/2018	8/17/2018	1808608-14A	Lead	67.9	0.00523	15	ppb
244-CH1082-A-001-A	By Gym	8/13/2018	8/17/2018	1808608-15A	Copper	0.0148	0.0000259	1.3	ppm
244-CH1082-A-001-A	By Gym	8/13/2018	8/17/2018	1808608-15A	Lead	6.23	0.00523	15	ppb
244-CH1082-A-001-B	By Gym	8/13/2018	8/17/2018	1808608-16A	Copper	0.0104	0.0000259	1.3	ppm
244-CH1082-A-001-B	By Gym	8/13/2018	8/17/2018	1808608-16A	Lead	20.6	0.00523	15	ppb
244-CH1082-B-001-A	By Gym	8/13/2018	8/17/2018	1808608-17A	Copper	0.0332	0.0000259	1.3	ppm
244-CH1082-B-001-A	By Gym	8/13/2018	8/17/2018	1808608-17A	Lead	17.3	0.00523	15	ppb
244-CH1082-B-001-B	By Gym	8/13/2018	8/17/2018	1808608-18A	Copper	0.00785	0.0000259	1.3	ppm
244-CH1082-B-001-B	By Gym	8/13/2018	8/17/2018	1808608-18A	Lead	17.5	0.00523	15	ppb

Results highlighted indicate a value at or above the PPS Action Level and that the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.