

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Duniway Elementary School - Test 3**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
244-CH1068-A-003-A	Hallway (16)	4/4/2019	4/16/2019	A9D0320-01	Lead	49.00	0.20	15	ppb
244-CH1068-B-003-A	Hallway (16)	4/4/2019	4/16/2019	A9D0320-03	Lead	32.10	0.20	15	ppb
244-CH1069-N/A-003-A	Classroom 17	4/4/2019	4/16/2019	A9D0320-05	Lead	35.00	0.20	15	ppb
244-CH1082-A-003-A	Hallway (19)	4/4/2019	4/16/2019	A9D0320-07	Lead	9.09	0.20	15	ppb
244-CH1082-B-003-A	Hallway (19)	4/4/2019	4/16/2019	A9D0320-09	Lead	3.81	0.20	15	ppb
244-CH1085-A-003-A	Hallway (Gym/Office)	4/4/2019	4/16/2019	A9D0320-11	Lead	83.30	0.20	15	ppb
244-CH1085-B-003-A	Hallway (Gym/Office)	4/4/2019	4/16/2019	A9D0320-13	Lead	37.10	0.20	15	ppb
244-CH1091-B-003-A	Hallway (12)	4/4/2019	4/16/2019	A9D0320-15	Lead	1.45	0.20	15	ppb
244-CH1094-N/A-003-A	Cafeteria	4/4/2019	4/16/2019	A9D0320-17	Lead	13.1	0.20	15	ppb

Results highlighted indicate a value at or above PPS Action Level and the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.