

Portland Public Schools
Lead and Copper Water Sampling Results
A (Initial) and B (Follow-Up) Sample Data
East Sylvan School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	PPS Action Level*	Units
372-2038-A-001A Hallway by Stair 2	08/02/18 11:02 AM	08/07/18 7:41 PM	18017326	Copper	2.3	1.3	ppm
372-2038-A-001A Hallway by Stair 2	08/02/18 11:02 AM	08/07/18 7:41 PM	18017326	Lead	19	15	ppb
372-2038-A-001B Hallway by Stair 2	08/02/18 11:02 AM	08/07/18 7:45 PM	18017323	Copper	0.6	1.3	ppm
372-2038-A-001B Hallway by Stair 2	08/02/18 11:02 AM	08/07/18 7:45 PM	18017323	Lead	6	15	ppb
372-2039-A-001A Hallway by Stair 1	08/02/18 11:05 AM	08/06/18 8:44 PM	18017324	Copper	0.2	1.3	ppm
372-2039-A-001A Hallway by Stair 1	08/02/18 11:05 AM	08/06/18 8:44 PM	18017324	Lead	4	15	ppb
372-2039-A-001B Hallway by Stair 1	08/02/18 11:05 AM	08/06/18 8:46 PM	18017322	Copper	0.3	1.3	ppm
372-2039-A-001B Hallway by Stair 1	08/02/18 11:05 AM	08/06/18 8:46 PM	18017322	Lead	7	15	ppb
372-2042-A-001A Kitchen	08/02/18 11:15 AM	08/06/18 9:18 PM	18017325	Copper	0.2	1.3	ppm
372-2042-A-001A Kitchen	08/02/18 11:15 AM	08/06/18 9:18 PM	18017325	Lead	8	15	ppb
372-2042-A-001B Kitchen	08/02/18 11:15 AM	08/06/18 8:47 PM	18017321	Copper	0.1	1.3	ppm
372-2042-A-001B Kitchen	08/02/18 11:15 AM	08/06/18 8:47 PM	18017321	Lead	1	15	ppb
372-2043-A-001A Kitchen	08/02/18 11:15 AM	08/06/18 9:20 PM	18017328	Copper	0.2	1.3	ppm
372-2043-A-001A Kitchen	08/02/18 11:15 AM	08/06/18 9:20 PM	18017328	Lead	10	15	ppb
372-2043-A-001B Kitchen	08/02/18 11:15 AM	08/06/18 8:49 PM	18017329	Copper	0.1	1.3	ppm
372-2043-A-001B Kitchen	08/02/18 11:15 AM	08/06/18 8:49 PM	18017329	Lead	1	15	ppb

Results highlighted indicate a value at or above the PPS Action Level and that the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.