

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Odyssey Program at East Sylvan - Test 3**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
372-CH2038-A-003-A	Hallway (4)	4/17/2019	4/25/2019	A9D0758-01	Lead	1.02	0.20	15	ppb
372-CH2038-B-003-B	Hallway (4)	4/17/2019	4/25/2019	A9D0758-02	Lead	0.706	0.20	15	ppb
372-CH2044-N/A-003-A	Hallway	4/17/2019	4/22/2019	A9D0758-03	Lead	15.80	0.20	15	ppb

Results highlighted indicate a value at or above PPS Action Level and the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.