

Portland Public Schools
Lead and Copper Water Sampling Results
A (Initial) and B (Follow-Up) Sample Data
Edwards Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	PPS Action Level*	Units
246-3833-A-002-A Hallway (11&12)	11/07/18 6:59 AM	11/08/18 7:23 PM	18029404	Copper	0.1	1.3	ppm
246-3833-A-002-A Hallway (11&12)	11/07/18 6:59 AM	11/08/18 7:23 PM	18029404	Lead	5	15	ppb
246-3833-A-002-B Hallway (11&12)	11/07/18 7:00 AM	11/08/18 7:28 PM	18029407	Copper	< 0.1	1.3	ppm
246-3833-A-002-B Hallway (11&12)	11/07/18 7:00 AM	11/08/18 7:28 PM	18029407	Lead	< 1	15	ppb
246-3833-B-002-A Hallway (11&12)	11/07/18 7:03 AM	11/08/18 7:34 PM	18029408	Copper	< 0.1	1.3	ppm
246-3833-B-002-A Hallway (11&12)	11/07/18 7:03 AM	11/08/18 7:34 PM	18029408	Lead	1	15	ppb
246-3833-B-002-B Hallway (11&12)	11/07/18 7:04 AM	11/08/18 7:39 PM	18029409	Copper	< 0.1	1.3	ppm
246-3833-B-002-B Hallway (11&12)	11/07/18 7:04 AM	11/08/18 7:39 PM	18029409	Lead	< 1	15	ppb
246-3834-A-002-A Hallway (4)	11/07/18 7:08 AM	11/08/18 7:44 PM	18029410	Copper	< 0.1	1.3	ppm
246-3834-A-002-A Hallway (4)	11/07/18 7:08 AM	11/08/18 7:44 PM	18029410	Lead	2	15	ppb
246-3834-A-002-B Hallway (4)	11/07/18 7:09 AM	11/08/18 7:50 PM	18029411	Copper	< 0.1	1.3	ppm
246-3834-A-002-B Hallway (4)	11/07/18 7:09 AM	11/08/18 7:50 PM	18029411	Lead	< 1	15	ppb
246-3830-A-002-A Staff (Faculty Room)	11/07/18 7:14 AM	11/08/18 8:27 PM	18029412	Copper	< 0.1	1.3	ppm
246-3830-A-002-A Staff (Faculty Room)	11/07/18 7:14 AM	11/08/18 8:27 PM	18029412	Lead	2	15	ppb
246-3830-A-002-B Staff (Faculty Room)	11/07/18 7:15 AM	11/08/18 8:32 PM	18029413	Copper	< 0.1	1.3	ppm
246-3830-A-002-B Staff (Faculty Room)	11/07/18 7:15 AM	11/08/18 8:32 PM	18029413	Lead	< 1	15	ppb
246-3810-A-002-A Staff (2)	11/07/18 7:19 AM	11/12/18 3:23 PM	18029414	Copper	< 0.1	1.3	ppm
246-3810-A-002-A Staff (2)	11/07/18 7:19 AM	11/12/18 12:06 PM	18029414	Lead	11	15	ppb
246-3810-A-002-B Staff (2)	11/07/18 7:20 AM	11/08/18 8:38 PM	18029415	Copper	0.2	1.3	ppm
246-3810-A-002-B Staff (2)	11/07/18 7:20 AM	11/08/18 8:38 PM	18029415	Lead	< 1.0	15	ppb
246-3810-B-002-A Staff (2)	11/07/18 7:21 AM	11/12/18 12:10 PM	18029416	Copper	0.3	1.3	ppm
246-3810-B-002-A Staff (2)	11/07/18 7:21 AM	11/12/18 3:23 PM	18029416	Lead	40	15	ppb
246-3810-B002-B Staff (2)	11/07/18 7:22 AM	11/12/18 3:23 PM	18029417	Copper	0.2	1.3	ppm
246-3810-B002-B Staff (2)	11/07/18 7:22 AM	11/12/18 12:13 PM	18029417	Lead	55	15	ppb
246-3827-A-002A Main Office Bubbles	11/07/18 7:27 AM	11/08/18 8:43 PM	18029418	Copper	< 0.1	1.3	ppm
246-3827-A-002A Main Office Bubbles	11/07/18 7:27 AM	11/08/18 8:43 PM	18029418	Lead	3	15	ppb
246-3827-A-002B Main Office Bubbles	11/07/18 7:28 AM	11/08/18 8:48 PM	18029419	Copper	< 0.1	1.3	ppm
246-3827-A-002B Main Office Bubbles	11/07/18 7:28 AM	11/08/18 8:48 PM	18029419	Lead	2	15	ppb
246-3822 A-002A Classroom 5 Bubblers	11/07/18 7:32 AM	11/08/18 8:54 PM	18029420	Copper	< 0.1	1.3	ppm
246-3822 A-002A Classroom 5 Bubblers	11/07/18 7:32 AM	11/08/18 8:54 PM	18029420	Lead	< 1	15	ppb
246-3822-A-002B Classroom 5 Bubblers	11/07/18 7:33 AM	11/08/18 8:59 PM	18029421	Copper	< 0.1	1.3	ppm
246-3822-A-002B Classroom 5 Bubblers	11/07/18 7:33 AM	11/08/18 8:59 PM	18029421	Lead	< 1	15	ppb
246-3813-A-002A Classroom 3 Bubbles	11/07/18 7:38 AM	11/12/18 3:23 PM	18029422	Copper	0.2	1.3	ppm
246-3813-A-002A Classroom 3 Bubbles	11/07/18 7:38 AM	11/12/18 12:17 PM	18029422	Lead	15	15	ppb
246-3813-A-002B Classroom 3 Bubbles	11/07/18 7:39 AM	11/08/18 9:04 PM	18029423	Copper	< 0.1	1.3	ppm
246-3813-A-002B Classroom 3 Bubbles	11/07/18 7:39 AM	11/08/18 9:04 PM	18029423	Lead	5	15	ppb

Results highlighted indicate a value at or above the PPS Action Level and that the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.