Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Day Program at Edwards School (Trillium Family Services) - Test 3

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
246-CH3810-A-003-A	Staff Room 2	4/25/2019	5/6/2019	A9D0961-01	Lead	15.00	0.20	15	ppb
246-CH3825-N/A-003-A	Classroom 8	4/25/2019	5/6/2019	A9D0961-02	Lead	12	0.20	15	ppb
246-CH3831-N/A-003-A	Library/Media Center	4/25/2019	5/8/2019	A9D0961-03	Lead	28.50	0.20	15	ppb

Results highlighted indicate a value at or above PPS Action Level and the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.

*OHA Action Level = 15ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek