

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Faubion**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
248-CH5670-N/A-001-A	Coffee Bar (back of 192)	4/27/2019	4/29/2019	A9E0020-04	Lead	1.63	0.2	15	ppb
248-CH5671-N/A-001-A	Partner workroom (169)	4/27/2019	4/29/2019	A9E0020-25	Lead	0.56	0.2	15	ppb
248-CH5672-A-001-A	Hall near Mothers room	4/27/2019	4/29/2019	A9E0020-01	Lead	ND	0.2	15	ppb
248-CH5672-B-001-A	Hall near Mothers room	4/27/2019	4/29/2019	A9E0020-02	Lead	ND	0.2	15	ppb
248-CH5672-C-001-A	Hall near Mothers room	4/27/2019	4/29/2019	A9E0020-03	Lead	ND	0.2	15	ppb
248-CH5673-N/A-001-A	PK&K Staff (154) NKZ	4/27/2019	4/29/2019	A9E0020-06	Lead	0.494	0.2	15	ppb
248-CH5674-N/A-001-A	PK&K Project (150)	4/27/2019	4/29/2019	A9E0020-05	Lead	0.347	0.2	15	ppb
248-CH5675-N/A-001-A	PK&K Project (116)	4/27/2019	4/29/2019	A9E0020-07	Lead	0.73	0.2	15	ppb
248-CH5676-A-001-A	Cafeteria	4/27/2019	4/29/2019	A9E0020-10	Lead	ND	0.2	15	ppb
248-CH5676-B-001-A	Cafeteria	4/27/2019	4/29/2019	A9E0020-11	Lead	0.23	0.2	15	ppb
248-CH5677-N/A-001-A	Kitchen (125)	4/27/2019	4/29/2019	A9E0020-08	Lead	0.621	0.2	15	ppb
248-CH5678-A-001-A	Gym	4/27/2019	4/29/2019	A9E0020-12	Lead	ND	0.2	15	ppb
248-CH5678-B-001-A	Gym	4/27/2019	4/29/2019	A9E0020-13	Lead	ND	0.2	15	ppb
248-CH5679-N/A-001-A	TLC Staff Lounge	4/27/2019	4/29/2019	A9E0020-17	Lead	ND	0.2	15	ppb
248-CH5680-A-001-A	Hallway Art CR 201	4/27/2019	4/29/2019	A9E0020-14	Lead	0.442	0.2	15	ppb
248-CH5680-B-001-A	Hallway Art CR 202	4/27/2019	4/29//2019	A9E0020-15	Lead	ND	0.2	15	ppb
248-CH5680-C-001-A	Hallway Art CR 203	4/27/2019	4/29/2019	A9E0020-16	Lead	ND	0.2	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

*OHA Action Level for lead is 15.0 ppb

248-CH5681-N/A-001-A	Flex (210)	4/27/2019	4/29/2019	A9E0020-18	Lead	0.601	0.2	15	ppb
248-CH5682-N/A-001-A	Flex (218)	4/27/2019	4/29/2019	A9E0020-19	Lead	0.567	0.2	15	ppb
248-CH5683-A-001-A	Hallway (Science 301)	4/27/2019	4/29/2019	A9E0020-20	Lead	ND	0.2	15	ppb
248-CH5683-B-001-A	Hallway (Science 301)	4/27/2019	4/29/2019	A9E0020-21	Lead	ND	0.2	15	ppb
248-CH5683-C-001-A	Hallway (Science 301)	4/27/2019	4/29/2019	A9E0020-22	Lead	ND	0.2	15	ppb
248-CH5684-N/A-001-A	Flex (310)	4/27/2019	4/29/2019	A9E0020-23	Lead	2.7	0.2	15	ppb
248-CH5685-N/A-001-A	Flex (318)	4/27/2019	4/29/2019	A9E0020-24	Lead	ND	0.2	15	ppb
248-CH5686-N/A-001-A	Kitchen (125) Steam Kettle	4/27/2019	4/29/2019	A9E0020-09	Lead	2.74	0.2	15	ppb