

Portland Public Schools
Lead and Copper Water Sampling Results
A (Initial) and B (Follow-Up) Sample Data
Forest Park Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	PPS Action Level*	Units
152-1997-A-001A Cafeteria	08/03/18 7:15 AM	08/07/18 8:15 PM	18017615	Copper	2.1	1.3	ppm
152-1997-A-001A Cafeteria	08/03/18 7:15 AM	08/07/18 8:15 PM	18017615	Lead	154	15	ppb
152-1997-A-001B Cafeteria	08/03/18 7:15 AM	08/06/18 2:35 PM	18017606	Copper	0.6	1.3	ppm
152-1997-A-001B Cafeteria	08/03/18 7:15 AM	08/06/18 2:35 PM	18017606	Lead	3	15	ppb
152-1996-A-001A Cafeteria	08/03/18 7:15 AM	08/06/18 2:37 PM	18017617	Copper	0.8	1.3	ppm
152-1996-A-001A Cafeteria	08/03/18 7:15 AM	08/06/18 2:37 PM	18017617	Lead	9	15	ppb
152-1996-A-001B Cafeteria	08/03/18 7:15 AM	08/06/18 2:38 PM	18017608	Copper	0.2	1.3	ppm
152-1996-A-001B Cafeteria	08/03/18 7:15 AM	08/06/18 2:38 PM	18017608	Lead	1	15	ppb
152-2027-A-001A Kitchen	08/03/18 7:25 AM	08/06/18 2:40 PM	18017613	Copper	0.2	1.3	ppm
152-2027-A-001A Kitchen	08/03/18 7:25 AM	08/06/18 2:40 PM	18017613	Lead	3	15	ppb
152-2027-A-001B Kitchen	08/03/18 7:25 AM	08/06/18 2:42 PM	18017612	Copper	0.1	1.3	ppm
152-2027-A-001B Kitchen	08/03/18 7:25 AM	08/06/18 2:42 PM	18017612	Lead	<1	15	ppb
152-1999-A-001A Kitchen	08/03/18 7:27 AM	08/06/18 2:44 PM	18017614	Copper	0.2	1.3	ppm
152-1999-A-001A Kitchen	08/03/18 7:27 AM	08/06/18 2:44 PM	18017614	Lead	2	15	ppb
152-1999-A-001B Kitchen	08/03/18 7:27 AM	08/06/18 2:46 PM	18017609	Copper	0.3	1.3	ppm
152-1999-A-001B Kitchen	08/03/18 7:27 AM	08/06/18 2:46 PM	18017609	Lead	<1	15	ppb
152-2033-A-001A Near Rm 131	08/03/18 7:35 AM	08/06/18 3:56 PM	18017607	Copper	2.5	1.3	ppm
152-2033-A-001A Near Rm 131	08/03/18 7:35 AM	08/06/18 2:47 PM	18017607	Lead	45	15	ppb
152-2033-A-001B Near Rm 131	08/03/18 7:35 AM	08/06/18 3:58 PM	18017611	Copper	1.4	1.3	ppm
152-2033-A-001B Near Rm 131	08/03/18 7:35 AM	08/06/18 3:00 PM	18017611	Lead	6	15	ppb
152-2034-A-001A Near Rm 131	08/03/18 7:35 AM	08/06/18 4:00 PM	18017610	Copper	1.1	1.3	ppm
152-2034-A-001A Near Rm 131	08/03/18 7:35 AM	08/06/18 3:02 PM	18017610	Lead	24	15	ppb
152-2034-A-001B Near Rm 131	08/03/18 7:35 AM	08/06/18 3:04 PM	18017616	Copper	0.6	1.3	ppm
152-2034-A-001B Near Rm 131	08/03/18 7:35 AM	08/06/18 3:04 PM	18017616	Lead	3	15	ppb
152-2030-A-001A Near Rm 116	08/03/18 7:42 AM	08/06/18 4:02 PM	18017604	Copper	1.6	1.3	ppm
152-2030-A-001A Near Rm 116	08/03/18 7:42 AM	08/06/18 3:06 PM	18017604	Lead	13	15	ppb
152-2030-A-001B Near Rm 116	08/03/18 7:42 AM	08/06/18 4:03 PM	18017605	Copper	1.8	1.3	ppm
152-2030-A-001B Near Rm 116	08/03/18 7:42 AM	08/06/18 3:07 PM	18017605	Lead	2	15	ppb
152-2031-A-001A Near Rm 116	08/03/18 7:45 AM	08/06/18 4:05 PM	18017619	Copper	2.1	1.3	ppm
152-2031-A-001A Near Rm 116	08/03/18 7:45 AM	08/06/18 3:09 PM	18017619	Lead	14	15	ppb
152-2031-A-001B Near Rm 116	08/03/18 7:45 AM	08/06/18 3:11 PM	18017620	Copper	0.8	1.3	ppm
152-2031-A-001B Near Rm 116	08/03/18 7:45 AM	08/06/18 3:11 PM	18017620	Lead	2	15	ppb
152-2035-A-001A Near Rm 201	08/03/18 7:50 AM	08/06/18 4:25 PM	18017621	Copper	2.2	1.3	ppm
152-2035-A-001A Near Rm 201	08/03/18 7:50 AM	08/06/18 3:13 PM	18017621	Lead	15	15	ppb
152-2035-A-001B Near Rm 201	08/03/18 7:50 AM	08/06/18 3:15 PM	18017622	Copper	0.9	1.3	ppm
152-2035-A-001B Near Rm 201	08/03/18 7:50 AM	08/06/18 3:15 PM	18017622	Lead	6	15	ppb
152-2036-A-001A Near Rm 201	08/03/18 7:50 AM	08/06/18 4:27 PM	18017623	Copper	1.8	1.3	ppm
152-2036-A-001A Near Rm 201	08/03/18 7:50 AM	08/06/18 3:16 PM	18017623	Lead	8	15	ppb
152-2036-A-001B Near Rm 201	08/03/18 7:50 AM	08/06/18 3:29 PM	18017624	Copper	0.5	1.3	ppm
152-2036-A-001B Near Rm 201	08/03/18 7:50 AM	08/06/18 3:29 PM	18017624	Lead	3	15	ppb

Results highlighted indicate a value at or above the PPS Action Level and that the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.