

**Portland Public Schools
Lead and Copper Water Sampling Results
Initial and Follow Up Flush Sample Data
Forest Park**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
152-CH2033-N/A-003-A	Hallway 131	10/20/2018	10/26/2018	A8J0664-01	Copper	0.747	0.00200	1.3	ppm
152-CH2033-N/A-003-A	Hallway 131	10/20/2018	10/26/2018	A8J0664-01	Lead	4.83	0.200	15	ppb
152-CH2033-N/A-003-B	Hallway 131	10/20/2018	10/26/2018	A8J0664-02	Copper	0.746	0.00200	1.3	ppm
152-CH2033-N/A-003-B	Hallway 131	10/20/2018	10/26/2018	A8J0664-02	Lead	0.941	0.200	15	ppb