

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Forest Park Elementary School - Test 4**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
152-CH2030-N/A-004-A	Hallway (116)	4/16/2019	4/26/2019	A9D0752-01	Lead	2.13	0.20	15	ppb