

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Franklin**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
215-CH5630-N/A-001-A	Life Skills (6031)	5/11/2019	5/13/2019	A9E0428-32	Lead	0.262	0.2	15	ppb
215-CH5631-N/A-001-A	Life Skills (6030)	5/11/2019	5/13/2019	A9E0428-33	Lead	ND	0.2	15	ppb
215-CH5632-A-001-A	Hallway (6019)	5/11/2019	5/13/2019	A9E0428-29	Lead	ND	0.2	15	ppb
215-CH5632-B-001-A	Hallway (6019)	5/11/2019	5/13/2019	A9E0428-30	Lead	ND	0.2	15	ppb
215-CH5632-C-001-A	Hallway (6019)	5/11/2019	5/13/2019	A9E0428-31	Lead	ND	0.2	15	ppb
215-CH5633-N/A-001-A	Teacher Office (6026)	5/11/2019	5/13/2019	A9E0428-28	Lead	0.461	0.2	15	ppb
215-CH5634-A-001-A	Weight Room (7014)	5/11/2019	5/13/2019	A9E0428-57	Lead	ND	0.2	15	ppb
215-CH5634-B-001-A	Weight Room (7014)	5/11/2019	5/13/2019	A9E0428-58	Lead	ND	0.2	15	ppb
215-CH5634-C-001-A	Weight Room (7014)	5/11/2019	5/13/2019	A9E0428-59	Lead	ND	0.2	15	ppb
215-CH5635-A-001-A	Girls Locker (7020)	5/11/2019	5/13/2019	A9E0428-54	Lead	ND	0.2	15	ppb
215-CH5635-B-001-A	Girls Locker (7020)	5/11/2019	5/13/2019	A9E0428-55	Lead	ND	0.2	15	ppb
215-CH5635-C-001-A	Girls Locker (7020)	5/11/2019	5/13/2019	A9E0428-56	Lead	ND	0.2	15	ppb
215-CH5636-A-001-A	Boys Locker (7028)	5/11/2019	5/13/2019	A9E0428-51	Lead	ND	0.2	15	ppb
215-CH5636-B-001-A	Boys Locker (7028)	5/11/2019	5/13/2019	A9E0428-52	Lead	ND	0.2	15	ppb
215-CH5636-C-001-A	Boys Locker (7028)	5/11/2019	5/13/2019	A9E0428-53	Lead	ND	0.2	15	ppb
215-CH5637-A-001-A	Elec (7036)	5/11/2019	5/13/2019	A9E0428-48	Lead	ND	0.2	15	ppb
215-CH5637-B-001-A	Elec (7036)	5/11/2019	5/13/2019	A9E0428-49	Lead	ND	0.2	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

*OHA Action Level for lead is 15.0 ppb

Page 1 of 4

215-CH5637-C-001-A	Elec (7036)	5/11/2019	5/13/2019	A9E0428-50	Lead	ND	0.2	15	ppb
215-CH5638-N/A-001-A	Concessions (8001)	5/11/2019	5/13/2019	A9E0428-62	Lead	2.38	0.2	15	ppb
215-CH5639-A-001-A	hallway (Gen Ed 2117)	5/11/2019	5/13/2019	A9E0428-04	Lead	ND	0.2	15	ppb
215-CH5639-B-001-A	hallway (Gen Ed 2117)	5/11/2019	5/13/2019	A9E0428-05	Lead	ND	0.2	15	ppb
215-CH5639-C-001-A	hallway (Gen Ed 2117)	5/11/2019	5/13/2019	A9E0428-06	Lead	ND	0.2	15	ppb
215-CH5640-N/A-001-A	Teacher Office (3106)	5/11/2019	5/13/2019	A9E0428-13	Lead	0.588	0.2	15	ppb
215-CH5642-A-001-A	hallway (near Daycare)	5/11/2019	5/13/2019	A9E0428-01	Lead	ND	0.2	15	ppb
215-CH5642-B-001-A	hallway (near Daycare)	5/11/2019	5/13/2019	A9E0428-02	Lead	ND	0.2	15	ppb
215-CH5642-C-001-A	hallway (near Daycare)	5/11/2019	5/13/2019	A9E0428-03	Lead	ND	0.2	15	ppb
215-CH5643-N/A-001-A	Work Room 1 (4134)	5/11/2019	5/13/2019	A9E0428-60	Lead	0.347	0.2	15	ppb
215-CH5644-N/A-001-A	Kitchen (5109)	5/11/2019	5/13/2019	A9E0428-17	Lead	0.36	0.2	15	ppb
215-CH5645-A-001-A	Kitchen Sprayer	5/11/2019	5/13/2019	A9E0428-18	Lead	0.236	0.2	15	ppb
215-CH5645-B-001-A	Kitchen Faucet	5/11/2019	5/13/2019	A9E0428-19	Lead	ND	0.2	15	ppb
215-CH5646-N/A-001-A	Kitchen Kettle	5/11/2019	5/13/2019	A9E0428-20	Lead	38.2	0.2	15	ppb
215-CH5647-N/A-001-A	Kitchen Skillet	5/11/2019	5/13/2019	A9E0428-21	Lead	5.92	0.2	15	ppb
215-CH5649-A-001-A	Kitchen (5109)	5/11/2019	5/13/2019	A9E0428-14	Lead	ND	0.2	15	ppb
215-CH5649-B-001-A	Kitchen (5109)	5/11/2019	5/13/2019	A9E0428-15	Lead	ND	0.2	15	ppb
215-CH5649-C-001-A	Kitchen (5109)	5/11/2019	5/13/2019	A9E0428-16	Lead	ND	0.2	15	ppb
215-CH5650-A-001-A	Main Gym (7115)	5/11/2019	5/13/2019	A9E0428-37	Lead	ND	0.2	15	ppb
215-CH5650-B-001-A	Main Gym (7115)	5/11/2019	5/13/2019	A9E0428-38	Lead	ND	0.2	15	ppb
215-CH5650-C-001-A	Main Gym (7115)	5/11/2019	5/13/2019	A9E0428-39	Lead	ND	0.2	15	ppb
215-CH5651-A-001-A	Main Gym (7115)	5/11/2019	5/13/2019	A9E0428-34	Lead	1.31	0.2	15	ppb

Analyzed by: Apex Laboratories

*OHA Action Level for lead is 15.0 ppb

Reviewed by: PBS Engineering and Environmental

Page 2 of 4

215-CH5651-B-001-A	Main Gym (7115)	5/11/2019	5/13/2019	A9E0428-35	Lead	1.4	0.2	15	ppb
215-CH5651-C-001-A	Main Gym (7115)	5/11/2019	5/13/2019	A9E0428-36	Lead	1.35	0.2	15	ppb
215-CH5652-A-001-A	Culinary Arts (7111)	5/11/2019	5/13/2019	A9E0428-40	Lead	1.02	0.2	15	ppb
215-CH5652-B-001-A	Culinary Arts (7111)	5/11/2019	5/13/2019	A9E0428-41	Lead	1.08	0.2	15	ppb
215-CH5653-A-001-A	Hallway (Culinary Arts)	5/11/2019	5/13/2019	A9E0428-42	Lead	0.385	0.2	15	ppb
215-CH5653-B-001-A	Hallway (Culinary Arts)	5/11/2019	5/13/2019	A9E0428-43	Lead	0.433	0.2	15	ppb
215-CH5653-C-001-A	Hallway (Culinary Arts)	5/11/2019	5/13/2019	A9E0428-44	Lead	0.437	0.2	15	ppb
215-CH5654-N/A-001-A	Teacher Office (2217)	5/11/2019	5/13/2019	A9E0428-27	Lead	0.791	0.2	15	ppb
215-CH5655-N/A-001-A	Teacher Office (3206)	5/11/2019	5/13/2019	A9E0428-63	Lead	0.57	0.2	15	ppb
215-CH5656-A-001-A	Hallway Gen Ed (4218)	5/11/2019	5/13/2019	A9E0428-23	Lead	0.302	0.2	15	ppb
215-CH5656-B-001-A	Hallway Gen Ed (4218)	5/11/2019	5/13/2019	A9E0428-24	Lead	ND	0.2	15	ppb
215-CH5656-C-001-A	Hallway Gen Ed (4218)	5/11/2019	5/13/2019	A9E0428-25	Lead	ND	0.2	15	ppb
215-CH5657-N/A-001-A	Teacher Office (4202)	5/11/2019	5/13/2019	A9E0428-26	Lead	0.287	0.2	15	ppb
215-CH5658-N/A-001-A	Teacher Office (4237)	5/11/2019	5/13/2019	A9E0428-22	Lead	0.354	0.2	15	ppb
215-CH5659-N/A-001-A	Kitchenette (5216)	5/11/2019	5/13/2019	A9E0428-61	Lead	ND	0.2	15	ppb
215-CH5660-A-001-A	Aux Gym (7205)	5/11/2019	5/13/2019	A9E0428-45	Lead	0.687	0.2	15	ppb
215-CH5660-B-001-A	Aux Gym (7205)	5/11/2019	5/13/2019	A9E0428-46	Lead	0.727	0.2	15	ppb
215-CH5660-C-001-A	Aux Gym (7205)	5/11/2019	5/13/2019	A9E0428-47	Lead	0.711	0.2	15	ppb
215-CH5661-A-001-A	Hallway (Auditorium)	5/11/2019	5/13/2019	A9E0428-07	Lead	ND	0.2	15	ppb
215-CH5661-B-001-A	Hallway (Auditorium)	5/11/2019	5/13/2019	A9E0428-08	Lead	ND	0.2	15	ppb
215-CH5661-C-001-A	Hallway (Auditorium)	5/11/2019	5/13/2019	A9E0428-09	Lead	ND	0.2	15	ppb
215-CH5662-A-001-A	Hallway (near S-016)	5/11/2019	5/13/2019	A9E0428-10	Lead	ND	0.2	15	ppb

Analyzed by: Apex Laboratories

*OHA Action Level for lead is 15.0 ppb

Reviewed by: PBS Engineering and Environmental

Page 3 of 4

215-CH5662-B-001-A	Hallway (near S-016)	5/11/2019	5/13/2019	A9E0428-11	Lead	ND	0.2	15	ppb
215-CH5662-C-001-A	Hallway (near S-016)	5/11/2019	5/13/2019	A9E0428-12	Lead	ND	0.2	15	ppb