

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
George Middle School - Test 4**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
156-CH2786-N/A-004-A	Hallway (150)	4/2/2019	4/16/2019	A9D0327-01	Lead	2.07	0.20	15	ppb
156-CH2807-N/A-004-A	Hallway (201)	4/2/2019	4/16/2019	A9D0327-03	Lead	7.42	0.20	15	ppb
156-CH2838-N/A-004-A	Classroom 124	4/2/2019	4/16/2019	A9D0327-05	Lead	23.20	0.20	15	ppb

Results highlighted indicate a value at or above PPS Action Level and the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.