

Portland Public Schools
Lead and Copper Water Sampling Results
A (Initial) and B (Follow-Up) Sample Data
Glencoe Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	PPS Action Level*	Units
157-1746-A-001A Main Hall S. Drink. FT	08/07/18 7:40 AM	08/09/18 6:24 PM	18018039	Copper	0.6	1.3	ppm
157-1746-A-001A Main Hall S. Drink. FT	08/07/18 7:40 AM	08/08/18 6:26 PM	18018039	Lead	< 1	15	ppb
157-1746-A-001B Main Hall S. Drink. FT	08/07/18 7:41 AM	08/09/18 6:28 PM	18018041	Copper	0.6	1.3	ppm
157-1746-A-001B Main Hall S. Drink. FT	08/07/18 7:41 AM	08/08/18 6:28 PM	18018041	Lead	< 1	15	ppb
157-1749-A-001A Main Hall N. Drink. FT	08/07/18 7:45 AM	08/09/18 6:32 PM	18018043	Copper	0.9	1.3	ppm
157-1749-A-001A Main Hall N. Drink. FT	08/07/18 7:45 AM	08/08/18 6:30 PM	18018043	Lead	< 1	15	ppb
157-1749-A-001B Main Hall N. Drink. FT	08/07/18 7:46 AM	08/09/18 6:35 PM	18018040	Copper	1.1	1.3	ppm
157-1749-A-001B Main Hall N. Drink. FT	08/07/18 7:46 AM	08/08/18 6:31 PM	18018040	Lead	1	15	ppb
157-1753-A-001A Double D. TF. Cafetorium	08/07/18 7:50 AM	08/08/18 6:33 PM	18018042	Copper	0.4	1.3	ppm
157-1753-A-001A Double D. TF. Cafetorium	08/07/18 7:50 AM	08/08/18 6:33 PM	18018042	Lead	< 1	15	ppb
157-1753-A-001B Double D. TF. Cafetorium	08/07/18 7:51 AM	08/08/18 6:35 PM	18018038	Copper	< 0.1	1.3	ppm
157-1753-A-001B Double D. TF. Cafetorium	08/07/18 7:51 AM	08/08/18 6:35 PM	18018038	Lead	< 1	15	ppb
157-1753-B-001A Double D. FT. Cafetorium	08/07/18 7:53 AM	08/08/18 6:37 PM	18018047	Copper	0.2	1.3	ppm
157-1753-B-001A Double D. FT. Cafetorium	08/07/18 7:53 AM	08/08/18 6:37 PM	18018047	Lead	1	15	ppb
157-1753-B-001B Double D. FT. Cafetorium	08/07/18 7:54 AM	08/08/18 6:39 PM	18018046	Copper	< 0.1	1.3	ppm
157-1753-B-001B Double D. FT. Cafetorium	08/07/18 7:54 AM	08/08/18 6:39 PM	18018046	Lead	< 1	15	ppb
157-1756-A-001A Kitch. DBL Sink	08/07/18 8:00 AM	08/08/18 6:40 PM	18018049	Copper	0.3	1.3	ppm
157-1756-A-001A Kitch. DBL Sink	08/07/18 8:00 AM	08/08/18 6:40 PM	18018049	Lead	< 1	15	ppb
157-1756-A-001B Kitch. DBL Sink	08/07/18 8:01 AM	08/08/18 6:51 PM	18018048	Copper	0.4	1.3	ppm
157-1756-A-001B Kitch. DBL Sink	08/07/18 8:01 AM	08/08/18 6:51 PM	18018048	Lead	< 1	15	ppb
157-1751-A-001A 2nd FL. Hall S. D. FT	08/07/18 8:07 AM	08/10/18 11:25 AM	18018045	Copper	0.7	1.3	ppm
157-1751-A-001A 2nd FL. Hall S. D. FT	08/07/18 8:07 AM	08/08/18 6:53 PM	18018045	Lead	2	15	ppb
157-1751-A-001B 2nd FL. Hall S. D. FT	08/07/18 8:08 AM	08/10/18 11:29 AM	18018044	Copper	0.7	1.3	ppm
157-1751-A-001B 2nd FL. Hall S. D. FT	08/07/18 8:08 AM	08/08/18 6:55 PM	18018044	Lead	< 1	15	ppb
157-1754-A-001A 2nd FL. Hall S. D. FT	08/07/18 8:12 AM	08/10/18 11:32 AM	18018050	Copper	0.7	1.3	ppm
157-1754-A-001A 2nd FL. Hall S. D. FT	08/07/18 8:12 AM	08/08/18 6:57 PM	18018050	Lead	< 1	15	ppb
157-1754-A-001B 2nd FL. Hall S. D. FT	08/07/18 8:13 AM	08/10/18 11:36 AM	18018051	Copper	1.1	1.3	ppm
157-1754-A-001B 2nd FL. Hall S. D. FT	08/07/18 8:13 AM	08/08/18 6:58 PM	18018051	Lead	< 1	15	ppb
157-1737-A-001A Play Court D. FT. Left	08/07/18 8:37 AM	08/08/18 7:00 PM	18018052	Copper	0.2	1.3	ppm
157-1737-A-001A Play Court D. FT. Left	08/07/18 8:37 AM	08/08/18 7:00 PM	18018052	Lead	< 1	15	ppb
157-1737-A-001B Play Court D. FT. Left	08/07/18 8:38 AM	08/08/18 7:02 PM	18018053	Copper	< 0.1	1.3	ppm
157-1737-A-001B Play Court D. FT. Left	08/07/18 8:38 AM	08/08/18 7:02 PM	18018053	Lead	< 1	15	ppb
157-1737-B-001A Play Court D. FT. RT.	08/07/18 8:42 AM	08/08/18 7:04 PM	18018054	Copper	0.2	1.3	ppm
157-1737-B-001A Play Court D. FT. RT.	08/07/18 8:42 AM	08/08/18 7:04 PM	18018054	Lead	< 1	15	ppb
157-1737-B-001B Play Court D. FT. RT.	08/07/18 8:43 AM	08/08/18 7:06 PM	18018055	Copper	< 0.1	1.3	ppm
157-1737-B-001B Play Court D. FT. RT.	08/07/18 8:43 AM	08/08/18 7:06 PM	18018055	Lead	< 1	15	ppb

Analyzed by: Pixis Labs

*EPA action level for lead is 20 ppb and 1.3 for copper

Reviewed by: TRC Environmental Corporation